



April 9, 2026

## RESPONSE LETTER NO. 1 TO REQUEST FOR INFORMATION

Project Title: Midway Pump Station Telemetry Improvements & Drainage Improvements Multiple Sites

Project No.: 20260067

**E-mail from Ms. Gretta Haber, Haber & Sons Plumbing, Inc.; dated Wednesday, April 8, 2026, 08:34 A.M. (attached)**

QUESTION: 1) Please confirm whether Emerson Process Management will be handling all work and materials related to the telemetry system.

RESPONSE: 1) Emerson will provide the telemetry hardware, required system configurations, and radio survey services necessary for the antenna system. In addition, Emerson will supply instrumentation, fully assembled controller/RTU panels, and solar power hardware. However, Emerson will not perform installation work or provide the appurtenances required for installation.

QUESTION: 2) Also, please provide a contact name and information for Emerson Process Management so we can reach out directly to request a quote for our bid.

RESPONSE: 2) Project Engineer: Rafael Jacomino 305-898-8095

[rafael.jacomino@emerson.com](mailto:rafael.jacomino@emerson.com)

Account Representative: Jack Lyons (407) 342-7534

[john.lyons@emerson.com](mailto:john.lyons@emerson.com)

**END OF REQUEST FOR INFORMATION No. 1**



Department of Transportation and Public Works  
111 NW 1<sup>st</sup> • Street Suite 1410  
Miami, Florida 33128-1970  
T 305-375-2930 F 305-375-2931  
[miamidade.gov](http://miamidade.gov)

Sincerely,

A handwritten signature in cursive script that reads "Elva Reyes".

Elva R. Reyes  
Engineer 2  
Department of Transportation and Public Works (DTPW)

C:  
Tiondra Wright, DTPW  
Katherine Fernandez, DTPW  
Fernando Ramos, DTPW  
Eric Perez, SPD  
Clerk of the Board  
Project File

**From:** [Haber & Sons Office](#)  
**To:** [Reyes, Elva \(DTPW\)](#)  
**Cc:** [Clerk of the Board \(COC\)](#)  
**Subject:** RFI Request - Midway Pump Station Telemetry System  
**Date:** Wednesday, April 8, 2026 8:34:15 AM  
**Attachments:** [RFI #1.pdf](#)

---

Some people who received this message don't often get email from office@haberandsonsplumbing.com. [Learn why this is important](#)

Good morning,

Please see the attached document for our formal Request for Information (RFI) regarding the Midway Pump Station Telemetry System. We appreciate your help with this and look forward to your response.

Sincerely,  
Gretta Haber.

As previously announced, we are in the process of implementing the new email system.

Please remember to use this email address for **all office purposes**. For proposal and invoices, please use our other email address: [billing@haberandsonsplumbing.com](mailto:billing@haberandsonsplumbing.com)

Formally known as [haberandplumbing@bellsouth.net](mailto:haberandplumbing@bellsouth.net)

Thank you for updating your records.

## **Haber & Sons Plumbing, Inc.**

**4106 NW 37th Ave**

**Miami, FL 33142**

**Office: (305) 637-7434**

**(305) 461-8653**

# Haber & Son's Plumbing, Inc.

4106 NW 37th Ave. Miami, FL 33142

Office: (305) 637-7434 (305) 461-8653

E-mail: [haberandplumbing@bellsouth.net](mailto:haberandplumbing@bellsouth.net)

<b>TO:</b>	Elva Reyes
<b>FROM:</b>	Haber & Sons Plumbing Inc.

<b>Project Name</b>	Midway Pump Station Telemetry System Improvements & Drainage Improvements
<b>Project Location</b>	Multiple Sites

RFI #	Request Date	Response Date
1	Apr 08, 2026	

Information Requested
<p>Please confirm wheter Emerson Process Management will be handling all work and materials related to the telemetry system.</p> <p>Also, please provide a contact name and information for Emerson Process Management so we can reach out directly to request a quote for our bid.</p> <p>Thanks in advance for your time and attention.</p>

<b>Name of Contractor:</b> Jose Haber	
<b>Signature:</b> <i>Jose Haber</i>	<b>Title:</b> President

<b>Date Received:</b>	
<b>Received By:</b>	<b>Print Name:</b>