



April 23, 2026

RESPONSE LETTER NO. 2 TO REQUEST FOR INFORMATION

Project Title: Midway Pump Station Telemetry Improvements & Drainage Improvements Multiple Sites

Project No.: 20260067

E-mail from Ms. Lory Roy, Acosta Tractors, Inc.; dated Monday, April 20, 2026, 04:56 P.M. (attached)

QUESTION: 1) Bid Item 425-82 MODIFY STRUCTURE – Cut to enlarge opening as needed in order to accommodate pipe due to utility conflict(s) brick and mortar as needed.

Is there a specific location(s) where this bid item applies? If not, please provide additional information with an example of how this bid item would be used.

RESPONSE: 1) There is no specific location associated with this bid pay item. It is intended for use on new structures after shop drawings have been approved, in cases where unforeseen utility conflicts or other issues arise that require modifications to the structure. For example, this pay item may be used when an existing underground utility is encountered that necessitates a design adjustment that requires modification to the structure.

QUESTION: 2) Will Inspector General Fees be deducted from Pay Applications on this project?

RESPONSE: 2) Inspector General fees will not be deducted from pay applications for this project, as such fees are not applicable due to the project's funding source.

E-mail from Ms. Lory Roy, Acosta Tractors, Inc.; dated Tuesday, April 21, 2026, 10:26 A.M. (attached)

QUESTION: 1) Bid Item 110-3-03 and 110-3-1 both refer to Pipe Removal and Inlet or MH Removal. There is a good amount of existing drainage structures and pipe that are to be removed and replaced. The Quantity for the two Bid items referenced do not reflect the quantity to remove for replacement.

RESPONSE: 1) Pay Items 110-3-03 and 110-3-1 apply only when the contractor is required to remove pipe, inlets, or manholes without replacement. All pipe, inlet, or manhole removals associated with replacement, the contractor shall include the cost of removal in the corresponding proposed bid pay item for the new installation.

Example: If the plans indicate removal of existing pipe and installation of 100 L.F. of 36" French drain, the cost of removal shall be included in the unit price for the pay item indicated for 36" French drain.

QUESTION: 2) Am I to assume that the removal is part of the new inlets/manholes bid items that replace them?

RESPONSE: 2) Yes. Removal shall be included in the unit price of the pay item for the corresponding inlet or manhole when the replacement is required.

QUESTION: 3) As well as the new pipe that replaces them?

RESPONSE: 3) Yes. When pipe is replaced, the contractor shall include the cost of removal in the unit price of the pay item for the corresponding proposed pipe.

QUESTION: 4) Is some of the pipe to be replaced also exfiltration?

RESPONSE: 4) Yes. The plans include removal and replacement of exfiltration pipe, solid pipe, inlet structures, and manholes. The cost of removal for all such items shall be included in the respective unit price of the each pay item.

QUESTION: 5) There is one structure that is called out for removal with NO replacement on 7th Street but there is no corresponding pipe shown on the plan that is called out to be removed and not replaced. Please advise if this is identified in the plans and where.

RESPONSE: 5) Yes, there is one structure to be removed without replacement, along with an existing pipe extending East of the structure, as indicated in the plans. The length of this pipe is unknown and therefore not shown. Both, the structure and associated pipe are to be removed and are not to be replaced.



END OF REQUEST FOR INFORMATION No. 2

Sincerely,

Elva R. Reyes
Engineer 2
Department of Transportation and Public Works (DTPW)

c:
Tiondra Wright, DTPW
Katherine Fernandez, DTPW
Fernando Ramos, DTPW
Eric Perez, SPD
Clerk of the Board
Project File

From: Lori Roy <lroy@acostatractors.com>
Sent: Monday, April 20, 2026 4:56 PM
To: Reyes, Elva (DTPW)
Cc: Clerk of the Board (COC)
Subject: Project 20260067: Midway Pump Station Telemetry System Improvements & Drainage Improvements Multiple Sites

REQUEST FOR INFORMATION:

1. Re: Bid Item 425-82 MODIFY STRUCTURE – Cut to enlarge opening as needed in order to accommodate pipe due to utility conflict(s) brick and mortar as needed.
 - Is there a specific location(s) where this bid item applies? If not, please provide additional information with an example of how this bid item would be used.
2. Will Inspector General Fees be deducted from Pay Applications on this project?



Lori S. Roy
Project Manager/Estimator

Acosta Tractors, Inc.
*11986 NW 97th Avenue
Hialeah Gardens, FL 33018
Cell: 786-269-6503
Phone: 305-556-0473
Fax: 305-556-8268
lroy@acostatractors.com*

AFFIRMATIVE ACTION NOTICE: Vendors and Subcontractors are notified that they may be subject to the provisions of 29CFR Part 470, 41CFR Section 60-1.4(a), (b) & (c), 41CFR Section 60-250.4 and Section 60-741.5 with respect to affirmative action program and plan requirements. The content of this e-mail is the confidential property of Acosta Tractors, Inc. and should not be copied, modified, retransmitted or used for any purpose except with Acosta's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

From: Lori Roy <lroy@acostatractors.com>
Sent: Tuesday, April 21, 2026 10:26 AM
To: Reyes, Elva (DTPW)
Cc: Clerk of the Board (COC)
Subject: Project 20260067: Midway Pump Station Telemetry System Improvements & Drainage Improvements Multiple Sites

REQUEST FOR INFORMATION:

Bid Item 110-3-03 and 110-3-1 both refer to Pipe Removal and Inlet or MH Removal. There is a good amount of existing drainage structures and pipe that are to be removed and replaced. The Quantity for the two Bid items referenced do not reflect the quantity to remove for replacement.

- Am I to assume that the removal is part of the new inlets/manholes bid items that replace them?
- As well as the new pipe that replaces them?
- Is some of the pipe to be replaced also exfiltration?
- There is one structure that is called out for removal with NO replacement on 7th Street but there is no corresponding pipe shown on the plan that is called out to be removed and not replaced. Please advise if this is identified in the plans and where.

Regards,



Lori S. Roy
Project Manager/Estimator

Acosta Tractors, Inc.
*11986 NW 97th Avenue
Hialeah Gardens, FL 33018
Cell: 786-269-6503
Phone: 305-556-0473
Fax: 305-556-8268
lroy@acostatractors.com*

AFFIRMATIVE ACTION NOTICE: Vendors and Subcontractors are notified that they may be subject to the provisions of 29CFR Part 470, 41CFR Section 60-1.4(a), (b) & (c), 41CFR Section 60-250.4 and Section 60-741.5 with respect to affirmative action program and plan requirements. The content of this e-mail is the confidential property of Acosta Tractors, Inc. and should not be copied, modified, retransmitted or used for any purpose except with Acosta's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.