



May 1, 2026

RESPONSE LETTER NO. 3 TO REQUEST FOR INFORMATION

Project Title: Midway Pump Station Telemetry Improvements & Drainage Improvements Multiple Sites

Project No.: 20260067

E-mail from Ms. Lory Roy, Acosta Tractors, Inc.; dated Thursday, April 30, 2026, 12:16 P.M. (attached)

QUESTION: 1) What exactly is proposed to be milled and resurfaced?

RESPONSE: 1) Milling and resurfacing under Pay Item 327-70-01 applies to the portions of the travel lane that are not excavated for the proposed exfiltration trench. Additionally, milling and resurfacing will be performed at intersections, as needed, in accordance with the applicable Public Works Manual requirements

QUESTION: 2) What exactly is the 570 tons for? The bid items for Milling of 1" would only cover a small portion of the 570 tons that is designated in 334-2-13-1. The plans do not show any parameters. Please provide more information

RESPONSE: 2) The 570 tons associated with Pay Item 334-2-13-1 (Hot Mix Asphalt, Traffic C, SP-9.5) represent the estimated quantity required for the asphalt overlay of the entire lane where the exfiltration trench is proposed. The quantity also accounts for additional asphalt required at intersections, as needed, in accordance with Public Works Manual standard details

END OF REQUEST FOR INFORMATION No. 3



Sincerely,

A handwritten signature in black ink that reads "Elva Reyes".

Elva R. Reyes
Engineer 2
Department of Transportation and Public Works (DTPW)

C:

Tiondra Wright, DTPW
Katherine Fernandez, DTPW
Fernando Ramos, DTPW
Eric Perez, SPD
Clerk of the Board
Project File

From: Lori Roy <lroy@acostatractors.com>
Sent: Thursday, April 30, 2026 12:16 PM
To: Reyes, Elva (DTPW)
Cc: Clerk of the Board (COC)
Subject: Project 20260067: Midway Pump Station Telemetry System Improvements & Drainage Improvements Multiple Sites

REQUEST FOR INFORMATION:

- What exactly is proposed to be milled and resurfaced?
- What exactly is the 570 tons for? The bid items for Milling of 1” would only cover a small portion of the 570 tons that is designated in 334-2-13-1. The plans do not show any parameters. Please provide more information.



Lori S. Roy
Project Manager/Estimator

Acosta Tractors, Inc.
11986 NW 97th Avenue
Hialeah Gardens, FL 33018
Cell: 786-269-6503
Phone: 305-556-0473
Fax: 305-556-8268
lroy@acostatractors.com

AFFIRMATIVE ACTION NOTICE: Vendors and Subcontractors are notified that they may be subject to the provisions of 29CFR Part 470, 41CFR Section 60-1.4(a), (b) & (c), 41CFR Section 60-250.4 and Section 60-741.5 with respect to affirmative action program and plan requirements. The content of this e-mail is the confidential property of Acosta Tractors, Inc. and should not be copied, modified, retransmitted or used for any purpose except with Acosta's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.