



September 18, 2026

RESPONSE LETTER NO. 2 TO REQUEST FOR INFORMATION

Project Title: **Streetlight Maintenance - South Central Zone**
Project No.: **20260136 (MCC 7360 Plan)**

E-mail from Mr. Johanna Rogers, MasTec Energy Solutions, Inc.; dated September 10, 2026, 11:42 A.M. (attached)

RESPONSE: 1) Is Item # 715-99-13 Lighting Conductors (Wire Theft) supposed to be in LF and not SY?

RESPONSE: 1) The unit of measure for line item 715-99-13 Lighting Conductors (Wire Theft) is Linear Feet (LF). Please see Addendum 2.

RESPONSE: 2) For Item # 715-99-03A Installation of Missing Light Poles (Contractor Furnishes all Materials, Foundation Existing) – Will this item include decorative poles, luminaires, and arms?

RESPONSE: 2) No.

RESPONSE: 3) In the event HPS Copper heads are not available, can they be replaced with LED fixtures on a per need basis?

RESPONSE: 3) For County Roads, if HPS fixtures are not available then an approved LED equivalent fixture may be used. On FDOT Roads, the contractor is to coordinate with the Engineer for approval prior to the placement of an LED fixture.

RESPONSE: 4) Does Item # 715-500-1 Pole Cable Distribution System [(Conventional)(Installation only - Miami-Dade will supply kit)] – Includes conventional and MG Square, or just conventional?

RESPONSE: 4) The Pole Cable Distribution System line item is for a full MG Square assembly that needs to be fully replaced at any given location with the Engineers approval.

E-mail from Mr. Osmany Oramas, AUM Construction, Inc.; dated September 15, 2026, 2:40 P.M. (attached)



RESPONSE: 1) The Bid Form for subject contract shows Pay Item 715-99-01 Roadway Lighting Relocation – Complete, EA. However, on page 715ME-9, Section 2.a the Pay item 715-99-01 is referred to as Removal and Relocation of Light Poles. In addition, on page 715ME-14, Section 3, the table identifies Pay item 715-99-01 as Removal and Relocation of Light Poles. Please clarify the discrepancy in the Bid Form?

RESPONSE: 1) Please see Addendum No. 2.

E-mail from Mr. Osmany Oramas, AUM Construction, Inc.; dated September 16, 2026, 11:44 A.M. (attached)

RESPONSE: 1) On page 2 of the Invitation to Bid (attached) for subject contract identifies that Davis-Bacon wage rates do not apply for this bid. However, under the Supplementary Conditions, section 1.02, Applicable Wage Rates, A.2., identifies Davis Bacon wage rates for this bid as shown on Appendix A. Please clarify?

RESPONSE: 1) Please see Addendum No. 2.

E-mail from Mr. Osmany Oramas, AUM Construction, Inc.; dated September 17, 2026, 9:21:12 A.M. (attached)

RESPONSE: 1) The Bid Form for previous County Bids for streetlight maintenance contracts included a column for the total number of periods (Example attached), that represented the total length of the contract. If the total number of periods is not included, the total bid contract amount will not represent the estimated value of the contract as advertised.?

RESPONSE: 1) Please see Addendum No. 2.

E-mail from Mr. Henry Echemendia, Horsepower Electric, Inc.; dated September 17, 2026, 10:35 A.M. (attached)

RESPONSE: 1) The Pay Item 715-500-1 under this contract's bid form, indicates that Miami Dade County will supply Conventional Pole Cable Distribution Kit. However, on page 715ME-13 under the Basis of Payment (J.1) for this pay item indicates that the contractor will include all the parts for the DOT Plug FDOT APL 715-001-000 (MG2). Please clarify this discrepancy?

RESPONSE: 1) Please see Addendum No. 2.



Department of Transportation and Public Work
111 NW 1st •Street Suite 141
Miami, Florida 33128-197
T 305-375-2930 F 305-375-293

miamidade.gov

END OF REQUEST FOR INFORMATION No. 2

Sincerely,

A handwritten signature in blue ink, appearing to read "TKW", written over the word "Sincerely,".

Tiondra Wright
Chief, Capital Improvement Division.
Department of Transportation and Public Works (DTPW)

TW:jbp

c: Jean Bernard Philippeaux, DTPW
Daniel Castilla, DTPW
Pedro P. Nuñez, P.E., DTPW
Caesar Suarez, SPD
Clerk of the Board
Project File

From: [Johanna Rogers](#)
To: [Philippeaux, Jean Bernard \(DTPW\)](#)
Cc: [Clerk of the Board \(COC\); MUS Bidding](#)
Subject: RFI for RPQ No 20260136 | Contract No MCC7360 Plan | Streetlight Maintenance - South Central Zone
Date: Thursday, September 10, 2026 11:42:12 AM

You don't often get email from johanna.rogers@mastec.com. [Learn why this is important](#)

Good morning,

Please see the questions below regarding the above-mentioned RPQ.

- Is Item # 715-99-13 Lighting Conductors (Wire Theft) supposed to be in LF and not SY?
- For Item # 715-99-03A Installation of Missing Light Poles (Contractor Furnishes all Materials, Foundation Existing) – Will this item include decorative poles, luminaires, and arms?
- In the event HPS Copper heads are not available, can they be replaced with LED fixtures on a per need basis?
- Does Item # 715-500-1 Pole Cable Distribution System [(Conventional)(Installation only - Miami-Dade will supply kit)] – Includes conventional and MG Square, or just conventional?

Thank you kindly,



Johanna Rogers
Proposal Coordinator
MasTec Energy Solutions
m: 305.965.4816
Johanna.Rogers@mastec.com • mastec.com

From: [Osmany Oramas](#)
To: [Philippeaux, Jean Bernard \(DTPW\)](#)
Cc: [Clerk of the Board \(COC\); Richard Mendez PE](#)
Subject: RFI - 20260136 Streetlight Maintenance South Central Zone
Date: Tuesday, September 15, 2026 2:40:30 PM

Good Afternoon Jean Bernard,

The Bid Form for subject contract shows Pay Item 715-99-01 Roadway Lighting Relocation – Complete, EA. However, on page 715ME-9, Section 2.a the Pay item 715-99-01 is referred to as Removal and Relocation of Light Poles. In addition, on page 715ME-14, Section 3, the table identifies Pay item 715-99-01 as Removal and Relocation of Light Poles. Please clarify the discrepancy in the Bid Form.

Thank you,

Osmany Oramas, EI

Electrical Engineer/Project Estimator

osmany@auminc.us

AUM Construction, Inc

8900 NW 119 St Hialeah Gardens, FL 33018

Office: 305-456-4848

Mobile: 786-484-5512

www.aumconstructioninc.com

From: [Osmany Oramas](#)
To: [Philippeaux, Jean Bernard \(DTPW\)](#)
Cc: [Clerk of the Board \(COC\); Richard Mendez PE](#)
Subject: RFI - 20260136 Streetlight Maintenance South Central Zone
Date: Wednesday, September 16, 2026 11:44:31 AM
Attachments: [ITB 20260136.pdf](#)

Good Morning Jean Bernard,

On page 2 of the Invitation to Bid (attached) for subject contract identifies that Davis-Bacon wage rates do not apply for this bid. However, under the Supplementary Conditions, section 1.02, Applicable Wage Rates, A.2. , identifies Davis Bacon wage rates for this bid as shown on Appendix A. Please clarify.

Thank you,

Osmany Oramas, EI

Electrical Engineer/Project Estimator

osmany@auminc.us

AUM Construction, Inc

8900 NW 119 St Hialeah Gardens, FL 33018

Office: 305-456-4848

Mobile: 786-484-5512

www.aumconstructioninc.com

From: [Osmany Oramas](#)
To: [Philippeaux, Jean Bernard \(DTPW\)](#)
Cc: [Clerk of the Board \(COC\); Richard Mendez PE](#)
Subject: RFI - 20260136 Streetlight Maintenance South Central Zone
Date: Thursday, September 17, 2026 9:21:12 AM
Attachments: [Bid Form Example.pdf](#)

Good Morning Jean Bernard,

The Bid Form for previous County Bids for streetlight maintenance contracts included a column for the total number of periods (Example attached), that represented the total length of the contract. If the total number of periods is not included, the total bid contract amount will not represent the estimated value of the contract as advertised.

Thank you,

Osmany Oramas, EI

Electrical Engineer/Project Estimator

osmany@auminc.us

AUM Construction, Inc

8900 NW 119 St Hialeah Gardens, FL 33018

Office: 305-456-4848

Mobile: 786-484-5512

www.aumconstructioninc.com

From: [Henry Echemendia](#)
To: [Philippeaux, Jean Bernard \(DTPW\); Clerk of the Board \(COC\)](#)
Cc: [Mike Martinez](#); [Roldan Rodriguez](#)
Subject: RFI 20260136 Streetlight Maintenance - South Central Zone
Date: Thursday, September 17, 2026 10:35:03 AM
Attachments: [image.png](#)
[image.png](#)

You don't often get email from henry@horsepowerelectric.com. [Learn why this is important](#)

Good morning,

The Pay Item 715-500-1 under this contract's bid form, indicates that Miami Dade County will supply Conventional Pole Cable Distribution Kit. However, on page 715ME-13 under the Basis of Payment (J.1) for this pay item indicates that the contractor will include all the parts for the DOT Plug FDOT APL 715-001-000 (MG2). Please clarify this discrepancy.

Thank you,

Henry Echemendia
Horsepower Electric, Inc
8105 West 20th Avenue, Hialeah, Florida 33014
P: 305.819.4060 | F: 305.819.4222 | C: 786.478.6169
E-mail: henry@horsepowerelectric.com

 Like us on Facebook!

HORSEPOWER  **ELECTRIC, INC.**