



January 21, 2026

## RESPONSE LETTER NO. 3 TO REQUEST FOR INFORMATION

Project Title: **Metrorail Refurbishment Project Vizcaya and Coconut Grove Stations**  
Project No.: **CIP134-DTPW24-CT**

**Email from Mr. Jorge Garcia, from Co GECKOGROUPINC; on January 19, 2026, at 1:19 PM (Email Attached).**

**QUESTION No. 1:** What is the night shift working hours and the days they are allowed?

**ANSWER No. 1:** Night shift working hours may occur on any day between 1:00 a.m. and 4:00 a.m. Please note that on weekends (Friday through Sunday nights), the area may operate under single-track conditions, which may allow work to be performed during daytime hours. However, all scheduled work must be requested and approved at the Track Allocation Meeting prior to commencement.

**QUESTION No. 2:** The proposed expansion joint by Sika "Jeene Wabo FW" is no longer available. An alternate 2 Hour system by Sika is EMShield DFR2, please verify if this is an acceptable alternate?

**ANSWER No. 2:** It is an acceptable equivalent.

**QUESTION No. 3:** Can equipment such as a Scissor Lift, be brought into the Concourse Area (First Floor) for repairs?

**ANSWER No. 3:** Yes.

**QUESTION No. 4:** Can the equipment remain in the Concourse Area (First Floor) until the work is completed?

**ANSWER No. 4:** Yes.

**QUESTION No. 5:** Have the plans been processed? Can permits be pulled? Is there a process Number?

**ANSWER No. 5:** Dry run has been completed.

**QUESTION No. 6:** Is a special Inspector required? if so, is the contractor responsible for the cost?

**ANSWER No. 6:** Special Inspector will be provided by DTPW.

**END OF REQUEST FOR INFORMATION NO. 3**

Sincerely,



Tiondra Wright  
Chief, Capital Improvement Division.  
Department of Transportation and Public Works (DTPW)

TW:jbp

cc:

Jean Bernard Philippeaux, DTPW	Katherine Fernandez, DTPW
Eric Perez, SPD	Isabel Padron, DTPW
Laurie Johnson, SPD	Bassam Moubayed, DTPW
Clerk of the Board	Olguita H. Sabagh, DTPW

## **Philippeaux, Jean Bernard (DTPW)**

---

**From:** Jorge Garcia <jorge@geckogroup.us>  
**Sent:** Monday, January 19, 2026 1:19 PM  
**To:** Philippeaux, Jean Bernard (DTPW)  
**Cc:** Clerk of the Board (COC); philippeaux;jeanbernard@miamnidade.gov; Rodriguez, Bryan (DTPW); Jim Zade  
**Subject:** Reference to: CIP134-DTPW24-CT (MCC 7360) Vizcaya & Coconut Grove Station.

Jean,

Please clarify the following:

1. What is the night shift working hours and the days they are allowed?
2. The proposed expansion joint by Sika "Jeene Wabo FW" is no longer available. An alternate 2 Hour system by Sika is EMShield DFR2, please verify if this is an acceptable alternate.
3. Can equipment such as a Scissor Lift, be brought into the Concourse Area (First Floor) for repairs?
4. Can the equipment remain in the Concourse Area (First Floor)until the work is completed?
5. Have the plans been processed ? Can permits be pulled? Is there a process Number?
6. Is a special inspector required? if so, is the contractor responsible for the cost?

Thank you

**Jorge Garcia**

**GECKOGROUPINC**  
120 Madeira Avenue  
Coral Gables, Florida 33134  
305.443.8482 office  
305.778.8124 cell