



June 26, 2025

RESPONSE LETTER NO. 2 TO REQUEST FOR INFORMATION

Project Title: **Diesel Exhaust Fuel (DEF) System Installation**
Project No.: **ID-0000000785**

Emails from Mr. Saide Rangel, from SCR Mechanical; on June 26, 2025, at 9:01 & 9:10 AM (emails attached).

QUESTION No.1: Please provide permit set of drawings to estimate the permit fees from the Miami-Dade Co. Building Department.

ANSWER No.1: The County has included all available drawings for the project. Refer to response to RFI Addendum 1, **ANSWER No.1 in page 2 of 3:** The County does not have detail plans, please refer to attached construction permit drawing dated September 2000 under addendum No. 1.

QUESTION No.2: Reference is made to RFI No. 1 and Addendum NO. 1 issue on 6.13.2025:

Add to RFI 3: Please provide technical data for the double wall tank 750 gals capacity. Are they stainless steel or fiberglass?

ANSWER No.2: Refer to RFI Addendum 1, **ANSWER No.3 in page 1 of 3:** There should be 4 double wall tanks with 750 gallons capacity each. Refer to Article 2.02 of the Technical Specification, issued under Addendum No.1.

END OF REQUEST FOR INFORMATION No. 2

Sincerely,

Frances Perez-Texidor, Program Management Specialist
Fleet Management Division, Internal Services Department (ISD)

cc:

Alfredo E. Munoz, P.E. ISD	Caesar Suarez, SBD
Scott Stephens, PIOD	Pete Moolah, PIOD
Laurie Johnson, ISD	Yliana Serra, PIOD
Project File	Clerk of the Board

Perez Texidor, Frances (PIOD)

From: saide@scrmechanical.com
Sent: Thursday, June 26, 2025 9:01 AM
To: Perez Texidor, Frances (PIOD); info@scrmechanical.com
Cc: Clerk of the Board (COC); Muñoz, Alfredo (PIOD)
Subject: RE: RFI and Addendum No. 1 - Diesel Exhaust Fuel (DEF) System Installation - ID-0000000785

EMAIL RECEIVED FROM EXTERNAL SOURCE

Good Morning.

Please provide permit set of drawings to estimate the permit fees from the Miami-Dade Co. Building Department.

Thanks,

Saide Rangel



E: saide@scrmechanical.com
1600 Ponce De Leon Blvd, Ste 1016
Coral Gables, Florida 33134
Phone: (786) 369-0465

Mobile: (954) 214-3759

Perez Texidor, Frances (PIOD)

From: saide@scrmechanical.com
Sent: Thursday, June 26, 2025 9:10 AM
To: Perez Texidor, Frances (PIOD); info@scrmechanical.com
Cc: Clerk of the Board (COC); Muñoz, Alfredo (PIOD)
Subject: RE: RFI and Addendum No. 1 - Diesel Exhaust Fuel (DEF) System Installation - ID-0000000785

EMAIL RECEIVED FROM EXTERNAL SOURCE

Reference is made to RFI No. 1 and Addendum NO. 1 issue on 6.13.2025:

Add to RFI 3: Please provide technical data for the double wall tank 750 gals capacity. Are they stainless steel or fiberglass?

Saide Rangel



E: saide@scrmechanical.com
1600 Ponce De Leon Blvd, Ste 1016
Coral Gables, Florida 33134
Phone: (786) 369-0465

Mobile: (954) 214-3759
