



ADDENDUM NO. 2

TO: All Prospective Bidders

BID NO.: FB-00123

TITLE: Chillers, Auxiliary Equipment, Water Treatment – Full Service Contract

BID OPENING DATE: Friday, October 3, 2014 at 6:00 p.m.

Please note the following change(s):

1. Section 3.6.4.B (Tube Brush Cleaning) has been changed to read as follows:

Includes tube inspection and the internal brushing of the water side of the heat exchanger tubes (cooler and condenser). Included are tubes that have factory installed brushes. Cooler shall be brushed on an as needed basis as determined by the user departments and the successful bidder(s). Successful bidder(s) shall be responsible to maintain brush system to OEM standards; including replacing damaged brushes, or replacing all brushes in accordance with manufacturer's recommended life expectancy.

All terms, covenants and conditions of the subject solicitation and any addenda issued thereto shall apply, except to the extent herein amended.

Miami-Dade County


Yuly Chauz-Ramirez
Procurement Contracting Officer

cc: Clerk of the Board