




MEMO

TO: All Building Officials in Miami-Dade County

FROM: Michael L. Goolsby, Director 
Board and Code Administration Division

DATE: June 4, 2014

SUBJECT: Notice of NOA Removals

13-0408.02 Eastern Metal Supply, Inc.
13-0514.01 All Miami Hurricane Corp.
13-0514.02 AC Shutters and Awning, Inc.
13-0514.03 J.C. Impact Shutters & Glass, Inc.

This is to inform you of the removal of the referenced NOAs as of May 30, 2014. The removals were due to an error in the accordion shutter pin screw dimension being specified shorter than actually tested.

These accordion shutters bear the *ASSA – Bertha HV-3* trade name in the industry. They have also achieved 2010 FBC Florida Product Approval under FL1850-R8, where it indicates they can be used in the HVHZ, but still show the shorter than tested pins. The State of Florida product approvals which indicate the shorter pin screws are not acceptable in the HVHZ.

If you have any questions or need additional information, please contact Jaime Gascon, P.E., Product Control Section Supervisor at 786-315-2590.

Thank you for your attention on this matter.