



## **MEMO**

**TO: All Building Officials in Miami-Dade County**

**FROM: Jaime Gascon, Assistant Director**   
**Board and Code Administration Division**

**DATE: June 22, 2020**

**SUBJECT: Notice of NOA Removals**

**17-0615.03 Eco Window Systems, LLC**

**18-0129.14 Eco Window Systems, LLC**

---

This is to inform you of the removal of the referenced NOAs as of May 29, 2020 and June 12, 2020, respectfully. The removals were due to an error in the material specification of the hinges and connecting angle components of the Series 850 Glass & Aluminum Sectional Garage doors being specified different than was tested.

If you have any questions or need additional information, please contact Helmy A. Makar, P.E., Product Control Section Supervisor at 786-315-2590.

Thank you for your attention on this matter.