




MIAMI-DADE COUNTY, FLORIDA  
HERBERT S. SAFFIR PERMITTING AND INSPECTION CENTER

Department of Regulatory and Economic Resources  
Board and Code Administration Division

11805 SW 26<sup>th</sup> Street (Coral Way) • Room 230  
MIAMI, FLORIDA 33175-2474  
(786) 315-2509 FAX (786) 315-2560


[www.miamidade.gov/building](http://www.miamidade.gov/building)

**ADVISORY MEMO**

**TO: ALL BUILDING OFFICIALS IN MIAMI-DADE COUNTY**  
**FROM: Jaime D. Gascon, P.E.**   
**Board and Code Administration Division**  
**DATE: May 11, 2023**  
**SUBJECT: Non-Approved Anchors**

It has come to our attention that Manny's General Fasteners Corp. is making unauthorized commercial use of Stanley Black & Decker, Inc.'s concrete and masonry screw anchors manufactured and sold under the DeWalt Ultracon and Ultracon+ brand covered under NOA 21-0113.01.

Stanley Black & Decker has issued Manny's General Fasteners Corp. a cease-and-desist letter demanding them to stop the use of DeWalt and Ultracon trademarks on all packaging and literature, and to stop using the deceptive markings shown in exhibit D on the head of masonry anchors that are not easily distinguishable from the genuine DeWalt Ultracon masonry screw anchor.



Manny's General Fastener Packaging Box.



Non-conforming, non-approved head markings with square or diamond.

Page 2.  
May 11, 2023

Although Manny's General Fasteners Corp. has cooperated by discontinuing the sale of these screw anchors, there may still be some of these out there being installed.

The packaging and product markings for DeWalt's approved anchors can be found in NOA 21-0113.01 under the Labeling Requirements section and in the approved drawings, respectively. [https://www.miamidade.gov/building/pc-search\\_app.asp](https://www.miamidade.gov/building/pc-search_app.asp)

If you have any questions, please contact Americo Segura, Quality Assurance Supervisor at (786) 315-2594 (Office) or via e-mail at [Americo.Segura@miamidade.gov](mailto:Americo.Segura@miamidade.gov) or Dexter Bleasdel, Senior Code Officer - Building at (786) 315-2556 (Office), or via e-mail at [Dexter@miamidade.gov](mailto:Dexter@miamidade.gov).