



MEMO

TO: All Building Officials in Miami-Dade County
FROM: Michael L. Goolsby, Division Director *MLG*
Board and Code Administration Division
DATE: March 15, 2016 (Revised March 31, 2016)
SUBJECT: ElectroGalvanized Roofing Fastener Listing Removals
Rev. 3/31/16

- | | |
|-------------------------------------|-------------------------------------|
| 11-1019.02 & 11-1019.03 | Bluelinx Corporation |
| 12-0423.06 | Continental Materials, Inc. |
| 15-112304 | PrimeSource Building Products, Inc. |
| 13-0530.01 | Specialty Fastening System |
| 12-0423.03 & 12-0423.04 | Summit Conglomerate, LLC |
| 12-1205.11, 12-1205.13 & 13-0514.05 | Weatherpro, LLC |

This is to inform you that effective April 1, 2016 the referenced Miami Dade County electrogalvanized fastener listings are suspended. The suspension is due to the results of research conducted by the University of Florida, where randomly selected electrogalvanized roofing nails from different distributors including some approved by Miami Dade County were tested for corrosion per TAS 114 Appendix E. The results of the tests showed that none of the tested electrogalvanized nails sampled from current supplies in the market passed the test.

An action plan to reinstate the listings is underway, which requires independent selection of the test samples and testing to prove compliance with TAS114 Appendix E. Upon confirmation, the listing will be reinstated.

If you have any questions or need additional information, please contact Americo Segura, M.S., Quality Assurance Unit Supervisor at 786-315-2594.

Thank you for your attention on this matter.