



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
 BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
 PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
 Miami, Florida 33175-2474
 T (786)315-2590 F (786) 315-2599

www.miamidade.gov/economy

GAF
1 Campus Drive
Parsippany, NJ 07054

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF EverGuard® TPO Single Ply Roofing Systems over Wood Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 15-0729.18 and consists of pages 1 through 38.
 The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 20-0518.02
 Expiration Date: 09/22/25
 Approval Date: 08/20/20
 Page 1 of 38

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Single Ply Roofing
Material:	TPO
Deck Type:	Wood
Maximum Design Pressure:	-120 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

Product	Dimensions	Test Specification	Product Description
EverGuard® TPO	Various	ASTM D6878 TAS 131	Thermoplastic olefin reinforced single-ply membrane.
EverGuard Extreme® TPO	Various	ASTM D6878 TAS 131	Thermoplastic olefin reinforced single-ply membrane designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Fleece-back Membrane	Various	ASTM D 6878 TAS 131	Thermoplastic olefin reinforced, fleece back single-ply membrane
EverGuard® TPO FB Ultra	Various	ASTM D 6878 TAS 131	Thermoplastic olefin reinforced, fleece back single-ply membrane
EverGuard Extreme® TPO Fleece-back Membrane	various	ASTM D6878 TAS 131	Thermoplastic olefin reinforced fleece back single-ply membrane designed for advanced protection against heat aging and UV degradation.
EverGuard Extreme® TPO FB Ultra	various	ASTM D6878 TAS 131	Thermoplastic olefin reinforced fleece back single-ply membrane designed for advanced protection against heat aging and UV degradation.
GAFGLAS® #75 Base Sheet	39.37" (1 meter) wide	ASTM D4601	Smooth asphaltic base or base/ply sheet reinforced with fiberglass mat.
Tri-Ply® #75 Base Sheet	39.37" (1 meter) wide	ASTM D4601	Smooth asphaltic base or base/ply sheet reinforced with fiberglass mat.
GAFGLAS® #80 Ultima™ Base Sheet	39.37" (1 meter) wide	ASTM D4601	Smooth asphaltic base or base/ply sheet reinforced with fiberglass mat.
Ruberoid® 20 Smooth	39.37" (1 meter) wide	ASTM D6163	SBS polymer-modified asphalt base or ply sheet reinforced with a fiberglass mat.
GAFGLAS® Stratavent® Nailable Venting Base Sheet	39.37" (1 meter) wide	ASTM D4897	Smooth surfaced asphaltic nailable venting base sheet reinforced with fiberglass mat. Bottom side surfaced with granules.



Product	Dimensions	Test Specification	Product Description
LRF Adhesive M	1:1 applicator	Proprietary	Two-part VOC free polyurethane foam adhesive.
LRF Adhesive O	1:1 applicator	Proprietary	Two-part VOC free polyurethane foam adhesive.
EverGuard® #1121 Bonding Adhesive	5 gallons	Proprietary	Solvent based adhesive for fully adhered TPO systems and membrane flashing.
EverGuard® WB 181 Bonding Adhesive	5 gallons	Proprietary	Water-based bonding adhesive for use with smooth TPO, fleece backed TPO and fleece backed PVC membranes.
EverGuard® Low VOC TPO Bonding Adhesive	5 gallons	Proprietary	Low VOC adhesive for TPO fully adhered systems and flashings.
VersaShield® Fire-Resistant Roof Deck Protection	12" x 100' rolls	ASTM D226	Non-asphaltic fiberglass reinforced underlayment and /or fire barrier.
VersaShield® Solo™ Fire-Resistant Slip Sheet	42" roll wide, 100 ft.	ASTM D146, D828, D4869, D6757	Non-asphaltic, fire resistant fiberglass underlayment.
EverGuard® TPO Coated Metal	4' x 10' sheets	Proprietary	24 gauge steel with a 25 mil thick GAF TPO for edge detailing.
EverGuard Extreme® TPO Coated Metal	4' x 10' sheets	Proprietary	24 gauge steel with a 25 mil thick GAF TPO for edge detailing and designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Cover Tape	6" x 100' 10" x 100'	Proprietary	GAF TPO laminated to white butyl tape primarily used for edge metal details.
EverGuard® TPO Cover Tape Heat-Weld	6" x 100'	Proprietary	Flashing strip manufactured from unreinforced GAF TPO laminated to a six inch wide strip, half the strip with a self-adhered side and half the strip with a heat-weldable edge; used for edge metal details.
EverGuard Extreme® TPO Cover Tape Heat-Weld	6" x 100'	Proprietary	Flashing strip manufactured from unreinforced GAF TPO designed for advanced protection against heat aging and UV degradation. Laminated to a six inch wide strip, half the strip with a self-adhered side and half the strip with a heat-weldable edge; used for edge metal details.
EverGuard® TPO Detailing Membrane	24" x 50'	Proprietary	Unreinforced flashing material manufactured from GAF TPO.



Product	Dimensions	Test Specification	Product Description
EverGuard Extreme® TPO Detailing Membrane	24" x 50'	Proprietary	Unreinforced flashing material manufactured from GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Flashing Strip	Various	Proprietary	Reinforced flashing membrane manufactured from GAF TPO.
EverGuard Extreme® TPO Flashing Strip	Various	Proprietary	Reinforced flashing membrane manufactured from GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Pourable Sealer Pocket	9" x 6" x 4" oval with 3" base flange	Proprietary	Pourable sealer pocket is molded with GAF TPO compound to a nominal 70 mil thickness designed for waterproofing irregular shaped roof penetrations.
EverGuard Extreme® TPO Pourable Sealer Pocket	9" x 6" x 4" oval with 3" base flange	Proprietary	Pourable sealer pocket is molded from GAF TPO designed for advanced protection against heat aging and UV degradation compounded to a nominal 70 mil thickness designed for waterproofing irregular shaped roof penetrations.
EverGuard® TPO RTA Strip™	6" x 100' roll	Proprietary	Reinforced GAF TPO membrane with pressure sensitive adhesive primarily used to secure membrane transitions from the field to vertical surfaces.
EverGuard® TPO RTA (Roof Transition Anchor) Strip™	6" x 100' roll	Proprietary	Reinforced GAF TPO membrane with pressure sensitive adhesive primarily used to secure membrane transitions from the field to vertical surfaces.
EverGuard Extreme® TPO RTA Strip™	6" x 100' roll	Proprietary	Reinforced GAF TPO membrane with pressure sensitive adhesive primarily used to secure membrane transitions from the field to vertical surfaces.
EverGuard Extreme® TPO RTA (Roof Transition Anchor) Strip™	6" x 100' roll	Proprietary	Reinforced GAF TPO membrane with pressure sensitive adhesive primarily used to secure membrane transitions from the field to vertical surfaces.
EverGuard® TPO Split Pipe Boot	1" - 2" 3" - 5" 6" - 8"	Proprietary	Reinforced GAF TPO membrane split to accommodate most common pipes and conduits.



Product	Dimensions	Test Specification	Product Description
EverGuard Extreme® TPO Split Pipe Boot	1" - 2" 3" - 5" 6" - 8"	Proprietary	Reinforced GAF TPO designed for advanced protection against heat aging and UV degradation split to accommodate most common pipes and conduits.
EverGuard® TPO Square Tube Wrap	4" x 4" 4" x 6" 6" x 6"	Proprietary	Reinforced GAF TPO with split design overlap to be wrapped around square or rectangular tubing.
EverGuard Extreme® TPO Square Tube Wrap	4" x 4" 4" x 6" 6" x 6"	Proprietary	Reinforced GAF TPO designed for advanced protection against heat aging and UV degradation with split design overlap to be wrapped around square or rectangular tubing.
EverGuard® TPO Corner Curb Wrap	Various	Proprietary	Corners fabricated from reinforced GAF TPO.
EverGuard Extreme® TPO Corner Curb Wrap	Various	Proprietary	Corners fabricated from reinforced GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Scupper	4" x 6" x 12" 8" x 10" x 12"	Proprietary	Scupper manufactured from coated metal and unreinforced GAF TPO.
EverGuard® TPO T-Joint Cover Patch	100 patches per box	Proprietary	T-Joint patch manufactured from unreinforced GAF TPO.
EverGuard Extreme® TPO T-Joint Cover Patch	100 patches per box	Proprietary	T- Joint patch manufactured from unreinforced GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Vent	2 vents per carton	Proprietary	Vent manufactured from reinforced GAF TPO membrane and galvanized steel.
EverGuard® TPO T-Top Vent	4" or 6"	Proprietary	Vent manufactured from reinforced GAF TPO membrane and galvanized steel.
EverGuard® TPO Walkway Rolls	Rolls 1/8" x 30" x 50'	Proprietary	Standard duty TPO walkway rolls.
EverGuard® TPO Inside Corner	6" x 6" x 5/4"	Proprietary	Inside corner manufactured from unreinforced GAF TPO.
EverGuard Extreme® TPO Inside Corner	6" x 6" x 5/4"	Proprietary	Inside corner manufactured from unreinforced GAF TPO designed for advanced protection against heat aging and UV degradation.



Product	Dimensions	Test Specification	Product Description
EverGuard® TPO Universal Corners	various	Proprietary	Universal corners manufactured from GAF TPO that are heat seamable and designed to accommodate both inside and outside corners of base and curb flashings manufactured from GAF TPO.
EverGuard Extreme® TPO Universal Corners	various	Proprietary	Universal corners manufactured from GAF TPO designed for advanced protection against heat aging and UV degradation are heat seamable and designed to accommodate both inside and outside corners of base and curb flashings.
EverGuard® TPO Vent Boot	1" - 6" o.d. 6 pcs. crtn.	Proprietary	Vent pipe boot molded from GAF TPO and supplied with stainless steel clamping rings.
EverGuard Extreme® TPO Vent Boot	1" - 6" o.d. 6 pcs. crtn.	Proprietary	Vent pipe boot molded from GAF TPO designed for advanced protection against heat aging and UV degradation and supplied with stainless steel clamping rings.
EverGuard® TPO Expansion Joint Cover	various	Proprietary	Low profile joint cover manufactured from reinforced GAF TPO.
EverGuard® Extreme TPO Expansion Joint Cover	various	Proprietary	Low profile joint cover manufactured from reinforced GAF TPO.
EverGuard® Extreme Expansion Joint Cover	various	Proprietary	Low profile joint cover manufactured from reinforced GAF TPO.
EverGuard® TPO Cut Edge Sealant	1 quart squeeze tube	Proprietary	Clear solvent based sealant for TPO cut edges.
EverGuard® Low VOC Cut Edge Sealant	1 quart squeeze tube	Proprietary	Low VOC clear solvent based sealant for TPO cut edges.
EverGuard® TPO Drain	various	Proprietary	Spun aluminum drain pre-flashed with unreinforced GAF TPO.
EverGuard® TPO Seam Cleaner	1 gallon	Proprietary	Solvent based seam cleaner.
EverGuard® TPO Primer	1 gallon	Proprietary	Solvent-based VOC compliant TPO primer
EverGuard® Low VOC TPO Primer	1 gallon	Proprietary	Low VOC TPO primer
EverGuard® TPO Low VOC Primer	1 gallon	Proprietary	Low VOC TPO primer



Product	Dimensions	Test Specification	Product Description
EverGuard® TPO Standing Seam Tape	6"	Proprietary	White butyl cover tape.
EverGuard® TPO Batten Seam Profile	10' length 1 ½" base 1 ¼" vertical rib	Proprietary	Accessory applied over GAF TPO roofing systems to simulate a standing seam metal roof.
EverGuard® TPO Standing Seam Profile	10' length 1 ½" base 1 ¼" vertical rib	Proprietary	Accessory applied over GAF TPO roofing systems to simulate a standing seam metal roof.
EverGuard® TPO Fluted Corner	8" diameter nominal .05" non-reinforced	Proprietary	Flashing for outside corners of base and curb flashing manufactured from non-reinforced GAF TPO.
EverGuard Extreme® TPO Fluted Corner	8" diameter nominal .05" non-reinforced	Proprietary	Flashing for outside corners of base and curb flashing manufactured from non-reinforced GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® CleanWeld™ Conditioner	1 gallon	Proprietary	Low VOC cleaner for TPO
EverGuard® Low VOC TPO Bonding Adhesive	5 gallons	Proprietary	Low VOC adhesive for TPO fully adhered systems and flashings.
TOPCOAT® Membrane	1, 5 or 55 gallons	ASTM D6083	Water-based elastomeric coating
TOPCOAT® TPO Red Primer	1 gallon	Proprietary	Solvent-based primer for TPO membranes
TPO Red Primer	1 gallon	Proprietary	Solvent-based primer for TPO membranes
TOPCOAT® FireOut™ Fire Barrier Coating	5 or 55 gallons	Proprietary	Low VOC, water-based fire barrier coating.
TOPCOAT® FlexSeal™	1 or 5 gallons or 1 qt. tube	TAS 139	Solvent-based elastomeric sealant.
EverGuard® 3 Square Low VOC TPO Bonding Adhesive	5 Gallons	Proprietary	Low VOC TPO bonding adhesive that provides 3 square coverage per pail.
EverGuard® TPO Quick Spray Adhesive	40.15 lbs	Proprietary	Sprayable solvent based adhesive for fully adhered TPO systems and membrane flashing.
EverGuard® TPO Quick Spray Adhesive LV50	36.3 lbs	Proprietary	Sprayable Low VOC solvent based adhesive for fully adhered TPO systems and membrane flashing.



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
EnergyGuard™ Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ HD Polyiso Insulation	High density polyisocyanurate foam insulation	GAF
EnergyGuard™ HD Plus Polyiso Insulation	High density polyisocyanurate foam insulation	GAF
EnergyGuard™ Ultra Polyiso Insulation	Glass-faced polyisocyanurate foam insulation.	GAF
EnergyGuard™ RA Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RH Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RH HD Polyiso Insulation	High density polyisocyanurate foam insulation	GAF
EnergyGuard™ RN Polyiso Insulation	Polyisocyanurate foam insulation	GAF
DensDeck® Roof Board	Gypsum board	Georgia Pacific Gypsum LLC
SECUROCK® Gypsum-Fiber Roof Board	Gypsum board	United States Gypsum Corporation
SECUROCK® Glass-Mat Roof Board	Glass faced gypsum board	United States Gypsum Corporation
Structodek® High Density Fiberboard Roof Insulation	High-density fiberboard	Blue Ridge FiberBoard, Inc.

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Drill-Tec™ #12 Fastener	Phillips head, modified buttress thread, pinch point, carbon steel fastener for use in steel or wood decks. With CR-10 coating. Available with a pinch point or drill point.	#12 x 8" max. length, #3 Phillips head	GAF
2.	Drill-Tec™ #14 Fastener	Truss head, self-drilling, pinch point, high thread fastener for use in steel, wood or concrete decks.	#14 x 16" max. Length, #3 Phillips head.	GAF



APPROVED FASTENERS:

Fastener Number	Product Name	TABLE 3 Product Description	Dimensions	Manufacturer (With Current NOA)
3.	Drill-Tec™ AccuTrac® Recessed Plate	Galvalume® steel plate with recess for use with Drill-Tec™ fasteners.	3" square; .017" thick.	GAF
4.	Drill-Tec™ AccuTrac® Flat Plate	A2-SS aluminized steel plate for use with Drill-Tec™ fasteners.	3" square; .017" thick	GAF
5.	Drill-Tec™ 2-3/8 in. Barbed XHD Plate	Round galvanized steel stress plates for use with Drill-Tec™ fasteners.	2-3/8" round	GAF
6.	Drill-Tec™ 2 in. Double Barbed XHD Plate	Round galvanized steel stress plates for use with Drill-Tec™ fasteners.	2" round	GAF
7.	Drill-Tec™ Eyehook AccuSeam Plate	Round Galvalume® steel plate for use with Drill-Tec™ fasteners.	2-3/8" round	GAF
8.	Drill-Tec™ 3" Steel Plate	Round Galvalume® steel stress plate with reinforcing ribs and recessed for use with Drill-Tec™ fasteners.	3" round	GAF
9.	Drill-Tec™ 3" Standard Steel Plate	Galvalume® coated steel stress plate for use with approved Drill-Tec™ fasteners.	3" round	GAF
10.	Drill-Tec™ 3 in. Ribbed Galvalume Plate (Flat)	Round Galvalume® plated steel stress plate with reinforcing ribs for use with Drill-Tec™ fasteners.	3" round	GAF
11.	Drill-Tec™ ASAP 3S	Drill-Tec™ #12 Fastener with Drill-Tec™ 3" Standard Steel Plate.	See Components	GAF
12.	Drill-Tec™ RhinoBond® TPO XHD Plate	Gold primer coated plate for use with TPO membranes.	3" Round	GAF
13.	Drill-Tec™ RhinoBond® TPO XHD TreadSafe Plate	Round, coated Galvalume® plate (Gold primer coating) used for TPO membranes.	3" Round	GAF



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>	
UL LLC	03CA38009	UL 790	01/21/04	
	08CA37926	UL 790	09/23/09	
	08CA49140	UL 790	09/23/09	
	R1306	UL 790	05/22/13	
	R10689	UL 790	03/11/19	
	R19254	ASTM D226	09/13/01	
	Factory Mutual Research Corp.	3B9Q1.AM	FM 4470	01/08/98
3020588		FM 4470	03/24/04	
3023458		FM 4470	07/18/06	
3026964		FM 4470	07/25/07	
3029832		FM 4470	05/11/07	
3033135		FM 4470	11/24/08	
3035658		FM 4470	09/16/09	
3038278		FM 4470	11/18/11	
3038318		FM 4470	12/10/10	
3036980		FM 4470	08/14/09	
3040377 LTR		FM 4470	09/21/16	
3040738		FM 4470	11/16/10	
3041769		FM 4470	05/26/11	
3042905		FM 4470	01/10/12	
3045166		FM 4470	07/24/12	
3045363		FM 4470	10/12/12	
3047636		FM 4470	08/08/13	
3053501		FM 4470	01/14/16	
PR449764		FM 4470	07/25/18	
RR210305		FM 4470	06/18/17	
RR221253		FM 4470	02/07/20	
IRT-ARCON		02-005	TAS 114	01/24/02
		02-008	TAS 114	01/24/02
Atlantic & Caribbean Roof Consulting, LLC	08-022-R1	TAS 114	01/15/15	
	11-056-R2	TAS 114	01/26/15	
Exterior Research & Design, L.L.C.	01509.03.04-2	TAS 114-J	03/16/04	
Trinity-ERD	G31360.03.10	ASTM D6164	03/31/10	
	G34140.04.11-2-R1	ASTM D6163	04/25/11	
	G34140.04.11-4-R2	ASTM D4601	06/04/15	
	G34140.04.11-5-R3	ASTM D4897	06/04/15	
NEMO etc.	4q-GAF-19-SSMBB-02.A	ASTM D6163	04/08/19	
PRI Construction Materials Technologies, LLC	GAF-122-02-01	TAS 139	05/07/06	
	GAF-270-02-02	ASTM D226 / D146	08/03/10	
	GAF-276-02-01REV	ASTM D6083	01/04/11	
	GAF-306-02-01	ASTM E96	08/23/11	
	GAF-349-02-01	TAS 110	07/03/12	
	GAF-369-02-01	ASTM C1289	10/23/12	



EVIDENCE SUBMITTED: (CONTINUED)

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
PRI Construction Materials Technologies, LLC	GAF-411-02-01	ASTM C1289	05/02/13
	GAF-412-02-01	ASTM C1289	05/02/13
	GAF-417-02-01	ASTM C1289	05/28/13
	GAF-421-02-01	ASTM D6878/TAS 131	10/23/13
	GAF-422-02-01	ASTM D6878/TAS 131	10/29/13
	GAF-424-02-01	ASTM D6878/TAS 131	11/11/13
	GAF-425-02-01	ASTM D6878/TAS 131	11/11/13
	GAF-434-02-01	TAS 117	09/16/13
	GAF-435-02-01	TAS 117(B)	01/29/14
	GAF-462-02-01	ASTM D413	11/18/13
	GAF-462-02-02	TAS 117(B)	11/18/13
	GAF-462-02-09	FM 4470	07/01/14
	GAF-462-02-10	FM 4470	07/01/14
	GAF-462-02-11	FM 4470	07/01/14
	GAF-464-02-01	ASTM C1289	02/06/14
	GAF-499-02-01	ASTM D6083	03/12/14
	GAF-508-02-01	Various	03/12/14
	GAF-515-02-01	FM 4470	05/13/14
	GAF-516-02-01	FM 4470	05/13/14
	GAF-516-02-02	FM 4470	06/06/14
	GAF-516-02-03	FM 4470	05/13/14
	GAF-559-02-01	TAS 117	10/16/14
	GAF-559-02-04	ASTM D1876	03/04/15
	GAF-559-02-11	TAS 114	10/16/14
	GAF-559-02-12	TAS 114	10/16/14
	GAF-559-02-13	TAS 114	10/16/14
	GAF-559-02-16	TAS 114	10/16/14
	GAF-559-02-18	TAS 114	10/16/14
	GAF-567-02-01	ASTM D1876	01/23/15
	GAF-580-02-01	ASTM C1289	07/23/15
	GAF-581-02-01	ASTM C1289	07/23/15
	GAF-602-02-01	ASTM C1289	09/25/15
	GAF-746-02-05	TAS 114	12/14/16
	GAF-746-02-06	TAS 114	12/14/16
	GAF-836-02-01	TAS 114	03/02/18
	GAF-836-02-02	TAS 114	03/02/18
	GAF-836-02-03	TAS 114	03/02/18
	GAF-836-02-04	TAS 114	03/02/18
	PRI 376T0017	TAS 114	08/09/19
	PRI 376T0025	TAS 114	09/06/19
	PRI 376T0026	TAS 114	09/06/19
PRI 376T0027	TAS 114	09/19/19	

APPROVED ASSEMBLIES:

- Membrane Type:** Single Ply, TPO
- Deck Type 1I:** Wood, Insulated
- Deck Description:** Min. 15/32” thick plywood attached to structural wood supports spaced maximum 24” o.c. using 8d ring shank nails spaced 6” o.c. at panel edge and intermediate supports.
- System Type B(1):** Base layer(s) of insulation mechanically attached to roof deck. Top layer of insulation is adhered. Membrane is subsequently fully adhered to top layer of insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

- Fire Barrier: (Optional)** VersaShield® Fire-Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer’s installation instructions.

One or more layers of any of the following.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ Ultra Polyiso Insulation Minimum 2” thick	2, 3, 4, 8, 9, 10	1:2 ft²

Note: Base layer(s) shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
SECUROCK® Gypsum-Fiber Roof Board Minimum 0.25” thick	N/A	N/A

Note: Apply top layer of insulation with OlyBond 500 applied in 0.75 – 1.0” wide ribbons spaced 12” o.c. or with LRF Adhesive M applied in 1” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layer(s) with a layer of approved top layer insulation installed as the final membrane substrate.

- Membrane:** EverGuard® TPO, EverGuard Extreme® TPO, EverGuard® TPO FB Ultra, EverGuard Extreme® TPO FB Ultra is adhered to the substrate as follows. Broom or roll the top surface of the membrane per manufacturer’s installation instructions after adhering the membrane to the substrate to ensure complete bonding. Membrane side laps are minimum 3.0 in. wide and sealed with minimum 1.5 in. wide heat welds for automatic machine welding or with minimum 2.0 in. wide heat welds for hand welding.



**Membrane:
(Continued)**

EverGuard® TPO or EverGuard Extreme® TPO adhered with EverGuard® TPO #1121 Bonding Adhesive applied per manufacturer's installation instructions at a total rate of 1.67 gal./sq. One half of the adhesive is applied to the substrate and the other half is applied to the back of the roof cover and sealed with minimum 1.5 in. wide heat welds for automatic machine welding or with minimum 2.0 in. wide heat welds for hand welding..

OR

EverGuard® TPO or EverGuard Extreme® TPO adhered with EverGuard® Low VOC TPO Bonding Adhesive applied per manufacturer's installation instructions at a total rate of 0.91 gal./sq. One half of the adhesive is applied to the substrate and the other half is applied to the back of the roof cover and sealed with minimum 1.5 in. wide heat welds for automatic machine welding or with minimum 2.0 in. wide heat welds for hand welding.

OR

EverGuard® TPO or EverGuard Extreme® TPO adhered with EverGuard® WB 181 Bonding Adhesive applied per manufacturer's installation instructions at a total rate of 0.83 gal./sq. Three quarters of the adhesive is applied to the substrate and one quarter of the adhesive is applied to the back of the roof cover and sealed with minimum 1.5 in. wide heat welds for automatic machine welding or with minimum 2.0 in. wide heat welds for hand welding.

OR

EverGuard® TPO FB Ultra or EverGuard Extreme® TPO FB Ultra adhered with OlyBond 500 applied in a spatter pattern at 0.318 gal./sq. and sealed with minimum 1.5 in. wide heat welds for automatic machine welding or with minimum 2.0 in. wide heat welds for hand welding

OR

EverGuard® TPO FB Ultra or EverGuard Extreme® TPO FB Ultra adhered with LRF Adhesive M applied in 0.75 – 1.0 in. wide ribbons spaced 4 in. o.c. for full coverage and sealed with minimum 1.5 in. wide heat welds for automatic machine welding or with minimum 2.0 in. wide heat welds for hand welding.

OR

One ply of EverGuard® TPO or EverGuard Extreme® TPO fully adhered to the insulation with EverGuard® TPO Quick Spray Adhesive applied at a total rate of 0.705 lbs./sq. Apply half to the insulation and half to the underside of the membrane, roll with a weighted roller. Apply a minimum of 1½" wide heat weld in the side lap of the sheets.

OR

EverGuard® TPO or EverGuard Extreme® TPO adhered with EverGuard® TPO Quick Spray Adhesive LV50 applied per manufacturer's installation instructions at a total rate of 0.837 lbs./sq. One half of the adhesive is applied to the substrate and the other half is applied to the back of the roof cover and sealed with minimum 1.5 in. wide heat welds for automatic machine welding or with minimum 2.0 in. wide heat welds for hand welding.

OR

EverGuard® TPO or EverGuard Extreme® TPO adhered with EverGuard® TPO 3 Square Low VOC Bonding Adhesive applied per manufacturer's installation instructions at a total rate of 1.67 gal./sq. One half of the adhesive is applied to the substrate and the other half is applied to the back of the roof cover and sealed with minimum 1.5 in. wide heat welds for automatic machine welding or with minimum 2.0 in. wide heat welds for hand welding..

**Surfacing:
(Optional)**

Chosen components must be applied in accordance with manufacturer's application instructions. Any coating listed below used as a surfacing must be listed within a current NOA.

1. TOPCOAT® Membrane applied at 1 to 1.5 gal./sq.
2. TOPCOAT® TPO Red Primer applied at 0.5 gal./sq. prior to applying TOPCOAT® Membrane.

**Maximum Design
Pressure:**

-52.5 psf. (See General Limitation #7)



Membrane Type: Single Ply, TPO
Deck Type 1I: Wood, Insulated
Deck Description: ¹⁹/₃₂" Plywood APA Span-Rated nailed 3"o.c. at the field of the sheet with #8 ring shank nails and 3"o.c. at the perimeter of the sheet with #8 ring shank nails. Plywood installed over wood trusses spaced 24"o.c.
System Type B(2): Base layer of insulation mechanically attached to roof deck. Top layer of insulation is adhered. Membrane is subsequently fully adhered to top layer of insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board, minimum ¼" thick (see insulation note below for preliminary attachment details).
 OR
 VersaShield® Fire-Resistant Roof Deck Protection VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 3.0" thick	1 or 2 & 8	1:1 ft. ²

Base Insulation Note: All Insulation layers shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.

Top Insulation Layer	Cover Board Fasteners (Table 3)	Fastener Density/ft ²
SECUROCK® Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Top Insulation Note: The top insulation layer is adhered to the base insulation layer with OlyBond 500 with 1 in. wide ribbons spaced 4 in. o.c. See Roofing Application Standard RAS 117 for fastening details.

Membrane: EverGuard® TPO FB Ultra or EverGuard Extreme® TPO FB Ultra is adhered to the cover board via Olybond 500 applied in spatter pattern at a rate of 0.325 gal/100ft² with a 3" side lap and sealed with a 1-1/2" wide heat weld.

Maximum Design Pressure: -120 psf. (See General Limitation #7)



Membrane Type: Single Ply, TPO
Deck Type II: Wood, Insulated
Deck Description: 19/32" CDX Plywood nailed 6"o.c. at the field of the sheet with #8 ring shank nails and 6"o.c. at the perimeter of the sheet with #8 ring shank nails. Plywood installed over wood rafters spaced 24"o.c.
System Type C(1): All layers of insulation are mechanically attached to roof deck. Membrane is subsequently fully adhered to insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: VersaShield® Fire-Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.
(Optional)

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
SECUROCK® Gypsum-Fiber Roof Board Minimum 1/4" thick	1 & 4	1:1.33 ft. ²

Insulation Note: All Insulation layers shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.

Membrane: EverGuard® TPO FB Ultra or EverGuard Extreme® TPO FB Ultra is adhered to the SECUROCK® Gypsum-Fiber Roof Board in an approved asphalt applied within the EVT range and at a rate of 20-25 lbs./sq. with a 3" side lap and sealed with a 2" wide heat weld. Broom top surface of membrane to ensure complete bonding.

Surfacing: Chosen components must be applied in accordance with manufacturer's application instructions. Any coating listed below used as a surfacing must be listed within a current NOA.
(Optional)

1. TOPCOAT® Membrane applied at 1 to 1.5 gal./sq.
2. TOPCOAT® TPO Red Primer applied at 0.5 gal./sq. prior to applying TOPCOAT® Membrane.

Maximum Design Pressure: -82.5 psf. (See General Limitation #7)



- Membrane Type:** Single Ply, TPO
- Deck Type 1I:** Wood, Insulated
- Deck Description:** Min. 15/32" thick plywood attached to structural wood supports spaced maximum 24" o.c. using 8d ring shank nails spaced 6" o.c. at panel edge and intermediate supports.
- System Type C(2):** All layers of insulation are mechanically attached to roof deck. Membrane is subsequently adhered to stress plates used to fasten insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

- Fire Barrier:** DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board, minimum ¼" thick (see insulation note below for preliminary attachment details).
OR
VersaShield® Fire-Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

One or more layers of any of the following.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation, EnergyGuard™ Ultra Polyiso Insulation, Structodek® High Density Fiberboard Roof Insulation, EnergyGuard™ HD Polyiso Insulation, EnergyGuard™ HD Plus Polyiso Insulation, EnergyGuard™ RH HD Polyiso Insulation Minimum 0.5" thick	2 and 12 or 13	1:2.67 ft²
DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board Minimum 0.25" thick	2 and 12 or 13	1:2.67 ft²

Insulation Note: Insulation shall have preliminary attachment. Preliminarily attach insulation through the top layer and underlying layer(s), when present, with the RhinoBond® membrane stress plates applied as specified in the membrane section of this roofing system. See Roofing Application Standard RAS 117 for fastening details.



Membrane:

EverGuard® TPO, EverGuard Extreme® TPO mechanically fastened using Drill-Tec™ #14 Fasteners and Drill-Tec™ RhinoBond® TPO XHD Plates or Drill-Tec™ RhinoBond® TPO XHD Tread Safe Plates applied at a rate of 12 fasteners per 48 x 96 in. board (2.67 ft² per fastener).

The membrane is bonded to stress plates using the RhinoBond® Portable Bonding Tool per manufacturer’s installation instructions. Weighted cooling magnets are placed over the bonded membrane/plates for a minimum of 45 seconds. Side laps are minimum 3” wide and sealed with a minimum 1.5” wide heat weld for automatic machine welding or a minimum 2” wide heat weld for hand welding.

*Drill-Tec™ RhinoBond® TPO XHD Tread Safe Plates shall only be used with a minimum insulation thickness of 2” and require a 5/8” diameter pilot hole when used with gypsum or wood fiber top layer insulation.

**Surfacing:
(Optional)**

Chosen components must be applied in accordance with manufacturer's application instructions. Any coating listed below used as a surfacing must be listed within a current NOA.

1. TOPCOAT® Membrane applied at 1 to 1.5 gal./sq.
2. TOPCOAT® TPO Red Primer applied at 0.5 gal./sq. prior to applying TOPCOAT® Membrane.

**Maximum Design
Pressure:**

-52.5 psf. (See General Limitation #7)



- Membrane Type:** Single Ply, TPO
- Deck Type 1I:** Wood, Insulated
- Deck Description:** Min. 15/32" thick plywood attached to structural wood supports spaced maximum 24" o.c. using 8d ring shank nails spaced 6" o.c. at panel edge supports and 12" o.c. at panel intermediate supports.
- System Type C(3):** All layers of insulation are mechanically attached to roof deck supports. Membrane is subsequently adhered to stress plates used to fasten insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

- Fire Barrier:** DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board, minimum ¼" thick (see insulation note below for preliminary attachment details).
OR
VersaShield® Fire-Resistant Roof Deck Protection VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

One or more layers of any of the following.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation, EnergyGuard™ Ultra Polyiso Insulation, Structodek® High Density Fiberboard Roof Insulation, EnergyGuard™ HD Polyiso Insulation, EnergyGuard™ HD Plus Polyiso Insulation, EnergyGuard™ RH HD Polyiso Insulation Minimum 0.5" thick	2 and 12 or 13	See Below
DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board Minimum 0.25" thick	2 and 12 or 13	See Below

Insulation Note: All insulation shall have preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft. and four fasteners for any insulation board having no dimension greater than 8 ft. Please refer to Roofing Application Standard RAS 117 for insulation attachment requirements.



Membrane: EverGuard® TPO, EverGuard Extreme® TPO mechanically fastened using Drill-Tec™ #14 Fasteners and Drill-Tec™ RhinoBond® TPO XHD Plates or Drill-Tec™ RhinoBond® TPO XHD Tread Safe Plates. Fasteners are driven through the plywood roof deck and into the structural wood supports as described in the fastening details below.

The membrane is bonded to stress plates using the RhinoBond® Portable Bonding Tool per manufacturer's installation instructions. Weighted cooling magnets are placed over the bonded membrane/plates for a minimum of 45 seconds. Side laps are minimum 3" wide and sealed with a minimum 1.5" wide heat weld for automatic machine welding or a minimum 2" wide heat weld for hand welding.

*Drill-Tec™ RhinoBond® TPO XHD Tread Safe Plates shall only be used with a minimum insulation thickness of 2" and require a 5/8" diameter pilot hole when used with gypsum or wood fiber top layer insulation.

Fastening #1: Fasteners are driven through the wood deck and into the structural wood supports in a maximum 24 x 36 in. grid.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Fastening #2: Fasteners are driven through the wood deck and into the structural wood supports in a maximum 24 x 24 in. grid.
Maximum Design Pressure: -75 psf. (See General Limitation #7)

Fastening #3: Fasteners are driven through the wood deck and into the structural wood supports in a maximum 18 x 24 in. grid.
Maximum Design Pressure: -82.5 psf. (See General Limitation #7)

**Surfacing:
(Optional)** **Chosen components must be applied in accordance with manufacturer's application instructions. Any coating listed below used as a surfacing must be listed within a current NOA.**

1. TOPCOAT® Membrane applied at 1 to 1.5 gal./sq.
2. TOPCOAT® TPO Red Primer applied at 0.5 gal./sq. prior to applying TOPCOAT® Membrane.

Maximum Design Pressure: See fastening options above.

Membrane Type: Single Ply, TPO
Deck Type 1I: Wood, Insulated
Deck Description: ¹⁵/₃₂" Plywood APA Span-Rated nailed 6"o.c. at the field of the sheet with #8 ring shank nails and 6"o.c. at the perimeter of the sheet with #8 ring shank nails. Plywood installed over wood trusses spaced 24"o.c.
System Type C(4): All layers of insulation are mechanically attached to roof deck. Membrane is subsequently fully adhered to insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board, minimum ¼" thick (see insulation note below for preliminary attachment details).
 OR
 VersaShield® Fire-Resistant Roof Deck Protection VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick	1, 2 & 8	1:1.78 ft. ²

Insulation Note: All Insulation layers shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.

Membrane: EverGuard® or EverGuard Extreme® TPO is fully adhered to the insulation layer via EverGuard® #1121 Bonding Adhesive at a rate of 1.67gal/100ft² with a 3" side lap and sealed with a 1-1/2" wide heat weld.
 OR
 EverGuard® or EverGuard Extreme® TPO is fully adhered to the insulation layer via EverGuard® TPO 3 Square Low VOC Adhesive at a rate of 1.67gal/100ft² with a 3" side lap and sealed with a 1-1/2" wide heat weld.
 OR
 EverGuard® or EverGuard Extreme® TPO is fully adhered to the insulation layer via EverGuard® Quick Spray Adhesive at a rate of 0.705 lbs/100ft² with a 3" side lap and sealed with a 1-1/2" wide heat weld.
 OR
 EverGuard® or EverGuard Extreme® TPO is fully adhered to the insulation layer via EverGuard® TPO Quick Spray Adhesive LV50 at a rate of 0.837 lbs/100ft² with a 3" side lap and sealed with a 1-1/2" wide heat weld.

Maximum Design Pressure: -52.5 psf. (See General Limitation #7)



- Membrane Type:** Single Ply, TPO
- Deck Type 1I:** Wood, Insulated
- Deck Description:** ¹⁵/₃₂" Plywood APA Span-Rated nailed 6"o.c. at the field of the sheet with #8 ring shank nails and 6"o.c. at the perimeter of the sheet with #8 ring shank nails. Plywood installed over wood trusses spaced 24"o.c.
- System Type C(5):** All layers of insulation are mechanically attached to roof deck. Membrane is subsequently fully adhered to insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

- Fire Barrier:** DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board, minimum ¼" thick (see insulation note below for preliminary attachment details).
OR
VersaShield® Fire-Resistant Roof Deck Protection VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick	1, 2 & 8	1:1.6 ft. ²

Insulation Note: All Insulation layers shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.

- Membrane:** EverGuard® or EverGuard Extreme® TPO is fully adhered to the insulation layer via GAF EverGuard® #1121 Bonding Adhesive at a rate of 1.67gal/100ft² with a 3" side lap and sealed with a 1-1/2" wide heat weld.
OR
EverGuard® or EverGuard Extreme® TPO is fully adhered to the insulation layer via EverGuard® TPO 3 Square Low VOC Adhesive at a rate of 1.67gal/100ft² with a 3" side lap and sealed with a 1-1/2" wide heat weld.
OR
EverGuard® or EverGuard Extreme® TPO is fully adhered to the insulation layer via EverGuard® Quick Spray Adhesive at a rate of 0.705 lbs/100ft² with a 3" side lap and sealed with a 1-1/2" wide heat weld.
OR
EverGuard® or EverGuard Extreme® TPO is fully adhered to the insulation layer via EverGuard® TPO Quick Spray Adhesive LV50 at a rate of 0.837 lbs/100ft² with a 3" side lap and sealed with a 1-1/2" wide heat weld.

- Maximum Design Pressure:** -60 psf. (See General Limitation #7)



Membrane Type: Single Ply, TPO
Deck Type 1I: Wood, Insulated
Deck Description: Min. 19/32" thick plywood attached to structural wood supports spaced maximum 24" o.c. using 8d ring shank nails spaced 3" o.c. at panel edge supports and 3" o.c. at panel intermediate supports.
System Type C(6): All layers of insulation are mechanically attached to roof deck supports. Membrane is subsequently adhered to stress plates used to fasten insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board, minimum 1/4" thick (see insulation note below for preliminary attachment details).
 OR
 VersaShield® Fire-Resistant Roof Deck Protection VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 1" thick	2 and 12 or 13	See Below

Insulation Note: All Insulation layers shall be mechanically attached with fasteners and density described below. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.

Membrane: EverGuard® TPO or EverGuard Extreme® TPO mechanically fastened using Drill-Tec™ #14 Fasteners and Drill-Tec™ RhinoBond® TPO XHD Plates or Drill-Tec™ RhinoBond® TPO XHD TreadSafe Plate are installed at 9 in. o.c. fastener spacing and 24in. o.c. row spacing into joists.
 The membrane is bonded to stress plates using the RhinoBond® Portable Bonding Tool per manufacturer's installation instructions. Weighted cooling magnets are placed over the bonded membrane/plates for a minimum of 45 seconds. Side laps are minimum 3" wide and sealed with a minimum 1.5" wide heat weld for automatic machine welding or a minimum 2" wide heat weld for hand welding.

Maximum Design Pressure: -105 psf. (See General Limitation #7)



Membrane Type: Single Ply, TPO
Deck Type II: Wood, Insulated
Deck Description: 1⁹/₃₂" or greater plywood secured 6 in. o.c. at panel end and intermediate supports to structural lumber joists spaced maximum 24 in. o.c using 8d ring shank nails or wood plank.
System Type D(1): All insulation is loose laid with preliminary attachment to roof deck. Membrane is subsequently mechanically fastened through insulation to the wood deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: VersaShield® Fire-Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer instructions.

One or more layers of any of the following.

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation, EnergyGuard™ Ultra Polyiso Insulation, EnergyGuard™ HD Polyiso Insulation, EnergyGuard™ HD Plus Polyiso Insulation, EnergyGuard™ RH HD Polyiso Insulation Minimum 0.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board Minimum 1/4" thick	N/A	N/A

Insulation Note: Insulation layer(s) above shall have preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft. and four fasteners for any insulation board having no dimension greater than 8 ft. All Insulation panels shall be mechanically fastened along with the roof membrane as specified below. Please refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: EverGuard® TPO, EverGuard Extreme® TPO or EverGuard® TPO FB Ultra is mechanically attached with Drill-Tec™ #14 Fasteners and Drill-Tec™ 2-3/8 in. Barbed XHD Barbed Plates, Drill-Tec™ 2 in. Double Barbed XHD Plates or Drill-Tec™ Eyehook AccuSeam Plates spaced 6" o.c. within fastener rows spaced maximum 114.5" o.c. The minimum 5" wide side laps are sealed with minimum 1³/₄" wide heat welds for automatic machine welding and with minimum 2" wide welds for hand welding.



**Surfacing:
(Optional)**

Chosen components must be applied in accordance with manufacturer's application instructions. Any coating listed below used as a surfacing must be listed within a current NOA.

1. TOPCOAT® Membrane applied at 1 to 1.5 gal./sq.
2. TOPCOAT® TPO Red Primer applied at 0.5 gal./sq. prior to applying TOPCOAT® Membrane.

**Maximum Design
Pressure:**

-45 psf. (See General Limitation #7)



Membrane Type: Single Ply, TPO
Deck Type 1I: Wood, Insulated
Deck Description: 1⁹/₃₂" or greater plywood attached to structural wood supports spaced maximum 24" o.c. using 8d common nails spaced 6" o.c. at all panel edges and intermediary supports.
System Type D(2): All insulation is loose laid with preliminary attachment to wood deck. Membrane is subsequently mechanically fastened through insulation to the wood deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board, minimum 1/4" thick (see insulation note below for preliminary attachment details).
 OR
 VersaShield® Fire-Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

One or more layers of any of the following.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation, EnergyGuard™ Ultra Polyiso Insulation Minimum 1.5" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
Dens Deck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board Minimum 0.25" thick	N/A	N/A
EnergyGuard™ HD Polyiso Insulation, EnergyGuard™ HD Plus Polyiso Insulation EnergyGuard™ RH HD Polyiso Insulation Minimum 0.5" thick	N/A	N/A

Insulation Note: All insulation shall have preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft. and four fasteners for any insulation board having no dimension greater than 8 ft. Please refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: EverGuard® TPO, EverGuard Extreme® TPO or EverGuard® TPO FB Ultra mechanically fastened using Drill-Tec™ #14 Fasteners and Drill-Tec™ 2 in. Double Barbed XHD Plates, Drill-Tec™ 2-3/8 in. Barbed XHD Plates or Drill-Tec™ Eyehook AccuSeam Plates spaced 6" o.c. in rows spaced 55" o.c. The outside 1.75" of the 5" lap is heat welded and the fasteners are centered within the remaining 3.25" lap area.



**Surfacing:
(Optional)**

Chosen components must be applied in accordance with manufacturer's application instructions. Any coating listed below used as a surfacing must be listed within a current NOA.

1. TOPCOAT[®] Membrane applied at 1 to 1.5 gal./sq.
2. TOPCOAT[®] TPO Red Primer applied at 0.5 gal./sq. prior to applying TOPCOAT[®] Membrane.

**Maximum Design
Pressure:**

-52.5 psf. (See General Limitation #7)



- Membrane Type:** Single Ply, TPO
- Deck Type 1I:** Wood, Insulated
- Deck Description:** Min. 19/32" thick plywood attached to structural wood supports spaced maximum 24" o.c. using 8d ring shank nails spaced 4" o.c. at panel end and intermediate supports.
- System Type D(3):** All insulation is loose laid with preliminary attachment to roof deck. Membrane is subsequently mechanically fastened through insulation to wood deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

- Fire Barrier:** DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board, minimum ¼" thick (see insulation note below for preliminary attachment details).
OR
VersaShield® Fire-Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

One or more layers of any of the following.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation, EnergyGuard™ Ultra Polyiso Insulation, EnergyGuard™ HD Polyiso Insulation, EnergyGuard™ HD Plus Polyiso Insulation, EnergyGuard™ RH HD Polyiso Insulation Minimum 0.5" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
Dens Deck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board Minimum 0.25" thick	N/A	N/A

Insulation Note: All insulation shall have preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft. and four fasteners for any insulation board having no dimension greater than 8 ft. Please refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

- Membrane:** EverGuard® TPO or EverGuard Extreme® TPO mechanically fastened using Drill-Tec™ #14 Fasteners and Drill-Tec™ 2 in. Double Barbed XHD Plates, Drill-Tec™ 2-3/8 in. Barbed XHD Plates or Drill-Tec™ Eyehook AccuSeam Plates spaced maximum 8" o.c. in fastener rows spaced maximum 55" o.c. The minimum 5" wide side laps are sealed with minimum 1.5" wide heat welds for automatic machine welding or with minimum 2" welds for hand welding.



**Surfacing:
(Optional)**

Chosen components must be applied in accordance with manufacturer's application instructions. Any coating listed below used as a surfacing must be listed within a current NOA.

1. TOPCOAT[®] Membrane applied at 1 to 1.5 gal./sq.
2. TOPCOAT[®] TPO Red Primer applied at 0.5 gal./sq. prior to applying TOPCOAT[®] Membrane.

**Maximum Design
Pressure:**

-45 psf. (See General Limitation #7)



Membrane Type: Single Ply, TPO

Deck Type 1I: Wood, Insulated

Deck Description: ¹⁵/₃₂" Plywood APA Span-Rated nailed 6"o.c. at the field of the sheet with #8 ring shank nails and 6"o.c. at the perimeter of the sheet with #8 ring shank nails. Plywood installed over wood trusses spaced 24"o.c.

System Type D(4): All insulation is loose laid with preliminary attachment to roof deck. Membrane is subsequently mechanically fastened through insulation to the wood deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board, minimum ¼" thick (see insulation note below for preliminary attachment details).
OR
VersaShield® Fire-Resistant Roof Deck Protection VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 1" thick	N/A	N/A

Insulation Note: All insulation shall have preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft. and four fasteners for any insulation board having no dimension greater than 8 ft. Please refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: EverGuard® TPO or EverGuard Extreme® TPO is mechanically attached with Drill-Tec™ #14 Fasteners (1.75 in.) and Drill-Tec™ 2 in. Double Barbed XHD Plates, Drill-Tec™ 2-3/8 in. Barbed XHD Plates or Drill-Tec™ Eyehook AccuSeam Plates. Fasteners are installed at 12 in. o.c. with 48 in. o.c. row spacing. Fasteners are installed into structural supports trusses with min. 1" embedment. The minimum 6" wide side laps are sealed with minimum 1.5" wide heat welds..

Maximum Design Pressure: -52.5 psf. (See General Limitation #7)



Membrane Type: Single Ply, TPO
Deck Type II: Wood, Insulated
Deck Description: ¹⁵/₃₂" Plywood APA Span-Rated nailed 6"o.c. at the field of the sheet with #8 ring shank nails and 6"o.c. at the perimeter of the sheet with #8 ring shank nails. Plywood installed over wood trusses spaced 24"o.c.

System Type D(5): All insulation is loose laid with preliminary attachment to roof deck. Membrane is subsequently mechanically fastened through insulation to the wood deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: DensDeck® Roof Board, SECUROCK® Gypsum-Fiber Roof Board, SECUROCK® Glass-Mat Roof Board, minimum ¼" thick (see insulation note below for preliminary attachment details).
 OR
 VersaShield® Fire-Resistant Roof Deck Protection VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 1" thick	N/A	N/A

Insulation Note: All insulation shall have preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft. and four fasteners for any insulation board having no dimension greater than 8 ft. Please refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: EverGuard® TPO or EverGuard Extreme® TPO is mechanically attached with Drill-Tec™ #14 Fasteners (1.75 in.) and Drill-Tec™ 2-3/4 in. Barbed SXHD Plates. Fasteners are installed at 12 in. o.c. with 48 in. o.c. row spacing. Fasteners are installed into structural supports trusses with min. 1" embedment. The minimum 6" wide side laps are sealed with minimum 1.5" wide heat welds.

Maximum Design Pressure: -67.5 psf. (See General Limitation #7)



Membrane Type: Single Ply, TPO
Deck Type 1: Wood, Non-Insulated
Deck Description: 1⁵/₃₂" or greater plywood or wood plank
System Type E(1): Anchor sheet mechanically attached to roof deck. Membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: (Optional) VersaShield[®] Fire Resistant Roof Deck Protection, VersaShield[®] Solo[™] Fire-Resistant Slip Sheet or TOPCOAT[®] FireOut[™] Fire Barrier Coating applied per manufacturer's installation instructions.

Anchor sheet: GAFGLAS[®] #75 Base Sheet, Tri-Ply[®] #75 Base Sheet, Ruberoid[®] 20 Smooth or GAFGLAS[®] Stratavent[®] Nailable Venting Base Sheet is secured as described below.

Fastening Option #1: Miami-Dade County Approved min. 12 ga. annular ring shank nails and min. 1-5/8 in. diameter tin caps are spaced 8 in. o.c. in the min. 4 in. wide anchor sheet side laps and 8 in. o.c. in the field of the sheet in two staggered rows.
(Maximum Design Pressure –45 psf. See General Limitation #7)

Fastening Option #2: Miami-Dade County Approved min. 12 ga. annular ring shank nails and min. 1-5/8 in. diameter tin caps are spaced 6 in. o.c. in the min 4 in. wide anchor sheet side laps and 6 in. o.c. in the field of the sheet in two staggered rows.
(Maximum Design Pressure –52.5 psf. See General Limitation #7)

Fastening Option #3: Drill-Tec[™] #14 Fasteners and Drill-Tec[™] 3 in. Standard Steel Plates, Drill-Tec[™] AccuTrac[®] Flat Plates or Drill-Tec[™] 3 in. Ribbed Galvalume Plate (Flat) are spaced 16 in. o.c. in the min. 4 in. wide anchor sheet side laps and 16 in. o.c. in the field of the sheet in two staggered rows.
(Maximum Design Pressure –52.5 psf. See General Limitation #7)

Fastening Option #4: Drill-Tec[™] #14 Fasteners and Drill-Tec[™] 3 in. Standard Steel Plates, Drill-Tec[™] AccuTrac[®] Flat Plates or Drill-Tec[™] 3 in. Ribbed Galvalume Plate (Flat) are spaced 12 in. o.c. in the min 4 in. wide anchor sheet side laps and 12 in. o.c. in the field of the sheet in two staggered rows.
(Maximum Design Pressure –60 psf. See General Limitation #7)

Fastening Option #5: Drill-Tec[™] #14 Fasteners and Drill-Tec[™] 3 in. Standard Steel Plates, Drill-Tec[™] AccuTrac[®] Flat Plates or Drill-Tec[™] 3 in. Ribbed Galvalume Plate (Flat) are spaced 8 in. o.c. in the min. 4 in. wide anchor sheet side laps and 8 in. o.c. in the field of the sheet in three staggered rows.
(Maximum Design Pressure –97.5 psf. See General Limitation #7)



Membrane: EverGuard® TPO FB Ultra or EverGuard Extreme® TPO FB Ultra adhered to anchor sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. with a 3” side lap and sealed with a 2” wide heat weld for automatic machine welding or a minimum 2” wide heat weld for hand welding. Broom top surface of membrane to ensure complete bonding.

**Surfacing:
(Optional)** **Chosen components must be applied in accordance with manufacturer's application instructions. Any coating listed below used as a surfacing must be listed within a current NOA.**

1. TOPCOAT® Membrane applied at 1 to 1.5 gal./sq.
2. TOPCOAT® TPO Red Primer applied at 0.5 gal./sq. prior to applying TOPCOAT® Membrane.

**Maximum Design
Pressure:** See fastening options.



- Membrane Type:** Single Ply, TPO
- Deck Type 1:** Wood, Non-Insulated
- Deck Description:** Min. 15/32" thick plywood attached to structural wood supports spaced maximum 24" o.c. using 8d ring shank nails spaced 6" o.c. at panel end supports and 12" o.c. along panel intermediate supports.
- System Type E(2):** Membrane adhered to stress plates which are mechanically attached to structural wood supports.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: VersaShield® Fire-Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer instructions.
(Optional)

Membrane: EverGuard® TPO or EverGuard Extreme® TPO mechanically fastened using Drill-Tec™ #14 Fasteners and Drill-Tec™ RhinoBond® TPO XHD Plates. Fasteners are driven through the plywood roof deck and into the structural wood supports as described in the fastening details below.

The roof cover is bonded to stress plates using the RhinoBond® Portable Bonding Tool per manufacturer's installation instructions. Weighted cooling magnets are placed over the bonded membrane/plates for a minimum of 45 seconds. Side laps are minimum 3" wide and sealed with a minimum 1.5" wide heat weld positioned on the outer edge of the lap.

Fastening #1: Fasteners are driven through the wood deck and into the structural wood supports in a maximum 24 x 36 in. grid.

Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Fastening #2: Fasteners are driven through the wood deck and into the structural wood supports in a maximum 24 x 24 in. grid.

Maximum Design Pressure: -75 psf. (See General Limitation #7)

Fastening #3: Fasteners are driven through the wood deck and into the structural wood supports in a maximum 18 x 24 in. grid.

Maximum Design Pressure: -82.5 psf. (See General Limitation #7)

Surfacing: Chosen components must be applied in accordance with manufacturer's application instructions. Any coating listed below used as a surfacing must be listed within a current NOA.
(Optional)

1. TOPCOAT® Membrane applied at 1 to 1.5 gal./sq.
2. TOPCOAT® TPO Red Primer applied at 0.5 gal./sq. prior to applying TOPCOAT® Membrane.

Maximum Design Pressure: See fastening options above.



Membrane Type: Single Ply, TPO
Deck Type 1I: Wood, Non-insulated.
Deck Description: ¹⁵/₃₂" Plywood APA Span-Rated nailed 6"o.c. at the field of the sheet with #8 ring shank nails and 6"o.c. at the perimeter of the sheet with #8 ring shank nails. Plywood installed over wood trusses spaced 24"o.c.

System Type E(3): Membrane is mechanically fastened to the wood deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: VersaShield® Fire Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.
(Optional)

Membrane: EverGuard® TPO or EverGuard Extreme® TPO is mechanically attached with Drill-Tec™ #14 Fasteners (3 in.) and Drill-Tec™ 2 in. Double Barbed XHD Plates, Drill-Tec™ 2-3/8 in. Barbed XHD Plates or Drill-Tec™ Eyehook AccuSeam Plates as described in the fastening details below.

Fastening #1: Fasteners are installed at 12 in. o.c. with 48 in. o.c. row spacing. Fasteners are installed into structural supports trusses with min. 1" embedment. The minimum 6" wide side laps are sealed with minimum 1.5" wide heat welds.
Maximum Design Pressure: -60 psf. (See General Limitation #7)

Fastening #2: Fasteners are installed at 6 in. o.c. with 48 in. o.c. row spacing. Fasteners are installed into structural supports trusses with min. 1" embedment. The minimum 6" wide side laps are sealed with minimum 1.5" wide heat welds.
Maximum Design Pressure: -67.5 psf. (See General Limitation #7)

Maximum Design Pressure: See fastening options above.



Membrane Type: Single Ply, TPO
Deck Type II: Wood, Non-insulated

Deck Description: 1⁵/₃₂" Plywood APA Span-Rated nailed 6"o.c. at the field of the sheet with #8 ring shank nails and 6"o.c. at the perimeter of the sheet with #8 ring shank nails. Plywood installed over wood trusses spaced 24"o.c.

System Type E(4): Membrane is mechanically fastened to the wood deck.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: (Optional) VersaShield® Fire Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

Membrane: EverGuard® TPO or EverGuard Extreme® TPO is mechanically attached with Drill-Tec™ #14 Fasteners (1.75 in.) and Drill-Tec™ 2-3/4in. Barbed SXHD Plates. Fasteners are installed at 12 in. o.c. with 48 in. o.c. row spacing. Fasteners are installed into structural supports trusses with min. 1" embedment. The minimum 6" wide side laps are sealed with minimum 1.5" wide heat welds..

Maximum Design Pressure: -75 psf. (See General Limitation #7)



Membrane Type: Single Ply, TPO

Deck Type 1I: Wood, Non-insulated

Deck Description: Min. 19/32" thick plywood attached to structural wood supports spaced maximum 24" o.c. using 8d ring shank nails spaced 3" o.c. at panel edge supports and 3" o.c. at panel intermediate supports.

System Type E(5): Membrane is adhered to stress plates.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: (Optional) VersaShield® Fire Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet or TOPCOAT® FireOut™ Fire Barrier Coating applied per manufacturer's installation instructions.

Membrane: EverGuard® TPO or EverGuard Extreme® TPO mechanically fastened using Drill-Tec™ #14 Fasteners and Drill-Tec™ RhinoBond® TPO XHD Plates Fasteners are installed at 9 in. o.c. fastener spacing and 24in. o.c. row spacing into joists.
The membrane is bonded to stress plates using the RhinoBond® Portable Bonding Tool per manufacturer's installation instructions. Weighted cooling magnets are placed over the bonded membrane/plates for a minimum of 45 seconds. Side laps are minimum 3" wide and sealed with a minimum 1.5" wide heat weld for automatic machine welding or a minimum 2" wide heat weld for hand welding.

Maximum Design Pressure: -90 psf. (See General Limitation #7)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf. as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 20-0518.02
Expiration Date: 09/22/25
Approval Date: 08/20/20
Page 38 of 38