



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Simon Roofing and Sheet Metal Corporation
dba SR Products
70 Karago Avenue
Youngstown, OH 44512

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: SR Products Built-Up Roofing Systems Over Steel Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA# 14-0122.09 and consists of pages 1 through 18.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 20-0721.18
Expiration Date: 10/15/25
Approval Date: 09/03/20
Page 1 of 18

ROOFING ASSEMBLY NOTICE OF ACCEPTANCE

Category: Roofing
Sub-Category: BUR
Material: SBS
Deck Type: Steel
Maximum Design Pressure: -127.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
SR SuperiorPly SAM II	39.37" x 61"	ASTM D 1970	Roofing sheet comprised of polyester mat and modified bitumen compound.
SR SuperiorPly SAP II	39.37" x 61"	ASTM D 1970	Roofing sheet comprised of polyester mat and modified bitumen compound.
SuperiorFlex Seal Max	5 gallon pails	ASTM D 3019	A two component modified coal tar epoxy used as a protective roof coating.
SuperiorFlex Seal Plus	5 gallon pails	ASTM D 3019	A thermoplastic rubber coating and mastic designed for waterproofing a variety of structural surfaces.
SR Insulation Adhesive	5 gallon pails	Proprietary	A two-component modified coal tar epoxy designed for adhering a wide range of approved insulation materials to standard roof deck assemblies.
Wite Brite Elastomeric Coating	5 and 55 gallon containers	ASTM D 6083	A water-based elastomeric coating.
Wite Brite Elastomeric Coating – Contrast FR	5 gallon pails	Proprietary	A fire retardant water-based elastomeric coating.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
ACFoam-II	Polyisocyanurate Insulation	Atlas Roofing Corporation
MonoBoard	Rockwool fiber insulation	Roxul
MonoBoard Plus	Rockwool fiber insulation	Roxul



NOA No.: 20-0721.18
Expiration Date: 10/15/25
Approval Date: 09/03/20
Page 2 of 18

APPROVED FASTENERS:**TABLE 3**

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	Trufast #12 DP Fastener	Carbon steel screw with #3 phillips drive, modified truss head for use in steel or wood decks. TruKote epoxy coating.	#12 x 8" max. length	Altenloh, Brinck & Co. U.S., Inc.
2.	Trufast #14 HD Fastener	Carbon steel screw with #3 phillips drive, modified truss head for use in steel, wood or concrete decks. TruKote epoxy coating.	#14 x 12" max. length	Altenloh, Brinck & Co. U.S., Inc.
3.	Trufast 3" Metal Insulation Plate	Galvalume steel stress plate for use with TruFast fasteners.	3" round with reinforcing ribs	Altenloh, Brinck & Co. U.S., Inc.
4.	Trufast 2" Barbed Metal Seam Plate	Galvalume steel stress plate for use with TruFast fasteners.	2" round with reinforcing ribs and barbs.	Altenloh, Brinck & Co. U.S., Inc.
5.	OMG Heavy Duty	Truss head, self-drilling, pinch point, high thread fastener for use in wood, steel, or concrete decks.	#14 x 16" max. length; #3 Phillips head	OMG, Inc.
6.	OMG XHD	Truss head, self-drilling, pinch point, high thread fastener for use in wood or steel decks.	#15 x 16" max. length; #3 Phillips head	OMG, Inc.
7.	#14 Roofgrip	Phillips head, modified buttress thread, drill point, carbon steel fastener for use in steel, wood, or concrete decks. With CR-10 coating	#14 x 24" max. length; #3 Phillips head	OMG, Inc.
8.	3 in. Round Metal Plate	Round galvalume stress plate for use with OMG fasteners.	3" round	OMG, Inc.
9.	OMG 2" Barbed Plate	Round galvalume steel stress plates for use with OMG fasteners.	2" round	OMG, Inc.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Momentum Technologies International	JX12C5A	ASTM D6146	07/25/15
	JX22M4A	Physical Properties	02/17/15
	CX13A4C	ASTMD 6083	03/26/14
Trinity ERD	SC6820.05.14	ASTM D 1970	05/21/14
	S44650.04.13	ASTM D 1970	04/22/13
	S43490.05.13-R2	TAS 114 app. J	05/21/14
Factory Mutual Research Corp.	3048293	FM 4470	08/27/13



APPROVED ASSEMBLIES

Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., type B, Grade 33 steel deck secured to structural steel supports spaced at a maximum of 6 ft. o.c. spans attached with two (2) Traxx/5 screws and 0.75" diameter washers at each corrugation (6" o.c.). Side laps are secured with Traxx/1 screws spaced 13" o.c.
System Type C(1):	All layer of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 2" thick	1 & 3	1:2ft ²

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Ply Sheet: (Optional)	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Cap Sheet:	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Surfacing:	<ol style="list-style-type: none">400 lb./ 100ft² gravel in a flood coat of SuperiorFlex Seal Plus at a rate of 5 gal./100 ft².Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq.Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., with one coat of Wite Brite Elastomeric Coating applied at a rate of 1.5 gal/sq.
Maximum Design Pressure:	-67.5 psf (See General Limitation #7.)



Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., type B, Grade 33 steel deck secured to structural steel supports spaced at a maximum of 6 ft. o.c. spans attached with two (2) Traxx/5 screws and 0.75" diameter washers at each corrugation (6" o.c.). Side laps are secured with Traxx/1 screws spaced 13" o.c.
System Type C(2):	All layer of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 2" thick	1 & 3	1:2ft²

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Ply Sheet: (Optional)	One ply of SR SuperiorPly SAM II or one ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Cap Sheet:	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Surfacing:	<ol style="list-style-type: none"> 1. 400 lb./ 100ft² gravel in a flood coat of SuperiorFlex Seal Plus at a rate of 5 gal./100 ft². 2. Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq. 3. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., with one coat of Wite Brite Elastomeric Coating applied at a rate of 1.5 gal/sq.
Maximum Design Pressure:	-67.5 psf (See General Limitation #7.)



Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., type B, Grade 33 steel deck secured to structural steel supports spaced at a maximum of 6 ft. o.c. spans attached with two (2) Traxx/5 screws and 0.75" diameter washers at each corrugation (6" o.c.). Side laps are secured with Traxx/1 screws spaced 13" o.c.
System Type C(3):	All layer of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 2" thick	1 & 3	1:2ft²

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Ply Sheet: (Optional)	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Cap Sheet:	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Surfacing:	1. Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq.
Maximum Design Pressure:	-52.5 psf (See General Limitation #7.)



NOA No.: 20-0721.18
Expiration Date: 10/15/25
Approval Date: 09/03/20
Page 7 of 18

Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., type B, Grade 33 steel deck secured to structural steel supports spaced at a maximum of 6 ft. o.c. spans attached with two (2) Traxx/5 screws and 0.75" diameter washers at each corrugation (6" o.c.). Side laps are secured with Traxx/1 screws spaced 13" o.c.
System Type C(4):	All layer of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 2" thick	1 & 3	1:2ft²

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Ply Sheet:	One ply of SR SuperiorPly SAM II or one ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Cap Sheet:	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Surfacing:	1. Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq.
Maximum Design Pressure:	-52.5 psf (See General Limitation #7.)



Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., type B, Grade 33 steel deck secured to structural steel supports spaced at a maximum of 6 ft. o.c. spans attached with two (2) Traxx/5 screws and 0.75" diameter washers at each corrugation (6" o.c.). Side laps are secured with Traxx/1 screws spaced 9" o.c.
System Type C(5):	All layer of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 2" thick	1 & 3	1:2ft²

Note: Base insulation layer shall be partially adhered to the steel deck with S.R. Insulation Adhesive applied in 1" wide ribbons at every other top-flange (12" o.c.). Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Ply Sheet: (Optional)	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Cap Sheet:	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Surfacing:	<ol style="list-style-type: none"> 1. 400 lb./ 100ft² gravel in a flood coat of SuperiorFlex Seal Plus at a rate of 5 gal./100 ft². 2. Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq. 3. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., with one coat of Wite Brite Elastomeric Coating applied at a rate of 1.5 gal/sq.
Maximum Design Pressure:	-67.5 psf (See General Limitation #7.)



Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., type B, Grade 33 steel deck secured to structural steel supports spaced at a maximum of 6 ft. o.c. spans attached with two (2) Traxx/5 screws and 0.75" diameter washers at each corrugation (6" o.c.). Side laps are secured with Traxx/1 screws spaced 9" o.c.
System Type C(6):	All layer of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 2" thick	1 & 3	1:2ft²

Note: Base insulation layer shall be partially adhered to the steel deck with S.R. Insulation Adhesive applied in 1" wide ribbons at every other top-flange (12" o.c.). Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Ply Sheet:	One ply of SR SuperiorPly SAM II or one ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Cap Sheet:	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Surfacing:	<ol style="list-style-type: none"> 1. 400 lb./ 100ft² gravel in a flood coat of SuperiorFlex Seal Plus at a rate of 5 gal./100 ft². 2. Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq. 3. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., with one coat of Wite Brite Elastomeric Coating applied at a rate of 1.5 gal/sq.
Maximum Design Pressure:	-67.5 psf (See General Limitation #7.)



Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., type B, Grade 33 steel deck secured to structural steel supports spaced at a maximum of 6 ft. o.c. spans attached with two (2) Traxx/5 screws and 0.75" diameter washers at each corrugation (6" o.c.). Side laps are secured with Traxx/1 screws spaced 13" o.c.
System Type C(7):	All layer of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 2" thick	2 & 3	1:1.33 ft²

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Ply Sheet: (Optional)	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Cap Sheet:	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Surfacing:	<ol style="list-style-type: none"> 1. 400 lb./ 100ft² gravel in a flood coat of SuperiorFlex Seal Plus at a rate of 5 gal./100 ft². 2. Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq. 3. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., with one coat of Wite Brite Elastomeric Coating applied at a rate of 1.5 gal/sq.
Maximum Design Pressure:	-127.5 psf (See General Limitation #7.)



NOA No.: 20-0721.18
 Expiration Date: 10/15/25
 Approval Date: 09/03/20
 Page 11 of 18

Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., type B, Grade 33 steel deck secured to structural steel supports spaced at a maximum of 6 ft. o.c. spans attached with two (2) Traxx/5 screws and 0.75" diameter washers at each corrugation (6" o.c.). Side laps are secured with Traxx/1 screws spaced 13" o.c.
System Type C(8):	All layer of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 2" thick	2 & 3	1: 1.33 ft²

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Ply Sheet: (Optional)	One ply of SR SuperiorPly SAM II or one ply of SR SuperiorPly SAP II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Cap Sheet:	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Surfacing:	<ol style="list-style-type: none"> 1. 400 lb./ 100ft² gravel in a flood coat of SuperiorFlex Seal Plus at a rate of 5 gal./100 ft². 2. Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq. 3. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., with one coat of Wite Brite Elastomeric Coating applied at a rate of 1.5 gal/sq.
Maximum Design Pressure:	-127.5 psf (See General Limitation #7.)



NOA No.: 20-0721.18
Expiration Date: 10/15/25
Approval Date: 09/03/20
Page 12 of 18

Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., 33 ksi steel
System Type C(9):	All layer of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 1” thick	N/A	N/A
Monoboard Plus or Monoboard Minimum 1” thick	N/A	N/A

All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 1.5” thick	2 with 3 or 5, 6, 7 with 8	1:1.33 ft ²

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of SR SuperiorPly SAM II self-adhered with heat weld side laps, and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 12-inches o.c.
Ply Sheet: (Optional)	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 12-inches o.c.
Cap Sheet:	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 12-inches o.c.



Surfacing:

1. 400 lb./ 100ft² gravel in a flood coat of SuperiorFlex Seal Plus at a rate of 5 gal./100 ft².
2. Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq.
3. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., with one coat of Wite Brite Elastomeric Coating applied at a rate of 1.5 gal/sq.

**Maximum Design
Pressure:**

-45 psf (See General Limitation #9.)

Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., 33ksi steel deck ASTM designation A653/A653M-01a secured to structural supports spaced at a maximum of 6 ft. o.c. spans with ITW Buildex ICH Traxx/5 fasteners spaced 6" o.c. Side laps are secured with ITW Buildex ICH Traxx/1 fasteners at 24" o.c.
System Type C(10):	All layer of insulation are mechanically attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 1" thick	N/A	N/A
Monoboard Plus or Monoboard Minimum 1" thick	N/A	N/A

All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 1.5" thick	2 with 3 or 5, 6, 7 with 8	1:1.33 ft ²

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of SR SuperiorPly SAM II self-adhered with heat weld side laps, and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Ply Sheet: (Optional)	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.
Cap Sheet:	One ply of SR SuperiorPly SAM II self-adhered and adhered with SuperiorFlex Seal Max 1-inch wide ribbons 6-inches o.c.



Surfacing:

1. 400 lb./ 100ft² gravel in a flood coat of SuperiorFlex Seal Plus at a rate of 5 gal./100 ft².
2. Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq.
3. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., with one coat of Wite Brite Elastomeric Coating applied at a rate of 1.5 gal/sq.

**Maximum Design
Pressure:**

-60 psf (See General Limitation #7.)

Membrane Type:	SBS
Deck Type 3I:	Steel Deck, Insulated
Deck Description:	Min 22 ga., 33ksi steel deck ASTM designation A653/A653M-01a secured to structural supports spaced at a maximum of 6 ft. o.c. spans with ITW Buildex ICH Traxx/5 fasteners spaced 6" o.c. Side laps are secured with ITW Buildex ICH Traxx/1 fasteners at 24" o.c.
System Type D(1):	All insulation is loose laid with preliminary attachment to roof deck. Membrane and/or anchor sheet is subsequently mechanically fastened through insulation to the roof deck.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II Minimum 1" thick	N/A	N/A

All layers of insulation and base sheet shall be simultaneously attached. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Base Sheet: One ply of SR SuperiorPly SAP II mechanically attached in the 3" wide lap, through the insulation to the deck with OMG #14 Heavy duty, #14 Roofgrip, or OMG XHD fasteners through OMG 2" Barbed Plates; or with Trufast #14 Stainless Steel HD or Trufast #15 EHD through Trufast 2" Barbed Metal Seam Plates spaced 12: o.c.

**Ply Sheet:
(Optional)** One ply of SR SuperiorPly SAM II self-adhered.

Cap Sheet: One ply of SR SuperiorPly SAM II self-adhered.

Surfacing:

1. 400 lb./ 100ft² gravel in a flood coat of SuperiorFlex Seal Plus at a rate of 5 gal./100 ft².
2. Wite Brite Elastomeric Coating or Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., one layer of SR Poly Plus 40 fabric reinforcement is laid dry and back rolled. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq. immediately after SR Poly Plus 40 is laid. After 24 hours, a coat of Wite Brite Elastomeric Coating is applied at 1.0 gal/sq for a total of 4 gal/sq.
3. Wite Brite Elastomeric Coating-Contrast FR applied in one coat at 1.5 gal/sq., with one coat of Wite Brite Elastomeric Coating applied at a rate of 1.5 gal/sq.

**Maximum Design
Pressure:** -45 psf (See General Limitation #9.)



NOA No.: 20-0721.18
Expiration Date: 10/15/25
Approval Date: 09/03/20
Page 17 of 18

STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be minimum 22 gage, 33 ksi, steel deck attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THIS ACCEPTANCE