



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Johns Manville Corporation
717 17th Street
Denver, CO 80202

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Johns Manville Self-Adhering Modified Roofing Systems Over Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 16-0413.04 and consists of pages 1 through 10.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 20-1214.03
Expiration Date: 07/19/26
Approval Date: 04/22/21
Page 1 of 10

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Modified Bitumen
Materials:	APP/SBS
Deck Type:	Concrete
Maximum Design Pressure:	-195 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
DynaGrip Base SD/SA	65'7" x 39-3/8" roll weight: 94 lbs.	ASTM D4601	A SBS modified bitumen coated, fiber glass reinforced, self-adhering base sheet.
JMCleanBond Base	65'-7" x 39-3/8" roll weight: 80 lbs.	ASTM D4601	A SBS modified bitumen coated, fiber glass reinforced, self-adhering base sheet, with added fire retardant.
JM BaseGrip SD/SA	72' x 36"	ASTM D4601	An SBS modified bitumen fiber glass base sheet with a sanded-surfacing top and self-adhered side lap and bottom.
JMCleanBond Cap	32'-10" x 39-3/8" roll weight: 100 lbs.	ASTM D6163	A SBS modified bitumen coated, fiber glass reinforced, self-adhering cap sheet, with added fire retardant.
JM APP Base	39-3/8" x 48'10"	ASTM D6509	APP modified asphalt, fiberglass reinforced, smooth surfaced base sheet.
DynaWeld Base	39'-3/8" x 32'-10"	ASTM D6163	A glass reinforced SBS modified bitumen base sheet for heat welded applications.
APPeX 4.5M FR	39-3/8" x 34'	ASTM D6222 Type I Grade G	APP modified asphalt, polyester reinforced, fire-retardant, mineral surfaced membrane.
Tricor M FR	39-3/8" x 34'	ASTM D6223	APP modified asphalt, polyester / glass reinforced, granule surfaced membrane.
Tricor M FR CR	39-3/8" x 34'	ASTM D6223	APP modified asphalt, polyester / glass reinforced, coated granule surfaced membrane.
JM Two Part Urethane Insulation Adhesive	Various	Proprietary	A two-component, cold-applied adhesive.
JM Two-Part UIA	Various	Proprietary	A two-component, cold-applied adhesive.
JM Two-Part Urethane Insulation Adhesive Canister	Various	Proprietary	Self-contained two-part, low-rise foam adhesive.
JM Two-Part UIA Canister	Various	Proprietary	Self-contained two-part, low-rise foam adhesive.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
JM Roofing System Urethane Adhesive	Various	Proprietary	A two-component, cold-applied adhesive
JM One-Step Foamable Adhesive	N/A	Proprietary	A two-part urethane insulation adhesive.
JM Vapor Barrier SA	45' x 134'	TAS 131	Polyethylene-reinforced, self-adhering SBS vapor barrier.
JM Vapor Barrier SAR	45' x 134'	ASTM D 1970	Fiber Glass-Reinforced, Polyethylene Surfaced, Self-Adhering SBS Vapor Barrier.
JM SA Primer Low VOC	5 gal.	ASTM D 1644	One-part, specification grade, penetrating priming solution.
JM SA Primer	5 gal.	Proprietary	One-part, specification grade, penetrating priming solution.
Urethane Insulation Adhesive	N/A	Proprietary	A one-part, cold application adhesive.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI	Polyisocyanurate insulation	Johns Manville
ENRGY 3 Foil Faced, ENRGY 3 Foil Faced 25 PSI	Polyisocyanurate insulation with foil facer	Johns Manville
ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI	Polyisocyanurate insulation	Johns Manville
DensDeck Prime	Silicone treated Gypsum	Georgia Pacific Gypsum, LLC
DEXcell FA Glass Mat Roof Board	Mold resistant gypsum board used as a coverboard and/or thermal barrier	National Gypsum Company

APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	N/A	N/A	N/A	N/A



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
FM Approvals	3017543	FM Class 4470	03/05/04
	3037540	FM 4450	10/20/10
	PR453769	FM 4470	04/27/20
UL LLC	R10167	UL 790	02/04/21
PRI Construction Materials Technologies, LLC	JMC-063-02-01	ASTM D6163	06/11/12
	JMC-076-02-01	ASTM D4601	06/11/12
	JMC-091-02-01	ASTM D4601	05/26/16
	JMC-147-02-01	ASTM D4601	05/28/13
	JMC-157-02-01	TAS 114 (D)	08/14/13
	JMC-053-02-01	ASTM D 6222	05/01/13
	JMC-054-02-01.04	ASTM D 6223	06/04/12
	JMC-107-02-01.8	Physical Property	09/17/20
	JMC-330-02-03 507T0019	ASTM D 6222 ASTM D 1970	10/17/18 08/28/19



APPROVED ASSEMBLIES

- Membrane Type:** SBS
- Deck Type 3I:** Concrete Decks, Insulated
- Deck Description:** 2500 psi structural concrete or concrete plank
- System Type A(1):** One or more layers of insulation adhered with approved adhesive.

All General and System Limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ENRGY3 Foil Faced, ENRGY 3 Foil Faced 25 PSI Minimum 1.5" thick	N/A	N/A

Note: Insulation shall be adhered with Urethane Insulation Adhesive in ¾" to 1" wide beads at maximum spacing of 12" o.c. and walked-in. Adhesive beads in subsequent insulation layers are applied perpendicular to those applied in preceding layers. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

- Base Sheet:** DynaGrip Base SD/SA or JMCleanBond Base, self-adhered with a 4" head lap and end lap.
- Ply Sheet:** (Optional) One ply of DynaGrip Base SD/SA or JMCleanBond Base, self-adhered with a 4" head lap and end lap.
- Membrane:** JMCleanBond Cap, self-adhered with a 4" head lap and end lap.
- Surfacing:** (Optional) Install the following:
1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400 lbs./sq., respectively.
- Maximum Design Pressure:** -75 psf. (See General Limitation #9.)



Membrane Type: SBS
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(2): One or more layers of insulation adhered with approved adhesive.

All General and System Limitations apply.

Vapor Barrier (Optional): DynaGrip Base SD/SA, self-adhered or JM APP Base, torch adhered. Concrete deck primed with ASTM D 41 asphaltic primer prior to application of vapor barrier.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ValuTherm, R-Panel, ENRGY 3 25 PSI, ValuTherm 25 PSI, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime, DEXcell FA Glass Mat Roof Board Minimum ¼" thick	N/A	N/A

Note: Insulation shall be adhered with JM Roofing System Urethane Adhesive, JM One-Step Foamable Adhesive, JM Two Part Urethane Insulation Adhesive, JM Two Part UIA, JM Two Part Urethane Insulation Adhesive Canister, or JM Two Part UIA Canister in ¾" to 1" wide beads at maximum spacing of 12" o.c. and walked-in. Adhesive beads in subsequent insulation layers are applied perpendicular to those applied in preceding layers. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: DynaGrip Base SD/SA or DynaGrip Base 250 SD/SA, self-adhered with a 4" head lap and end lap.

Ply Sheet (Optional): DynaWeld Base, DynaBase HW, DynaWeld 180 S, DynaFast 180 HW, DynaWeld 250 S, or DynaFast 250 HW, torch applied with a min. 3" lap.

Membrane: DynaWeld Cap, DynaWeld Cap FR, DynaWeld Cap FR CR, DynaWeld Cap FR CR G, DynaWeld Cap 180 FR CR, DynaWeld Cap 180 FR CR G, DynaWeld Cap 180 FR, DynaWeld Cap FR XT, DynaWeld Cap 250 FR, DynaWeld Cap 250, DynaWeld Cap 250 FR CR G, DynaKap FR T1 HW CR G, DynaMax FR HW, DynaWeld Cap 250 FR CR, DynaMax FR HW CR torch applied with a min. 3" lap.

Surfacing: (Optional) Install the following:
 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400 lbs./sq., respectively.

Maximum Design Pressure: -195 psf. without Vapor Barrier (See General Limitation #9.)
 -180 psf. with Vapor Barrier (See General Limitation #9.)



Membrane Type: SBS
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(3): One or more layers of insulation adhered with approved adhesive.

All General and System Limitations apply.

Vapor Barrier: JM Vapor Barrier SAR or JM Vapor Barrier SA, self-adhered to concrete deck primed with JM SA Primer Low VOC or JM SA Primer applied at a rate of 0.5 gal/sq.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ValuTherm, R-Panel, ENRGY 3 25 PSI, ValuTherm 25 PSI, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime, DEXcell FA Glass Mat Roof Board Minimum ¼" thick	N/A	N/A

Note: Insulation shall be adhered with JM Roofing System Urethane Adhesive, JM One-Step Foamable Adhesive, JM Two Part Urethane Insulation Adhesive, JM Two Part UIA, JM Two Part Urethane Insulation Adhesive Canister, or JM Two Part UIA Canister in ¾" to 1" wide beads at maximum spacing of 12" o.c. and walked-in. Adhesive beads in subsequent insulation layers are applied perpendicular to those applied in preceding layers. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: DynaGrip Base SD/SA or DynaGrip Base 250 SD/SA, self-adhered with a 4" head lap and end lap.

Ply Sheet: DynaWeld Base, DynaBase HW, DynaWeld 180 S, DynaFast 180 HW, DynaWeld 250 S, or DynaFast 250 HW, torch applied with a min. 3" lap.

Membrane: DynaWeld Cap, DynaWeld Cap FR, DynaWeld Cap FR CR, DynaWeld Cap FR CR G, DynaWeld Cap 180 FR CR, DynaWeld Cap 180 FR CR G, DynaWeld Cap 180 FR, DynaWeld Cap FR XT, DynaWeld Cap 250 FR, DynaWeld Cap 250, DynaWeld Cap 250 FR CR G, DynaKap FR T1 HW CR G, DynaMax FR HW, DynaWeld Cap 250 FR CR, DynaMax FR HW CR torch applied with a min. 3" lap.

Surfacing: (Optional) Install the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400 lbs./sq., respectively.

Maximum Design Pressure: -135 psf. with JM One-Step Foamable Adhesive, or JM Roofing Systems Urethane Adhesive (See General Limitation #9.)
-82.5 psf. with JM Two Part Urethane Insulation Adhesive, JM Two Part UIA, JM Two Part Urethane Insulation Adhesive Canister, or JM Two Part UIA Canister (See General Limitation #9.)



Membrane Type: APP
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(1): Base sheet adhered to primed concrete

All General and System Limitations apply.

Primer: Deck primed with ASTM D41 primer with an application rate of 1 gal./sq.
Base Sheet: JM BaseGrip SD/SA, self-adhered with a 4” head lap and end lap.
Ply Sheet: None
Membrane: APPeX 4.5M FR heat welded while maintaining 4” side laps and 6” end laps.
Maximum Design Pressure: -180 psf. (See General Limitation #9.)



Membrane Type: APP
Deck Type 3: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(2): Base sheet adhered to primed concrete

All General and System Limitations apply.

Primer: Deck primed with ASTM D41 primer with an application rate of 1 gal./sq.
Base Sheet: JM BaseGrip SD/SA, self-adhered with a 4" head lap and end lap.
Ply Sheet: None
Membrane: APPeX 4.5M FR, Tricor M FR, or Tricor M FR CR heat welded while maintaining 4" side laps and 6" end laps.
Maximum Design Pressure: -132.5 psf. (See General Limitation #9.)



CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117; calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE