



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

**GAF**  
**1 Campus Drive**  
**Parsippany, NJ 07054**

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: **GAF Timberline Ultra HD® and Timberline® UHD Shingles**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 18-0123.07 and consists of pages 1 through 5.  
The submitted documentation was reviewed by *Freddy Semino*



NOA No.: 21-0105.12  
Expiration Date: 04/22/23  
Approval Date: 02/18/21  
Page 1 of 5

## ROOFING ASSEMBLY APPROVAL

**Category:** Roofing  
**Sub-Category:** Asphalt Shingles  
**Materials:** Laminate  
**Deck Type:** Wood

### SCOPE

This approves **GAF Timberline Ultra HD®** and **Timberline® UHD Shingles** as manufactured by GAF described in Section 2 of this Notice of Acceptance.

### PRODUCT DESCRIPTION

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
<b>GAF Timberline Ultra HD®</b> <i>Manufacturing</i> <i>Locations # 1, 2, 3.</i>	13 <sup>1</sup> / <sub>4</sub> " x 39 <sup>3</sup> / <sub>8</sub> "	TAS 110	Fiberglass reinforced heavy weight asphalt roof shingle, with a laminate profile.
<b>GAF Timberline® UHD</b> <i>Manufacturing</i> <i>Locations #1, 2, 3</i>	13 <sup>1</sup> / <sub>4</sub> " x 39 <sup>3</sup> / <sub>8</sub> "	TAS 100	Fiberglass reinforced heavy weight asphalt roof shingle, with a laminte profile.

### MANUFACTURING LOCATION

1. Michigan City, IN
2. Myerstown, PA
3. Tuscaloosa, AL

### EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Underwriters Laboratories, Inc.	ASTM D 3462	4788201324	01/02/17
	ASTM D 3462	4788201324	01/04/17
	ASTM D 3462	4788201324	12/20/17
	TAS 107	02NK41811	11/11/02
	TAS 107	03CA35209	10/17/03
	TAS 107	05CA42840	11/11/05
	TAS 107	06CA10139	09/13/06
PRI Asphalt Technologies, Inc.	TAS 100	GAF-046-02-01	04/05/04
	TAS 100	GAF-103-02-01	11/16/05



NOA No.: 21-0105.12  
Expiration Date: 04/22/23  
Approval Date: 02/18/21  
Page 2 of 5

## LIMITATIONS

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Shall not be installed on roof mean heights in excess of **33 ft.**
3. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule **61G20-3** of the Florida Administrative Code.

## INSTALLATION

1. Shingles shall be installed in compliance with Roofing Application Standard RAS 115.
2. Flashing shall be in accordance with Roofing Application Standard RAS 115
3. The manufacturer shall provide clearly written application instructions.
4. Exposure and course layout shall be in compliance with Detail 'A', attached.
5. Nailing shall be in compliance with Detail 'B', attached.

## LABELING

Shingles shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



## BUILDING PERMIT REQUIREMENTS:


Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by Building Official or Applicable building code in order to properly evaluate the installation of this material.




NOA No.: 21-0105.12  
Expiration Date: 04/22/23  
Approval Date: 02/18/21  
Page 3 of 5


**DETAIL A**  
**COURSE LAYOUT**



**DETAIL B – 13-1/4" X 39-3/8"**  
**OVERALL DIMENSIONS AND NAILING PATTERN**



Front Side (Maximum Slope 21:12)



Back Side

**GAF TIMBERLINE ULTRA HD® and Timberline® UHD Shingles**

**END OF THIS ACCEPTANCE**



NOA No.: 21-0105.12  
 Expiration Date: 04/22/23  
 Approval Date: 02/18/21  
 Page 5 of 5