



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599

**NOTICE OF ACCEPTANCE (NOA)**

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Atlas Armor, Inc.**  
430 South Congress Avenue, Suite 3  
Delray Beach, Florida 33445

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER- Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: "Atlas Armor Hurricane Screens" Flexible Wind Abatement System**

**APPROVAL DOCUMENT:** Drawing No. 22-54540, titled "Atlas Armor Hurricane Screens", sheets 1 through 10 of 10, prepared by Engineering Express, dated July 22, 2021, last revised on April 05, 2023, signed and sealed by Richard Neet, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and the expiration date by the Miami-Dade County Product Control Section.

**MISSILE IMPACT RATING: Large and Small Missile Impact Resistant**

**LABELING:** Each panel shall bear a permanent label with the manufacturer's name or logo, city, state, the following statement: "Miami-Dade County Product Control Approved", and NOA number, per TAS-201, TAS-202, and TAS-203, unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises & renews** NOA #21-0512.04 and consists of this page 1, evidence submitted pages E-1, E-2, E-3, E-4 & E-5 as well as approval document mentioned above.

The submitted documentation was reviewed by **Helmy A. Makar, P.E., M.S.**



*Helmy A. Makar*  
04/13/2023

NOA No. 23-0120.02  
Expiration Date: 04/18/2028  
Approval Date: 04/13/2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

**1. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL #12-1107.05**

**A. DRAWINGS**

1. *Drawing No. AD12-60, titled "Gladiator Screening Systems", sheets 1 through 10 of 10, prepared by MCY Engineering, Inc., dated April 03, 2013, signed and sealed by Yiping Wang, P.E., on April 04, 2013.*

**B. TESTS**

1. *Test report on Uniform Static Air Pressure Test of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-11-3340, dated December 12, 2011, signed and sealed by Rafael E. Droz-Seda, P.E.*
2. *Test report on Large Missile Impact Test and Cyclic Wind Pressure Test of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-11-3341, dated December 12, 2011, signed and sealed by Rafael E. Droz-Seda, P.E.*
3. *Test report on Uniform Static Air Pressure Test of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-11-3343, dated December 12, 2011, signed and sealed by Rafael E. Droz-Seda, P.E.*
4. *Test report on Large Missile Impact Test and Cyclic Wind Pressure Test of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-11-3336, dated December 12, 2011, signed and sealed by Rafael E. Droz-Seda, P.E.*
5. *Test report on Large Missile Impact Test and Cyclic Wind Pressure Test of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-12-4057, dated September 21, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
6. *Test report on Uniform Static Air Pressure Test of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-12-4056, dated September 21, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
7. *Test report on Uniform Static Air Pressure Test of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-11-3335, dated December 12, 2011, signed and sealed by Rafael E. Droz-Seda, P.E.*
8. *Test report on Uniform Static Air Pressure Test of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-12-4060, dated September 21, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*



---


Helmy A. Makar, P.E., M.S.  
Product Control Section Supervisor  
NOA No. 23-0120.02  
Expiration Date: 04/18/2028  
Approval Date: 04/13/2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

9. *Test report on Large Missile Impact Test and Cyclic Wind Pressure Test of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-12-4061, dated September 21, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
10. *Compressive Strength of Cylindrical Concrete Specimens, per ASTM C39-12, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-11-C173, dated October 02, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
11. *Compressive Strength of Grout, per ASTM C39-12, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-11-C172, dated October 02, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
12. *Breaking Strength and Elongation of Textile Fabrics Grab Test per ASTM D 5034-09 prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-12-T121, dated September 21, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
13. *Breaking Strength and Elongation of Textile Fabrics Grab Test per ASTM D 5034-09 prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-12-T122, dated September 21, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
14. *Sewn Seams Strength Using Grab Tensile Test per ASTM D 1683-11a prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-12-T123, dated September 21, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
15. *Breaking Force and elongation of Textile fabrics per ASTM D 638-10/ASTM D 5035-11 prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-12-U108, dated July 24, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
16. *Breaking Force and elongation of Textile fabrics per ASTM D 638-10/ASTM D 5035-11 prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-12-U109, dated July 24, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
17. *Accelerated Weathering Using Xenon Arc light Apparatus per ASTM G 155-05a prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-12-A403, dated July 24, 2012, signed and sealed by Rafael E. Droz-Seda, P.E.*
18. *Test report on Large Missile Impact Test and Cyclic Wind Pressure Test of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report No. HETI-11-3345, dated December 12, 2011, signed and sealed by Rafael E. Droz-Seda, P.E.*
19. *Test report on Large Missile Impact and Cyclic Wind Pressure of Gladiator Screening System Flexible Hurricane Wind Abatement System, prepared by Hurricane Engineering & Testing, Inc., Report #HETI-11-3344, dated 12/12/11, signed and sealed by Rafael E. Droz-Seda, P.E.*

**C. CALCULATIONS**

1. *Comparative Analysis and Anchor calculations dated 11/03/12, Pages L-1, L-2, D-1, TR-1, A-1 through A-31, R-1 through R-3, T-1 through T-55, prepared by MCY Engineering, Inc., signed and sealed by Yiping Wang, P.E.*

  
\_\_\_\_\_  
Helmy A. Makar, P.E., M.S.  
Product Control Section Supervisor  
NOA No. 23-0120.02  
Expiration Date: 04/18/2028  
Approval Date: 04/13/2023

**Atlas Armor, Inc.**

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**D. QUALITY ASSURANCE**

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

**E. MATERIAL CERTIFICATIONS**

1. *Fabric specifications.*

**2. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL #14-0811.17**

**A. DRAWINGS**

1. *Drawing No. AD12-60, titled "Gladiator Screening Systems", sheets 1 through 10 of 10, prepared by MCY Engineering, Inc., dated April 03, 2013, last revision #1 dated October 13, 2015, signed and sealed by Yiping Wang, P.E.*

**B. TESTS**

1. *None.*

**C. CALCULATIONS**

1. *Anchor calculations dated October 12, 2015, Pages L-1, L-2, D-1, TR-1, A-1 through A-36, R-1 through R-5, prepared by MCY Engineering, Inc., signed and sealed by Yiping Wang, P.E., on October 15, 2015.*

**D. QUALITY ASSURANCE**

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

**E. MATERIAL CERTIFICATIONS**

1. *Fabric specifications.*

**3. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL #17-0426.11**

**A. DRAWINGS**

1. *None.*

**B. TESTS**

1. *None.*

**C. CALCULATIONS**

1. *None.*

**D. QUALITY ASSURANCE**

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

**E. MATERIAL CERTIFICATIONS**

1. *None.*



Helmy A. Makar, P.E., M.S.  
Product Control Section Supervisor  
NOA No. 23-0120.02  
Expiration Date: 04/18/2028  
Approval Date: 04/13/2023

**Atlas Armor, Inc.**

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**4. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL #19-0415.03**

**A. DRAWINGS**

1. *Drawing No. AD12-60, titled "Atlas Armor Hurricane Screens", sheets 1 through 10 of 10, prepared by MCY Engineering, Inc., dated March 04, 2019, last revision #2 dated March 04, 2019, signed and sealed by Yiping Wang, P.E.*

**B. TESTS**

1. *None.*

**C. CALCULATIONS**

1. *None.*

**D. QUALITY ASSURANCE**

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

**E. MATERIAL CERTIFICATIONS**

1. *None.*

**5. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL #21-0512.04**

**A. DRAWINGS**

1. *Drawing No. AD12-60, titled "Atlas Armor Hurricane Screens", sheets 1 through 10 of 10, prepared by MCY Engineering, Inc., dated March 04, 2019, last revision #3 dated May 08, 2021, signed and sealed by Yiping Wang, P.E.*

**B. TESTS**

1. *None.*

**C. CALCULATIONS**


1. *None.*

**D. QUALITY ASSURANCE**

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

**E. MATERIAL CERTIFICATIONS**

1. *None.*



Helmy A. Makar, P.E., M.S.  
Product Control Section Supervisor  
NOA No. 23-0120.02  
Expiration Date: 04/18/2028  
Approval Date: 04/13/2023

**Atlas Armor, Inc.**

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**6. NEW EVIDENCE SUBMITTED**

**A. DRAWINGS**

1. *Drawing No. 22-54540, titled "Atlas Armor Hurricane Screens", sheets 1 through 10 of 10, prepared by Engineering Express, dated July 22, 2021, last revised on April 05, 2023, signed and sealed by Richard Neet, P.E.*

**B. TESTS**

1. *None.*

**C. CALCULATIONS**


1. *None.*

**D. QUALITY ASSURANCE**

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

**E. MATERIAL CERTIFICATIONS**

1. *None.*



---


**Helmy A. Makar, P.E., M.S.**  
**Product Control Section Supervisor**  
**NOA No. 23-0120.02**  
**Expiration Date: 04/18/2028**  
**Approval Date: 04/13/2023**

# ATLAS ARMOR HURRICANE SCREENS


NON-SITE-SPECIFIC STRUCTURAL PERFORMANCE EVALUATION. A DESIGN PROFESSIONAL SHALL BE RESPONSIBLE FOR CERTIFYING THE APPLICATION OF THIS INFORMATION TO ANY SITE-SPECIFIC LOCATION.

RICHARD NEET, P.E.  
PE# 86488 CA# 9885

APRIL 6, 2023



Digitally signed by Richard Neet  
Reason: Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies  
Date: 2023.04.06 12:10:47-04'00'



ATLAS ARMOR HURRICANE SCREEN SYSTEM WITH HOUSING  
(L.M.I. & S.M.I.)

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 23-0120.02  
Expiration Date 04/18/2028  
By *Helga*  
Miami Dade Product Control

7. ANCHORING OR LOADING CONDITIONS NOT SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.
8. MATERIALS INCLUDING BUT NOT LIMITED TO METAL SCREWS THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE FLORIDA BUILDING CODE SEVENTH EDITION (2020) SECTION AS APPLICABLE.
9. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR/E.O.R. TO VERIFY THAT THE EXISTING STRUCTURE OR APPROVED MULLION IS DESIGNED TO SUPPORT  $F_x$  &  $F_y$  FORCES AT END OF TRACK. FOR  $F_x$  &  $F_y$  REFER TO CHART ON SHEET 3.
10. ROLLUP MECHANISM IS NOT PART OF THIS APPROVAL. CARE SHOULD BE TAKEN WHEN SCREEN IS IN MOTION TO ENSURE THAT PERSONAL INJURY OR DAMAGE TO THIS PRODUCT DOES NOT OCCUR.
11. ALL SCREEN PANELS SHALL BE PERMANENTLY LABELED, IN A READILY VISIBLE LOCATION, WITH AT LEAST ONE LABEL STATING:  

ATLAS ARMOR, INC  
430 SOUTH CONGRESS AVE, SUITE 3  
DELRAY BEACH, FL 33445  
MIAMI DADE COUNTY  
PRODUCT CONTROL APPROVAL
12. ENGINEER SEAL AFFIXED HERETO VALIDATES STRUCTURAL DESIGN AS SHOWN ONLY. USE OF THIS SPECIFICATION BY CONTRACTOR, et. al. INDEMNIFIES & SAVES HARMLESS THIS ENGINEER FOR ALL COST & DAMAGES INCLUDING LEGAL FEES & APPELLATE FEES RESULTING FROM MATERIAL FABRICATION, SYSTEM ERECTION, & CONSTRUCTION PRACTICES BEYOND THAT WHICH IS CALLED FOR BY LOCAL, STATE, & FEDERAL CODES & FROM DEVIATIONS OF THIS PLAN.
13. ALTERATIONS, ADDITIONS, OR OTHER MARKINGS TO THIS DOCUMENT ARE NOT PERMITTED AND INVALIDATE THIS CERTIFICATION.
14. EXCEPT AS EXPRESSLY PROVIDED HEREIN, NO ADDITIONAL CERTIFICATIONS OR AFFIRMATIONS ARE INTENDED.

**GENERAL NOTES:**

1. THE ROLLING SCREEN SYSTEM IS A NON-POROUS LARGE/SMALL MISSILE IMPACT PROTECTION DEVICE. IT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE SEVENTH EDITION (2020). FOR USE INSIDE AND OUTSIDE OF THE HIGH VELOCITY HURRICANE ZONE (HVHZ).
2. THIS PRODUCT HAS BEEN TESTED AS PER FBC 2020 TAS 201, 202 (STRUCTURAL WIND LOAD ONLY) AND 203 FOR LARGE/SMALL MISSILE IMPACT. THE SYSTEM IS ALSO TESTED AS PER ASTM D635-06, ASTM D2843-99, ASTM D1929-96 AND ASTM G155.
3. THIS PRODUCT HAS SUCCESSFULLY PASSED THE EXTENDED WEATHERING TEST (ASTM G-155) FOR DAILY USAGE IN FULL SPECTRUM SUNLIGHT.
4. DESIGN LOAD SHALL BE DETERMINED BASED ON BASIC WIND SPEED, BUILDING HEIGHT, AND WIND ZONE USING APPLICABLE ASCE 7-16 STANDARD.
5. DESIGN LOAD OBTAINED FROM ASCE 7-16 (ULTIMATE LOAD), MULTIPLIED BY 0.6, SHALL BE LESS THAN OR EQUAL TO MAX. DESIGN LOAD IN THIS DOCUMENT.
6. ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS. ANCHOR EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

**ENGINEERING EXPRESS**  
POSTAL ADDRESS:  
401 W. ATLANTIC AVE R10 BOX 219  
DELRAY BEACH, FL 33444  
ENGINEERINGEXPRESS.COM

**ATLAS ARMOR, INC.**  
420 SOUTH CONGRESS AVENUE, SUITE 3  
DELRAY BEACH, FLORIDA 33445  
(561) 206-0813

ATLAS ARMOR HURRICANE SCREENS  
FLORIDA BUILDING CODE SEVENTH EDITION (2020)  
MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE (NOA)


REMARKS	DRWN	CHKD	DATE
NOA # 21-0512.04 NOA RENEWAL	EPR	RWN	07/22/21 04/05/23
COPYRIGHT ENGINEERING EXPRESS®			
22-54540			
SCALE: NTS UNLESS NOTED			
1 OF 10			

c:\users\eric\desktop\22-54540d.noa.dwg.dwg 4/6/2023 11:48 AM ERIC

c:\users\eric\Desktop\22-54540d noa.dwg.dwg

ERIC

4/6/2023 11:48 AM



SCREEN ELEVATION  
BOTH SIDES SUPPORT

ATLAS ARMOR HURRICANE SCREEN SYSTEM  
WITHOUT HOUSING (L.M.I. & S.M.I)

SCREEN ELEVATION  
TOP & BOTTOM SUPPORT

DESIGN LOADS V.S.  
SCREEN WIDTH SEE  
CHART ON SHEET 3

RICHARD NEET, P.E.  
PE# 86488 CA# 9885

APRIL 6, 2023

FL

**EX ENGINEERING EXPRESS**

POSTAL ADDRESS:  
401 W. ATLANTIC AVE R10 BOX 219  
DELRAY BEACH, FL 33444  
ENGINEERINGEXPRESS.COM

**ATLAS ARMOR, INC.**  
420 SOUTH CONGRESS AVENUE, SUITE 3  
DELRAY BEACH, FLORIDA 33445  
(561) 206-0813





ATLAS ARMOR HURRICANE SCREENS  
FLORIDA BUILDING CODE SEVENTH EDITION (2020)  
MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE (NOA)

REMARKS	DRWN	CHKD	DATE
NOA # 21-0512.04	EPR	RVN	07/22/21
NOA RENEWAL			04/05/23

22-54540


SCALE: NTS UNLESS NOTED

2 OF 10





PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 23-0120.02  
Expiration Date 09/14/2028  
By *Hedy Avila*  
Miami Dade Product Control





**CHART FOR DESIGN LOAD VS. SPAN AND ANCHOR SPACING**

MAX. DESIGN LOAD (psf)	SPAN / SCREEN WIDTH (in)	END REACTIONS AT TRACK		GLASS SEPARATION	ANCHOR SPACING (in)															
					DETAIL A				DETAIL B				DETAIL C							
		F <sub>x</sub>	F <sub>y</sub>	a	OPTION 1	OPTION 2	OPTION 3		OPTION 4	OPTION 1	OPTION 2	OPTION 3		OPTION 4	OPTION 1	OPTION 2	OPTION 3		OPTION 4	
lb/ft	lb/ft	in	CONC.	CONC.	STEEL	ALUM.	WOOD	CONC.	CONC.	STEEL	ALUM.	WOOD	CONC.	CONC.	STEEL	ALUM.	WOOD			
≤ 50	0 to 84.0	602	175	9.7	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	
	120.0	685	250	15.0	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	
	156.0	734	325	21.7	5.5	5.5	5.5	5.5	5.0	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.0	
	192.0	761	400	29.9	5.4	5.5	5.5	5.5	4.5	5.4	5.5	5.5	5.5	-	5.5	5.5	5.5	5.5	4.7	
	230.8	774	481	40.6	5.0	5.5	5.5	5.5	4.0	5.1	5.5	5.5	5.5	-	5.5	5.5	5.5	5.5	4.5	
≤ 65	0 to 72.0	732	195	9.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	4.1	5.5	5.5	5.5	5.5	5.3	
≤ 80	0 to 84.0	964	280	9.7	5.1	5.5	5.5	5.3	4.6	-	5.5	5.5	5.3	-	5.5	5.5	5.5	5.5	4.0	
	120.0	1097	400	15.0	-	5.5	5.5	4.4	3.7	-	4.8	5.5	4.5	-	5.5	5.5	5.5	5.5	5.5	
	156.0	1175	520	26.8	-	4.9	5.5	3.9	3.2	-	-	5.5	4.0	-	5.5	5.5	5.5	5.5	-	
≤ 100	0 to 79.0	1205	350	10.0	-	5.4	5.5	4.2	3.7	-	4.5	5.3	4.2	-	5.5	5.5	5.5	5.5	-	



PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No **23-0120.02**  
Expiration Date **04/14/2028**  
By *Helga A. Alon*  
Miami Dade Product Control

**EX ENGINEERING EXPRESS**  
POSTAL ADDRESS:  
401 W. ATLANTIC AVE R10 BOX 219  
DELRAY BEACH, FL 33444  
ENGINEERINGEXPRESS.COM


**ATLAS ARMOR, INC.**  
420 SOUTH CONGRESS AVENUE, SUITE 3  
DELRAY BEACH, FLORIDA 33445  
(561) 206-0813  
ATLAS ARMOR HURRICANE SCREENS  
FLORIDA BUILDING CODE SEVENTH EDITION (2020)  
MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE (NOA)

REMARKS	DATE	DRWN	CHKD
NOA # 21-0512.04	07/22/21	-	-
NOA RENEWAL	04/05/23	EPR	RWN

COPYRIGHT ENGINEERING EXPRESS®  
**22-54540**


SCALE: NTS UNLESS NOTED  
**3** OF **10**

**DETAILS WITH STANDARD TRACKS**




**A** OPTION 1

5/16" Ø ULTRACONS W/ 2" MIN. EMBEDMENT INTO CONCRETE. FOR SPACING SEE CHART ON SHEET 3




**B** OPTION 1

5/16" Ø ULTRACONS W/ 2" MIN. EMBEDMENT INTO CONCRETE. FOR SPACING SEE CHART ON SHEET 3




**C** OPTION 1

**DETAILS WITH HEAVY DUTY TRACKS**




**A** OPTION 1

5/16" Ø ULTRACONS W/ 2" MIN. EMBEDMENT INTO CONCRETE. FOR SPACING SEE CHART ON SHEET 3



**B** OPTION 1

5/16" Ø ULTRACONS W/ 2" MIN. EMBEDMENT INTO CONCRETE. FOR SPACING SEE CHART ON SHEET 3




**C** OPTION 1

**ANCHOR**  
5/16" DIA. ULTRACON BY 'DEWALT' (Fy = 155 ksi, Fu = 177 ksi)

**ATTACHMENT TO CONCRETE**  
fc=3515 PSI MIN.

RICHARD NEET, P.E.  
PE# 86488 CA# 9885

APRIL 6, 2023



**EX ENGINEERING EXPRESS**  
POSTAL ADDRESS:  
401 W. ATLANTIC AVE R10 BOX 219  
DELRAY BEACH, FL 33444  
ENGINEERINGEXPRESS.COM

**ATLAS ARMOR, INC.**  
420 SOUTH CONGRESS AVENUE, SUITE 3  
DELRAY BEACH, FLORIDA 33445  
(561) 206-0813

ATLAS ARMOR HURRICANE SCREENS  
FLORIDA BUILDING CODE SEVENTH EDITION (2020)  
MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE (NOA)

REMARKS	NOA #	DATE	DRWN	CHKD	DATE
NOA RENEWAL	21-0512.04	07/22/21	EPR	RWN	04/05/23


COPYRIGHT ENGINEERING EXPRESS®

22-54540


SCALE: NTS UNLESS NOTED

4 OF 10


PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 23-0120.02  
Expiration Date 09/15/2028  
By *[Signature]*  
Miami Dade Product Control




**DETAILS WITH STANDARD TRACKS**



**A** OPTION 2




**B** OPTION 2




**C** OPTION 2


**DETAILS WITH HEAVY DUTY TRACKS**



**A** OPTION 2



**B** OPTION 2



**C** OPTION 2

**ANCHOR**  
3/8" DIA. WEDGE BOLT BY: "POWERS" (Fu = 100 KSI, Fy = 65 KSI)

**ATTACHMENT TO CONCRETE**  
f'c=3000 PSI MIN.

**ENGINEERING EXPRESS**  
POSTAL ADDRESS:  
401 W. ATLANTIC AVE R10 BOX 219  
DELRAY BEACH, FL 33444  
ENGINEERINGEXPRESS.COM

**ATLAS ARMOR, INC.**  
420 SOUTH CONGRESS AVENUE, SUITE 3  
DELRAY BEACH, FLORIDA 33445  
(561) 206-0813

ATLAS ARMOR HURRICANE SCREENS  
FLORIDA BUILDING CODE SEVENTH EDITION (2020)  
MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE (NOA)

REMARKS	DATE	DRWN	CHKD	EPR	RWN
NOA # 21-0512.04	07/22/21				
NOA RENEWAL	04/05/23				


COPYRIGHT ENGINEERING EXPRESS®

22-54540




SCALE: NTS UNLESS NOTED

5 OF 10




PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 23-0120.02  
Expiration Date 09/18/2028  
By: *Heidi A. Miller*  
Miami Dept. Product Control



**DETAILS WITH STANDARD TRACKS**



**DETAILS WITH HEAVY DUTY TRACKS**



**ANCHOR**  
5/16" ST./ST. TEKS SCREW Fu= 100 KSI Fy = 65 KSI

**ATTACHMENT TO STEEL/ALUM.**  
A36 OR 6063-T5 MIN. 1/4" MIN. THK

**ENGINEERING EXPRESS®**  
POSTAL ADDRESS:  
401 W. ATLANTIC AVE R10 BOX 219  
DELRAY BEACH, FL 33444  
ENGINEERINGEXPRESS.COM

**ATLAS ARMOR, INC.**  
420 SOUTH CONGRESS AVENUE, SUITE 3  
DELRAY BEACH, FLORIDA 33445  
(561) 206-0813  
ATLAS ARMOR HURRICANE SCREENS  
FLORIDA BUILDING CODE SEVENTH EDITION (2020)  
MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE (NOA)

REMARKS	DATE	DRWN	CHKD
NOA # 21-0512.04	07/22/21		
NOA RENEWAL	04/05/23	EPR	RWN

COPYRIGHT ENGINEERING EXPRESS®


22-54540

SCALE: NTS UNLESS NOTED


6 OF 10

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 23-0120.02  
Expiration Date 04/15/2028  
By *H. S. A. Alkhr*  
Miami Dade Product Control


**DETAILS WITH STANDARD TRACKS**



**A** OPTION 4




**B** OPTION 4




**C** OPTION 4


**DETAILS WITH HEAVY DUTY TRACKS**



**A** OPTION 4



**B** OPTION 4



**C** OPTION 4


**ANCHOR**

5/16" DIA. ULTRACON BY 'DEWALT' (Fy = 155 ksi, Fu = 177 ksi)

**ATTACHMENT TO WOOD**  
SG=0.55 MIN

RICHARD NEET, P.E.  
PE# 86488 CA# 9885

APRIL 6, 2023



FL

**ENGINEERING EXPRESS**

POSTAL ADDRESS:  
401 W. ATLANTIC AVE R10 BOX 219  
DELRAY BEACH, FL 33444  
ENGINEERINGEXPRESS.COM

**ATLAS ARMOR, INC.**  
420 SOUTH CONGRESS AVENUE, SUITE 3  
DELRAY BEACH, FLORIDA 33445  
(561) 206-0813

ATLAS ARMOR HURRICANE SCREENS  
FLORIDA BUILDING CODE SEVENTH EDITION (2020)  
MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE (NOA)

REMARKS	DATE	DRWN	CHKD
NOA # 21-0512.04	07/22/21		
NOA RENEWAL	04/05/23	EPR	RWN

COPYRIGHT ENGINEERING EXPRESS®

22-54540





SCALE: NTS UNLESS NOTED

7 OF 10

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 23-0120.02  
Expiration Date 04/15/2024  
By *H. A. Miller*  
Miami Dade Product Control

RICHARD NEET, P.E.  
PE# 86488 CA# 9885

APRIL 6, 2023

1 SCREEN BOTTOM EDGE

SUMMARY OF TEST RESULTS				
TEST STANDARDS	DESCRIPTION	TEST RESULT	MIAMI-DADE COUNTY CRITERIA	HURRICANE ENGINEERING & TESTING (HETI) #
ASTM D1929-96	SELF-IGNITION TEMPERATURE (SIT)	SIT = 751° F	ACCEPTABLE IF > 650° F	TEL-01700388C
ASTM D635	RATE OF BURNING (CC1 / C-1)	CC1/C-1 < 1.0 in/min	PASS IF < 1.0 in/min	HETI-12-F108
ASTM D635	AVERAGE TIME OF BURNING	---	---	HETI-12-F108
ASTM D635	AVERAGE EXTENT OF BURNING	---	---	HETI-12-F108
ASTM D2843-99	SMOKE DENSITY (SDR)	SDR = 10.6%	ACCEPTABLE IF < 75%	TEL-01700388B
ASTM G155-05a	ACCELERATED WEATHERING	+7.2% DIFFERENCE	ACCEPTABLE IF < 10%	HETI-12-A403

BREAKING STRENGTH & ELONGATION OF TEXTILE FABRICS				
TEST	MAX. FORCE	ELONGATION	HURRICANE ENGINEERING & TESTING (HETI) #	
ASTM D638 & ASTM D5035-11	473.0 lb/in	98.60%	HETI-12-U109	WEAK DIRECTION
ASTM D638 & ASTM D5035-11	438.8 lb/in	94.80%	HETI-12-U108	WEAK DIRECTION
ASTM D1683-AA1	231.7 lb/in	25.00%	HETI-12-T123	AT SEWN SEAMS
ASTM D5034-09	742.6 lb/in	19.60%	HETI-12-T122	STRONG DIRECTION
ASTM D5034-09	449.8 lb/in	74.60%	HETI-12-T121	WEAK DIRECTION

**ENGINEERING EXPRESS**

POSTAL ADDRESS:  
401 W. ATLANTIC AVE R10 BOX 219  
DELRAY BEACH, FL 33444  
ENGINEERINGEXPRESS.COM

**ATLAS ARMOR, INC.**  
420 SOUTH CONGRESS AVENUE, SUITE 3  
DELRAY BEACH, FLORIDA 33445  
(561) 206-0813

ATLAS ARMOR HURRICANE SCREENS  
FLORIDA BUILDING CODE SEVENTH EDITION (2020)  
MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE (NOA)

REMARKS	DATE	DRWN	CHKD
NOA # 21-0512.04	07/22/21	EPR	RWN
NOA RENEWAL	04/05/23		



PRODUCT REVISED  
as complying with the Florida Building Code  
Acceptance No. 23-0120.02  
Expiration Date 04/15/2024  
By *Healy A. Major*  
Miami Dade Product Control

COPYRIGHT ENGINEERING EXPRESS®

22-54540

SCALE: NTS UNLESS NOTED


8 OF 10



SUBSTRATE




(2) 5/16" Ø TAPCONS W/ 1 3/4" MIN. EMBED. AND 2 1/2" MIN. EDGE DISTANCE INTO MASONRY

BALL BEARING ASSEMBLY OR SIMU FREE END




PRODUCT COVER

CUSTOM HOOD / BRACKET  
WALL MOUNTED



WALL MOUNT BRACKET OPTIONS

1/4" TEKS SCREW  
(1) PER ROTOR TUBE  
3.93 in x 3.93 in 1/8" THK.  
STEEL BEARING PLATE  
WITH (4) 1/4" SMS




MOTOR ASSEMBLY

ROTOR TUBE  
8 OR 11

HOUSING ASSEMBLY DETAILS-OPTION  
NOT PART OF THIS NOA

1/8" ALUM. RIVETS OR  
#8 SS SDS

MIN. 0.040"  
ALUM. HOOD



OCTAGONAL TUBE

5" - 10"

5" - 10"

SCREEN  
WEAVE

GUIDE  
RAIL

ALTERNATE SQUARE HOUSING

**ENGINEERING EXPRESS**  
POSTAL ADDRESS:  
401 W. ATLANTIC AVE R10 BOX 219  
DELRAY BEACH, FL 33444  
ENGINEERINGEXPRESS.COM

**ATLAS ARMOR, INC.**  
420 SOUTH CONGRESS AVENUE, SUITE 3  
DELRAY BEACH, FLORIDA 33445  
(561) 206-0813

ATLAS ARMOR HURRICANE SCREENS  
FLORIDA BUILDING CODE SEVENTH EDITION (2020)  
MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE (NOA)

REMARKS	DRWN	CHKD	DATE
NOA # 21-0512.04	EPR	RWN	07/22/21
NOA RENEWAL			04/05/23

COPYRIGHT ENGINEERING EXPRESS®


22-54540

SCALE: NTS UNLESS NOTED
















PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 23-0120.02  
Expiration Date 09/14/2024  
By: *H. G. A. Miller*  
Miami Dade Product Control



OF 10



ITEM #	QTY.	PROFILE	DESCRIPTION	MATERIAL	MANUFACTURER/REMARKS
1	AS REQD.	T03A15899	SCREEN WOVEN	POLYESTER & ARAMID	0.045" THICK / TWITCHELL CORP.
2	2 EACH	-	STANDARD GUIDE RAIL	ALUM. 6063-T6	ATLAS ARMOR
3	2 EACH	-	GUIDE RAIL CAP	ALUM. 6063-T6	ATLAS ARMOR
4	1 OR 2 EACH	-	BOTTOM WEIGHT	STEEL	ATLAS ARMOR
4A	AS REQD.	-	BOTTOM WEIGHT BAR (US PATENT # 9382752)	ALUM. 6063-T6	ATLAS ARMOR
5	AS REQD.	-	ALUMINUM ANGLE	ALUM. 6063-T6	ATLAS ARMOR
6	AS REQD.	-	ALUMINUM TUBE	ALUM. 6063-T6	ATLAS ARMOR
7	AS REQD.	-	ROLLER TUBE	ALUM. 6063-T6	ATLAS ARMOR
8	AS REQD.	-	ROLLER TUBE REINFORCEMENT	ALUM. 6063-T6	ATLAS ARMOR
9	1 PER SIDE	0.325 DIA.	(3) 5/16" - BRAIDED ROPE	POLYPROPYLENE	ATLAS ARMOR
10	2 EACH	-	HEAVY DUTY GUIDE RAIL	ALUM. 6063-T6	ATLAS ARMOR
11	AS REQD.	-	ROLLER TUBE REINFORCEMENT	ALUM. 6063-T6	ATLAS ARMOR
12	AS REQD.	-	ALUMINUM TUBE	ALUM. 6063-T6	ATLAS ARMOR
13	AS REQD.	-	ALUMINUM ANGLE COVER 1" x 2" x 1/8"	ALUM. 6063-T6	ATLAS ARMOR
14	AS REQD.	-	SELF-ADJUSTING BOTTOM BLADE	ALUM. 6063-T6	ATLAS ARMOR



PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 23-0120-02  
Expiration Date 04/18/2028  
By *Hedy A. [Signature]*  
Miami Dade Product Control

**EXENGINEERING EXPRESS**  
POSTAL ADDRESS:  
401 W. ATLANTIC AVE R10 BOX 219  
DELRAY BEACH, FL 33444  
ENGINEERINGEXPRESS.COM

**ATLAS ARMOR, INC.**  
420 SOUTH CONGRESS AVENUE, SUITE 3  
DELRAY BEACH, FLORIDA 33445  
(561) 206-0813  
ATLAS ARMOR HURRICANE SCREENS  
FLORIDA BUILDING CODE SEVENTH EDITION (2020)  
MIAMI-DADE COUNTY NOTICE OF ACCEPTANCE (NOA)

REMARKS	DRWN	CHKD	DATE
NOA # 21-0512.04			07/22/21
NOA RENEWAL	EPR	RVN	04/05/23

COPYRIGHT ENGINEERING EXPRESS®  
22-54540  
SCALE: NTS UNLESS NOTED  
10 OF 10