



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Atlas Roofing Corporation**  
**2000 Riveredge Parkway**  
**Suite 800**  
**Atlanta, GA. 30328**

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Gorilla Guard Spec 30 and Gorilla Guard 30

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 18-0501.06 and consists of pages 1 through 2.  
The submitted documentation was reviewed by Jorge L. Acebo.



NOA: 23-0215.01  
Expiration Date: 06/13/28  
Approval Date: 05/18/23  
Page 1 of 2

**ROOFING COMPONENT APPROVAL**

**Category:** Roofing  
**Sub-Category:** Underlayment  
**Material:** Asphalt

**TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Gorilla Guard Spec 30	36" x 72' rolls	ASTM D 226 Type II	Fiberglass reinforced inorganic felt underlayment.
Gorilla Guard 30	36" x144.5' rolls	ASTM D 226 Type II	Fiberglass reinforced inorganic felt underlayment.

**MANUFACTURING LOCATION:**

1. Tuscaloosa, AL.

**EVIDENCE SUBMITTED:**

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials	ATL-234-02-01	ASTM D 226 Type II	05/24/18
Technologies, LLC	ATL-235-02-01	ASTM D 226 Type II	05/24/18

**INSTALLATION:**

1. Atlas Roofing Corporation’s Gorilla Guard Spec 30 and Gorilla Guard 30 and its components shall be installed in strict compliance with applicable Building Codes.
2. Gorilla Guard Spec 30 and Gorilla Guard 30 shall be installed with 4-inch head laps in a single layer fashion and a 6-inch end lap.
3. Gorilla Guard Spec 30 and Gorilla Guard 30 shall be fastened with corrosion resistant tin-caps and 12 guage 1-1/4” annular ring-shank nails, spaced 6” o.c. at the laps and two (2) staggered rows in the field spaced 12” o.c.
4. Gorilla Guard Spec 30 and Gorilla Guard 30 may be used with asphaltic shingles, wood shakes and shingles, non-structural metal roofing, quarry slate, and tile roofing when used as a mechanically attached base sheet.

**BUILDING PERMIT REQUIREMENTS:**

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

**LIMITATIONS:**

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Gorilla Guard Spec 30 and Gorilla Guard 30 shall not be left exposed for more than 30 days.
3. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
4. All packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and a yellow line in the center of the roll to identify the ASTM Standard designation or the Miami-Dade County Product Control Seal as shown below.



**END OF THIS ACCEPTANCE**



NOA: 23-0215.01  
 Expiration Date: 06/13/28  
 Approval Date: 05/18/23  
 Page 2 of 2