



MIAMI-DADE COUNTY, FLORIDA
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/building

PGT Industries, Inc.
1070 Technology Drive
North Venice, FL 34275

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series "AW-740" Aluminum Awning Window - L.M.I.

APPROVAL DOCUMENT: Drawing No. MD-AW740LM, Rev F titled "Awning Window Details - LM & SM", sheets 1 through 11 of 11, dated 08/08/12 and last revised on 08/07/23, prepared by manufacturer, signed and sealed by Anthony Lynn Miller, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises No. 23-0303.05** and consists of this page 1 and evidence pages E-1, E-2, E-3, E-4 and E-5, as well as approval document mentioned above.

The submitted documentation was reviewed by **Ishaq I. Chanda, P.E.**



Ishaq I. Chanda

NOA No. 23-0816.15
Expiration Date: April 11, 2028
Approval Date: September 07, 2023
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS NOA's

A. DRAWINGS

1. Manufacturer's die drawings and sections.
(Submitted under NOA No. 12-1218.07)
2. Drawing No. **MD-AW740LM**, titled "Awning Window Details – LM & SM", sheets 1 through 11 of 11, dated 08/08/12, with revision **D** dated 03/13/20, signed and sealed by Anthony Lynn Miller, P.E.
(Submitted under NOA No. 20-0402.07)

B. TESTS

1. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Large Missile Impact Test per FBC, TAS 201-94
5) Cyclic Wind Pressure Loading per FBC, TAS 203-94
6) Forced Entry Test, per ASTM F588 and TAS 202-94
along with marked-up drawings and installation diagram of all PGT Industries, Inc. representative units listed below and tested to qualify **Dowsil 791** and **Dowsil 983** silicones, prepared by Fenestration Testing Laboratory, Inc., Test Reports No.: **FTL-7897**, PGT PW5520 PVC Fixed Window (unit 6 in proposal), dated 09/03/14
FTL-20-2107.1, PGT SGD780 Aluminum Sliding Glass Door (unit 7 in proposal)
FTL-20-2107.2, PGT CA740 Alum. Outswing Casement Window (unit 8 in proposal)
FTL-20-2107.3, PGT PW7620A Aluminum Fixed Window (unit 9 in proposal) and
FTL-20-2107.4, PGT PW7620A Aluminum Fixed Window (unit 10 in proposal)
dated 07/13/20, all signed and sealed by Idalmis Ortega, P.E.
(Submitted under NOA No. 20-0402.07)
2. Test reports on: 1) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
2) Large Missile Impact Test per FBC, TAS 201-94
3) Cyclic Wind Pressure Loading per FBC, TAS 203-94
along with marked-up drawings and installation diagram of a PVC sliding glass door, a PVC fixed window and an aluminum sliding glass door, using: Kodispace 4SG TPS spacer system, Duraseal® spacer system, Super Spacer® NXT™ spacer system and XL Edge™ spacer system at insulated glass, prepared by Fenestration Testing Laboratory, Inc., Test Reports No. **FTL-8717**, **FTL-8968** and **FTL-8970**, dated 11/16/15, 06/07/16 and 06/02/16 respectively, all signed and sealed by Idalmis Ortega, P.E.
(Submitted under NOA No. 16-0714.23)

Ishaq I. Chanda

Ishaq I. Chanda, P.E.
Product Control Unit Supervisor
NOA No. 23-0816.15
Expiration Date: April 11, 2028
Approval Date: September 07, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS NOA's (CONTINUED)

B. TESTS (CONTINUED)

3. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Forced Entry Test, per FBC 2411.3.2.1, and TAS 202-94
5) Large Missile Impact Test per FBC, TAS 201-94
6) Cyclic Wind Pressure Loading per FBC, TAS 203-94
along with marked-up drawings and installation diagram of a series CA740P aluminum projected (awning) window, prepared by Fenestration Testing Laboratory, Inc. Test Report No. **FTL-7061**, dated 10/03/12, signed and sealed by Marlin D. Brinson, P.E.
(Submitted under NOA No. 12-1218.07)

C. CALCULATIONS

1. Anchor verification calculations and structural analysis, complying with **FBC 6th Edition (2017)**, prepared by manufacturer, dated 06/09/17 and revised and updated to the **FBC 7th Edition (2020)** on 03/25/20, signed and sealed by Anthony Lynn Miller, P.E.
(Submitted under NOA No. 20-0402.07)
2. Glazing complies with **ASTM E1300-04**

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **16-1117.01** issued to **Kuraray America, Inc.** for their "**Trosifol® Ultraclear, Clear and Color PVB Glass Interlayers**" dated 01/19/17, expiring on 07/08/19.
2. Notice of Acceptance No. **14-0916.11** issued to **Kuraray America, Inc.** for their "**Kuraray SentryGlas® (Clear and White) Glass Interlayers**" dated 06/25/15, expiring on 07/04/18.

Ishaq I. Chanda

Ishaq I. Chanda, P.E.
Product Control Unit Supervisor
NOA No. 23-0816.15
Expiration Date: April 11, 2028
Approval Date: September 07, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS NOA's (CONTINUED)
F. STATEMENTS

1. Statement letter of conformance, complying with **FBC 6th Edition (2017)** and the **FBC 7th Edition (2020)**, dated March 10, 2020, issued by manufacturer, signed and sealed by Anthony Lynn Miller, P.E.
(Submitted under NOA No. 20-0402.07)
2. Statement letter of no financial interest, dated March 10, 2020, issued by manufacturer, signed and sealed by Anthony Lynn Miller, P.E.
(Submitted under NOA No. 20-0402.07)
3. Proposal No. **19-1155 TP** issued by the Product Control Section, dated January 10, 2020, signed by Ishaq Chanda, P.E.
(Submitted under NOA No. 20-0402.07)
4. Proposal No. **16-0125** issued by the Product Control Section, dated March 09, 2016, signed by Ishaq Chanda, P.E.
(Submitted under NOA No. 16-0714.23)

G. OTHERS

1. Notice of Acceptance No. **17-0614.20**, issued to PGT Industries, Inc. for their Series "AW-740" Aluminum Awning Window - L.M.I. approved on 09/05/17 and expiring on 04/11/23.

Ishaq I. Chanda

Ishaq I. Chanda, P.E.
Product Control Unit Supervisor
NOA No. 23-0816.15
Expiration Date: April 11, 2028
Approval Date: September 07, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

2. EVIDENCE SUBMITTED under previous approval

A. DRAWINGS

1. Drawing No. **MD-AW740LM**, titled “Awning Window Details – LM & SM”, sheets 1 through 11 of 11, dated 08/08/12, with revision **E** dated 03/01/23, signed and sealed by Anthony Lynn Miller, P.E.

B. TESTS

1. None.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **20-0915.22** issued to **Kuraray America, Inc.** for their “**Trosifol® Ultraclear, Clear and Color PVB Glass Interlayers**” dated 11/19/20, expiring on 07/08/24.
2. Notice of Acceptance No. **22-1116.01** issued to **Kuraray America, Inc.** for their “**SentryGlas® (Clear and White) Glass Interlayers**” dated 12/15/22, expiring on 07/04/28.

F. STATEMENTS

1. Statement letter of conformance, complying with **FBC 7th Edition (2020)**, dated March 1, 2023, issued by manufacturer, signed and sealed by Anthony Lynn Miller, P.E.
2. Statement letter of no financial interest, dated March 1, 2023, issued by manufacturer, signed and sealed by Anthony Lynn Miller, P.E.

G. OTHERS

1. Notice of Acceptance No. **20-0402.07**, issued to PGT Industries, Inc. for their Series “**AW-740**” Aluminum Awning Window - L.M.I. approved on 08/20/20 and expiring on 04/11/23.

Ishaq I. Chanda

Ishaq I. Chanda, P.E.
Product Control Unit Supervisor
NOA No. 23-0816.15
Expiration Date: April 11, 2028
Approval Date: September 07, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

3. NEW EVIDENCE SUBMITTED

A. DRAWINGS

1. Drawing No. **MD-AW740LM**, Rev **F** titled “Awning Window Details - LM & SM”, sheets 1 through 11 of 11, dated 08/08/12 and last revised on 08/07/23, prepared by manufacturer, signed and sealed by Anthony Lynn Miller, P.E.

B. TESTS

1. None.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **20-0915.22** issued to **Kuraray America, Inc.** for their “**Trosifol® Ultraclear, Clear and Color PVB Glass Interlayers**” dated 11/19/20, expiring on 07/08/24.
2. Notice of Acceptance No. **22-1116.01** issued to **Kuraray America, Inc.** for their “**SentryGlas® (Clear and White) Glass Interlayers**” dated 12/15/22, expiring on 07/04/28.

F. STATEMENTS

1. Statement letter of conformance, complying with **FBC 8th Edition (2023)**, dated 08/07/23, issued by manufacturer, signed and sealed by Anthony Lynn Miller, P.E.

G. OTHERS

1. *This NOA revises NOA No. 23-0303.05, updates to FBC 2023, expiring 04/11/28.*

Ishaq I. Chanda

Ishaq I. Chanda, P.E.
Product Control Unit Supervisor
NOA No. 23-0816.15
Expiration Date: April 11, 2028
Approval Date: September 07, 2023

10) REFERENCES: TEST REPORTS FTL-7061, 3579, 3580, 3724;
DEWALT ULTRACON+ NOA; ELCO ULTRACON NOA;
DEWALT/ELCO CRETEFLEX NOA; ANSI/AF&PA NDS FOR WOOD
CONSTRUCTION AND ADM ALUMINUM DESIGN MANUAL.

GENERAL NOTES.....	1
ELEVATION.....	1
GLAZING DETAILS.....	1
INSTALLATION.....	2
ASSEMBLY TUBE DETAILS.....	3
ANCHOR SPECIFICATIONS.....	4
ANCHOR QUANTITIES.....	4
DESIGN PRESSURES.....	5-9
ASSEMBLY DETAILS/BOM.....	10
EXTRUSIONS/SPACER.....	11

Glass Types		Sheet #
1	5/16" Lami (1/8" An - .090" PVB - 1/8" An)	5
2	7/16" Lami (3/16" An - .090" SG - 3/16" An)	6
3	7/8" Lami. IG (1/8" An - 7/16" Air - 1/8" An - .090" PVB - 1/8" An)	7
4	7/8" Lami. IG (1/8" T - 7/16" Air - 1/8" An - .090" PVB - 1/8" An)	8
5	7/8" Lami. IG (3/16" An - 1/4" Air - 3/16" An - .090" SG - 3/16" An)	9
6	7/8" Lami. IG (3/16" T - 1/4" Air - 3/16" An - .090" SG - 3/16" An)	9


"PVB"= TROSIFOL[®] PVB BY KURARAY AMERICA, INC.
 "SG"= SENTRYGLAS[®] BY KURARAY AMERICA, INC.

- 2023 FLORIDA BUILDING CODE (FBC), 8TH EDITION
- 2020 FLORIDA BUILDING CODE (FBC), 7TH EDITION
- ASTM E1300-09
- ANSI/AF&PA NDS-2018 FOR WOOD CONSTRUCTION
- ALUMINUM DESIGN MANUAL, ADM-2020
- AISI S100-16
- AISC 360-16



 Custom Windows and Doors			PREPARED BY K. LYNN MILLER 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275			
1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600			(941) 480-1600			
			REGISTRATION #29296			
Title	AWNING WINDOW (LM)				Date	8/8/12
Desc.	GENERAL NOTES & ELEVATION			Drawn By	JENS ROSOWSKI	
Rev	UPDATE TO FBC 2023-AM				Rev Date	08/04/23
Series	AW-740	Sheet	1 OF 11	DWG No.	MD-AW740LM	Rev. F

Miami-Dade Product Control




INSTALLATION

OPTION 1

INSTALLATION ANCHORS
INTO 2X WOOD.

AS REQUIRED PER
TABLE 3, SHEET 4




INSTALLATION OPTION 3
INSTALLATION ANCHORS THROUGH
1X BUCKSTRIP INTO MASONRY.

VERTICAL SECTION B-B

INSTALLATION

OPTION 2

INSTALLATION ANCHORS
DIRECTLY INTO MASONRY.





NOTES:


1) USE ONLY SUBSTRATE-APPROPRIATE ANCHORS LISTED ON TABLE 3, SHEET 4. FOLLOW EMBEDMENT AND EDGE DISTANCE LIMITS. ANY INSTALLATION OPTION SHOWN MAY BE USED ON ANY SIDE OF THE WINDOW.

2) ALL WOOD BUCKS LESS THAN 1-1/2" THICK ARE TO BE CONSIDERED 1X INSTALLATIONS. 1X WOOD BUCKS ARE OPTIONAL. UNIT MAY BE INSTALLED DIRECTLY TO SUBSTRATE. WOOD BUCKS DEPICTED AS 2X ARE 1-1/2" THICK OR GREATER. 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED TO PROPERLY TRANSFER LOADS TO THE STRUCTURE. WOOD BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD. MAXIMUM SHIM THICKNESS TO BE 1/4".


SEE DETAIL
A1, BELOW



HORIZONTAL SECTION A-A



SEE DETAIL A2, BELOW




DETAIL
A2

INSTALLATION

OPTION 4

INSTALLATION ANCHORS
DIRECTLY INTO METAL.



NOTES:

1) WHEN INSTALLING COMBINATION UNITS, ADDITIONAL INSTALLATION ANCHORS MAY NEED TO BE INSTALLED THROUGH THE WINDOW FRAMES AT 10" MAX. FROM EACH SIDE OF THE FRAME ASSEMBLY TUBE CENTERLINE. SEE TABLE BELOW:

Additional Anchors Required on each Side of the Frame Assembly Tube (FAT)			
Vert. FAT	Window Width	Anchor Type	
		A	B, C & D
	17" - 25.9"	1	0
	26"+	1	1
Horiz. FAT	Window Height	Anchor Type	
		A	B, C & D
	17" - 25.9"	1	0
	26"+	1	1


VISIBLE LIGHT FORMULAS
WIDTH: WINDOW WIDTH - 7
HEIGHT: WINDOW HEIGHT - 7

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0816.15

Expiration Date 04/11/2028


By *Ishag I. Chank*
Miami-Dade Product Control

PGT Custom Windows and Doors		PREPARED BY A. LYNN MILLER 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600	
1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600		REGISTRATION #29296	
Series	AW-740	Sheet	2 OF 11
Rev	NO CHANGES IN THIS SHEET - AM		Date 08/04/23
Desc.	GENERAL NOTES & ELEVATION		Drawn By JENS ROSOWSKI
Title	AWNING WINDOW (LM)		Date 8/8/12
Rev	NO CHANGES IN THIS SHEET - AM		Date 08/04/23
Series	AW-740	Sheet	2 OF 11
DWG No.	MD-AW740LM		Rev. F



A. LYNN MILLER, P.E.
P.E.# 58705



AWNING (X)



FOR SINGLE UNITS:

- 1) DETERMINE YOUR WINDOW SIZE AND GLASS.
- 2) KNOWING YOUR ANCHOR TYPE AND SUBSTRATE, DETERMINE YOUR ANCHOR GROUP FROM TABLE 3, SHEET 4.
- 3) FROM SHEETS 5-9, FIND THE SHEET FOR YOUR GLASS TYPE. FIND THE PRODUCT'S DESIGN PRESSURE FROM THE TABLE LABELED "DESIGN PRESSURE (PSF) FOR SINGLE WINDOWS, ALL ANCHOR GROUPS".
- 4) DIMENSIONS SHOWN ARE WINDOW. FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE WIDTH OR HEIGHT DIMENSION SHOWN ON THE TABLES.
- 5) USING THE TABLE LABELED "WINDOW ANCHORS REQUIRED" (TABLE 2, SHEET 4), DETERMINE THE NUMBER OF ANCHORS NEEDED IN THE HEAD, SILL AND JAMBS OF YOUR WINDOW.
- 6) INSTALL AS PER THE INSTRUCTIONS ON SHEET 2.


AWNING / AWNING (XX)




FOR EACH WINDOW IN A VERTICALLY OR HORIZONTALLY COMBINED ASSEMBLY:

- 1) DETERMINE EACH INDIVIDUAL WINDOW TYPE, SIZE AND GLASS MAKEUP, SEE FIGURES 1 & 2, THIS SHEET. DETERMINE YOUR ANCHOR GROUP FROM TABLE 3, SHEET 4.
- 2) FROM SHEETS 5-9, FIND THE SHEET FOR YOUR GLASS TYPE.
- 3) FIND THE DESIGN PRESSURE FROM THE TABLES LABELED "DESIGN PRESSURE (PSF) FOR WINDOWS ATTACHED TO A VERTICAL FRAME ASSEMBLY TUBE" OR "DESIGN PRESSURE (PSF) FOR WINDOWS ATTACHED TO A HORIZONTAL FRAME ASSEMBLY TUBE", DEPENDING ON WHICH WAY THE FRAME ASSEMBLY TUBE IS ORIENTATED. THIS MUST BE DONE FOR EACH WINDOW IN THE ASSEMBLY, AND THE LOWEST DESIGN PRESSURE APPLIES TO THE ENTIRE ASSEMBLY. DIMENSIONS SHOWN ARE WINDOW. FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE WIDTH OR HEIGHT DIMENSION SHOWN ON THE TABLES.
- 4) USING THE TABLE LABELED "WINDOW ANCHORS REQUIRED" (TABLE 2, SHEET 4), DETERMINE THE NUMBER OF ANCHORS NEEDED IN THE HEAD, SILL AND JAMBS OF YOUR WINDOW.
- 5) INSTALL AS PER THE INSTRUCTIONS ON SHEETS 2-3. NOTE THAT ADDITIONAL ANCHORS THROUGH THE WINDOW FRAME INTO THE SUBSTRATE MAY BE REQUIRED (SEE SHEET 2), AND THAT MIN. # 12 X 1" ANCHORS ARE TO BE USED THROUGH THE FRAME INTO THE FRAME ASSEMBLY TUBE (SEE DETAILS ON THIS SHEET).


AWNING / CASEMENT / FIXED CASEMENT (XXO)



*SEE PRODUCT'S NOA FOR INSTALLATION SPECS



VERTICAL SECTION D-D



VERTICAL SECTION E-E

FRAME ASSEMBLY TUBE NOTES:

- 1) DIMENSIONS SHOWN ARE WINDOW DIMENSIONS FOR EACH INDIVIDUAL WINDOW. FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE WIDTH OR HEIGHT DIMENSION SHOWN ON THE TABLES.
- 2) ANY 740-SERIES PRODUCT (CASEMENT, AWNING OR FIXED CASEMENT) MAY BE ATTACHED TO THE FRAME ASSEMBLY TUBE. FOR ALL WINDOWS, USE THE WINDOW'S NOA FOR ANCHORAGE, SIZE AND DESIGN PRESSURE LIMITATIONS.
- 3) ALL WINDOWS IN THE COMBINATION UNIT MUST BE ABLE TO INDIVIDUALLY COMPLY WITH THE REQUIREMENTS OF THEIR RESPECTIVE NOA.
- 4) FRAME ASSEMBLY TUBE TO BE FASTENED TO WINDOW, AS SHOW IN DETAILS, WITH MIN. #12 X 1" SHEET METAL SCREWS. USE THE SAME SPACING AND QUANTITY AS THE OPPOSITE FRAME MEMBER.
- 5) THE FRAME ASSEMBLY TUBE MAY NOT EXCEED 62" IN LENGTH (AS USED IN A 63" FLANGED WINDOW) OR BE USED IN TEE OR CROSS CONFIGURATIONS.
- 6) THE FRAME ASSEMBLY TUBE IS NOT REQUIRED TO BE CLIPPED TO THE SUBSTRATE. ALL EXTERIOR JOINTS TO BE SEALED BY INSTALLER.
- 7) FOR ALL COMBINATION UNITS, ADDITIONAL INSTALLATION ANCHORS MAY NEED TO BE INSTALLED THROUGH THE WINDOW FRAMES AT 10" MAX. FROM EACH SIDE OF THE FRAME ASSEMBLY TUBE CENTERLINE. SEE TABLE BELOW:

Additional Anchors Required on each Side of the Frame Assembly Tube (FAT)			
Vert. FAT	Window Width	Anchor Type	
	17" - 25.9"	A	B, C & D
	26"+	1	0
Horiz. FAT	Window Height	Anchor Type	
	17" - 25.9"	A	B, C & D
	26"+	1	1

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0816.15
Expiration Date 04/11/2028
By *Ishaq I. Chande*
Miami-Dade Product Control

Revision: F) NO CHANGES IN THIS SHEET. AM

 Custom Windows and Doors 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600		REGISTRATION #29296					
		AWNING WINDOW (LM)		Date	08/08/12		
		FRAME ASSEMBLY TUBE DETAILS		Drawn By	JENS ROSOWSKI		
		series	AW-740	Sheet	3 OF 11	DWG No.	MD-AW740LM




TABLE 2:

			Window Anchors Required																																							
			Window Width (in)																																							
			under 23"				25-15/16"				27-7/8"				30-3/4"				32"				34"				37"				46"				53-1/8"				60"			
			Anchor Group				Anchor Group				Anchor Group				Anchor Group				Anchor Group				Anchor Group				Anchor Group				Anchor Group				Anchor Group							
			A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D				
Window Height (in)	under 23"	Jamb	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2				
		Head/Sill	2	2	2	2	4	2	2	2	4	2	2	2	4	4	4	4	4	4	4	4	4	4	6	4	4	4	6	4	4	4	8	6	4	4	8	6	6	4		
	25-15/16"	Jamb	3	2	2	2	3	2	2	2	3	2	2	2	3	2	2	2	3	2	2	2	3	2	2	2	3	2	2	2	3	2	2	2	3	2	2	2	2			
		Head/Sill	2	2	2	2	4	2	2	2	4	2	2	2	4	4	4	4	4	4	4	4	4	4	6	4	4	4	8	4	4	4	8	6	4	4	10	6	6	4		
	39"	Jamb	5	3	3	2	5	3	3	2	5	4	3	2	6	4	3	2	6	4	3	2	6	4	3	2	6	4	3	2	5	4	3	2	5	3	3	2	2			
		Head/Sill	2	2	2	2	4	2	2	2	4	2	2	2	4	4	4	4	4	4	4	4	6	4	4	4	6	4	4	4	8	6	4	4	10	6	6	4				
	50-5/8"	Jamb	7	4	4	4	7	5	4	4	8	5	4	4	8	5	4	4	8	5	5	4	9	6	5	4	9	6	5	4	9	6	5	4								
		Head/Sill	2	2	2	2	4	2	2	2	4	2	2	2	4	4	4	4	4	4	4	4	6	4	4	4	6	4	4	4	8	6	4	4								
	60"	Jamb	8	5	5	4	9	6	5	4	10	6	5	4	10	7	6	4	10	7	6	4	10	7	6	4	10	7	6	4												
		Head/Sill	2	2	2	2	4	2	2	2	4	2	2	2	4	4	4	4	4	4	4	4	4	4	4	4	6	4	4	4												
	63"	Jamb	9	6	5	4	10	6	5	4	10	7	6	4	11	7	6	4	11	7	6	4	11	7	6	4	11	7	6	4												
		Head/Sill	2	2	2	2	4	2	2	2	4	2	2	2	4	4	4	4	4	4	4	4	4	4	4	4	6	4	4	4												
	67"	Jamb	10	6	5	4	10	7	6	4	11	7	6	4	11	7	6	4	11	7	6	4	11	7	6	4																
		Head/Sill	2	2	2	2	4	2	2	2	4	2	2	2	4	4	4	4	4	4	4	4	4	4	4	4																
	72"	Jamb	10	7	6	5	11	7	6	5	12	8	6	5	12	8	7	5	12	8	7	5																				
		Head/Sill	2	2	2	2	4	2	2	2	4	2	2	2	4	4	4	4	4	4	4	4	4	4	4																	
76"	Jamb	11	7	6	5	12	8	7	5	13	8	7	5	13	8	7	5																									
	Head/Sill	2	2	2	2	4	2	2	2	4	2	2	2	4	4	4	4																									
84"	Jamb	12	8	7	5	14	9	7	5	14	9	8	5																													
	Head/Sill	2	2	2	2	4	2	2	2	4	2	2	2																													

USE THIS TABLE FOR ALL WINDOWS PER THE ELEVATIONS ON SHEET 1. DIMENSIONS SHOWN ARE WINDOW TIP-TO-TIP. FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE WIDTH OR HEIGHT DIMENSION SHOWN ON THE TABLE.

TABLE 3:

Group	Anchor	Substrate	Min. Edge Distance	Min. O.C. Distance	Min. Embedment	Anchor Plate Required?
A	#12 steel SMS (G5) or #14 steel SMS (G5) or #14 410 SS SMS	S. Pine	5/8"	1"	1-3/8"	No
		6063-T5 Alum.	3/8"	5/8"	.063"	No
		A36 Steel	3/8"	5/8"	.050"	No
		A653 Stud, Gr. 33	3/8"	5/8"	.045", 20 Ga.	No
	1/4" steel Ultracon+	3k Concrete	1"	3"	1-3/4"	No
		Hollow Block	1"	3"	1-1/4"	No
B	1/4" steel Ultracon	S. Pine	1"	1"	1-3/8"	No
		2.85k Concrete	2-1/2"	4"	1-3/8"	No
		Hollow Block	1"	6"	1-1/4"	No
		Hollow Block	2-1/2"	5"	1-1/4"	No
C	1/4" steel Ultracon+	3k Concrete	1"	4"	1-3/8"	Yes
		Hollow Block	1"	3"	1-1/4"	Yes
	1/4" 410 SS CreteFlex	3.35k Concrete	1"	5"	1-3/4"	No
		Hollow Block	2-1/2"	5"	1-1/4"	No
D	#12 steel SMS (G5) or #12 410 SS SMS or #14 steel SMS (G5) or #14 410 SS SMS	S. Pine	5/8"	1"	1-3/8"	Yes
		6063-T5 Alum.	3/8"	5/8"	.0713"	Yes
		A36 Steel	3/8"	5/8"	.050"	Yes
		A653 Stud, Gr. 33	3/8"	5/8"	.045", 18 Ga.	Yes
		3.35k Concrete	1"	6"	1-3/4"	Yes
		Hollow Block	2-1/2"	6"	1"	Yes
	1/4" 410 SS CreteFlex	3.35k Concrete	2-1/2"	6"	1"	Yes
		Hollow Block	2-1/2"	6"	1-1/4"	Yes
		3.5k Concrete	1-1/4"	5"	1-3/4"	No
	5/16" steel Ultracon	Hollow Block	3-1/8"	5"	1-1/4"	No
		Filled Block	2-1/2"	5"	1-3/4"	No
		3k Concrete	1-5/16"	4"	1-3/8"	Yes
	1/4" steel Ultracon+	Hollow Block	1-3/4"	3"	1-1/4"	Yes
		S. Pine	1"	1"	1-3/8"	Yes

- 1) WHERE SUBSTRATE CONDITIONS REQUIRE ANCHORAGE FROM MORE THAN ONE OF THE ANCHOR GROUPS ABOVE, CHOOSE THE ANCHOR GROUP OF THE LOWEST LETTER FOR ALL SUBSEQUENT TABLES IN THIS APPROVAL.
- 2) ANCHOR MUST EXTEND A MINIMUM OF 3 THREADS BEYOND ANY METAL SUBSTRATE.
- 3) ANCHORS MAY BE HEXHEAD, PANHEAD OR FLATHEAD. ALL ANCHOR HEAD TYPES ACCEPTABLE
- 4) FOR STEEL STUDS, MIN. FU = 45 KSI, MIN FY = 33 KSI.

EXAMPLE 1: FOR WINDOW COMBINATION SHOWN BELOW; 7/16" ANNEALED LAMINATED GLASS, 1/4" MASONRY ANCHORS INTO CONCRETE, +70/-70 PSF DP REQUIRED

AWNING ANCHORS:

A) FROM TABLE 9, ANCHORS C & D ALLOW A DP OF +70/-90.

B) FOR THE JAMB, FROM TABLE 3, ANCHORS IN GROUP C HAVE THE ANCHOR AND SUBSTRATE DESIRED AND DOES NOT REQUIRE THE ANCHOR PLATE IF USING THE CRETEFLEX ANCHOR.

C) FROM TABLE 2, 6 ANCHORS ARE REQUIRED IN EACH JAMB.

C) SIMILARLY, 2 ANCHORS ARE REQUIRED IN THE HEAD & SILL.

D) DISTRIBUTE ANCHORS FOLLOWING GUIDELINES FROM ELEVATION ON SHEET 1.

E) PER RULES ON SHEETS 2 & 3, INSTALL 1 ADDITIONAL ANCHOR ON THE FRAME ASSEMBLY TUBE SIDE OF THE AWNING (HEAD & SILL).

FIXED CASEMENT ANCHORS:

A) FROM TABLE 9, A 34" X 61" FIXED CASEMENT WINDOW HAS A DESIGN PRESSURE EXCEEDING THE REQUIREMENT OF +70/-70 USING ANCHORS C OR D.

B) FOR THE JAMB, FROM TABLE 3, ANCHOR TYPE C HAS THE ANCHOR AND SUBSTRATE DESIRED AND DOES NOT REQUIRE THE ANCHOR PLATE IF USING THE CRETEFLEX ANCHOR.

C) FROM TABLE 2A, 6 ANCHORS ARE REQUIRED IN EACH JAMB.

D) SIMILARLY, 3 ANCHORS ARE REQUIRED IN THE HEAD & SILL.

E) DISTRIBUTE ANCHORS FOLLOWING GUIDELINES FROM ELEVATION ON SHEET 1.



F) PER RULES ON SHEET 2, INSTALL 1 ADDITIONAL ANCHOR ON THE FRAME ASSEMBLY TUBE SIDE OF THE FIXED CASEMENT (HEAD & SILL).

Material	Min. F _y	Min. F _u
Steel Screw	92 ksi	120 ksi
410 Screw	90 ksi	110 ksi
Elco UltraCon®	155 ksi	177 ksi
1/4" DeWalt UltraCon+®	148 ksi	164 ksi
410 SS DeWalt/Elco CreteFlex®	127.4 ksi	189.7 ksi
6063-T5 Aluminum	16 ksi	22 ksi
A36 Steel	36 ksi	58 ksi
Gr. 33 Steel Stud	33 ksi	45 ksi

TABLE 4:

Head Snubber Locations	
Glass Type:	
PVB (Types 1, 3 & 4)	SG (Types 2, 5 & 6)
None Required	20" max. from each end & 20" max O.C.

SAMPLE CONFIGURATIONS:



PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. 23-0816.15
Expiration Date 04/11/2028
By *Ishag I. Chank*
Miami-Dade Product Control

Revision: F) REMOVED ULTRACON FROM ANCHOR TABLES.

PREPARED BY A. LYNN MILLER 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600	REGISTRATION #29296	08/08/12	JENS ROSOWSKI	MD-AW740LM	F
PGI Custom Windows and Doors 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600	AWNING WINDOW (LM)	ANCHOR TYPE & QUANTITY	AW-740	4 OF 11	Sheet





TABLE 5:

		Design Pressure (psf) for Single Windows, All Anchor Groups									
		Window Width									
		under 23"	25-15/16"	27-7/8"	30-3/4"	32"	34"	37"	46"	53-1/8"	60"
Window Height	under 23"	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90
	25-15/16"	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90
	39"	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/-81.1	+70/-71.2
	50-5/8"	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/-89.2	+70/-77.9		
	60"	+70/- 90	+70/- 90	+70/- 90	+70/-86.5	+70/-83.7	+70/-79.6	+70/-74.3			
	63"	+70/- 90	+70/- 90	+70/- 90	+70/-82.3	+70/-79.4	+70/-75.6	+70/- 70.1			
	67"	+70/- 90	+70/- 90	+70/- 83.5	+70/- 76.3	+70/- 73.4	+/- 69.4				
	72"	+70/- 90	+70/-87.2	+70/- 77.4	+/- 69.3	+/- 65.4					
	76"	+70/- 90	+70/- 84.6	+70/- 75.2	+/- 65						
	84"	+70/- 90	+70/- 80.4	+70/- 70.8							




FOR GLASS TYPES:
1) 5/16" LAMI (1/8 AN - .090" PVB - 1/8 AN)

"PVB"= TROSIFOL® PVB BY KURARAY AMERICA, INC.

SEE SHEETS 1
& 4 FOR
WINDOW
ANCHOR
LOCATIONS
AND
QUANTITIES.

TABLE 6:


		Design Pressure (psf) for Windows Attached to a Vertical Frame Assembly Tube																						
		Window Width																						
		under 23"				25-15/16"			27-7/8"			30-3/4"		32"		34"		37"		46"		53-1/8"	60"	
		Anchor Group				Anchor Group			Anchor Group			Anchor Group		Anchor Group		Anchor Group		Anchor Group		Anchor Group		Anchor Group	Anchor Group	
		A	B	C	D	A	B	C & D	A	B	C & D	A	B, C & D	A	B, C & D	A	B, C & D	A	B, C & D	A	B, C & D	All	All	
Window Height	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	39"	+70/-90	+70/-75.2	+70/-89.9	+70/-90	+70/-83.1	+70/-90	+70/-90	+70/-77.4	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.4	+70/-90	+70/-90	+70/-90	+70/-90	+70/-81.1	+70/-71.2
	50-5/8"	+70/-72.3	+/-57.9	+/-69.3	+70/-90	+/-64	+70/-90	+70/-90	+/-59.6	+70/-90	+70/-90	+70/-81	+70/-90	+70/-77.9	+70/-90	+70/-73.3	+70/-90	+/-67.3	+70/-89.2	+/-54.2	+70/-77.9			
	60"	+/-61	+/-48.9	+/-58.5	+70/-90	+/-54	+70/-86.6	+70/-90	+/-50.3	+70/-80.6	+70/-90	+/-68.4	+70/-86.5	+/-65.7	+70/-83.7	+/-61.8	+70/-79.6	+/-56.8	+70/-74.3					
	63"	+/-58.1	+/-46.5	+/-55.7	+70/-88.7	+/-51.5	+70/-82.5	+70/-90	+/-47.9	+70/-76.8	+70/-90	+/-65.1	+70/-82.3	+/-62.6	+70/-79.4	+/-58.9	+70/-75.6	+/-54.1	+70/-70.1					



SEE SHEETS 1 & 4 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

TABLE 7:

		Design Pressure (psf) for Windows Attached to a Horizontal Frame Assembly Tube																						
		Window Width																						
		under 23"	25-15/16"	27-7/8"	30-3/4"	32"	34"			37"			46"				53-1/8"				60"			
		Anchor Group	Anchor Group	Anchor Group	Anchor Group	Anchor Group	Anchor Group			Anchor Group			Anchor Group				Anchor Group				Anchor Group			
		All	All	All	All	All	A	B	C & D	A	B	C & D	A	B	C	D	A	B	C	D	A	B	C	D
Window Height	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-86.2	+70/-90	+70/-90	+70/-79.2	+70/-90	+70/-79.5	+/-63.7	+70/-76.3	+70/-90	+/-68.9	+/-55.2	+/-66	+70/-90	+/-61	+/-48.9	+/-58.5	+70/-90
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.6	+70/-90	+70/-90	+70/-70.5	+70/-90	+70/-90	+70/-90	+/-61	+70/-90	+70/-90	+70/-90	+/-54	+70/-86.6	+70/-90	+70/-90
	39"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.4	+70/-90	+70/-90	+70/-70.3	+70/-75.1	+70/-89.9	+70/-90	+/-50.7	+/-65.1	+70/-77.8	+70/-81.1	+/-44.9	+/-57.6	+/-68.9	+70/-71.2
	50-5/8"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-85.5	+70/-90	+70/-90	+70/-78.6	+70/-89.2	+70/-89.2	+/-63.2	+70/-77.9	+70/-77.9	+70/-77.9								
	60"	+70/-90	+70/-90	+70/-90	+70/-86.5	+70/-83.7	+70/-79.6	+70/-79.6	+70/-79.6	+70/-74.3	+70/-74.3	+70/-74.3												
	63"	+70/-90	+70/-90	+70/-90	+70/-82.3	+70/-79.4	+70/-75.6	+70/-75.6	+70/-75.6	+70/-70.1	+70/-70.1	+70/-70.1												
	67"	+70/-90	+70/-90	+70/-83.5	+70/-76.3	+70/-73.4	+/-69.4	+/-69.4	+/-69.4															
	72"	+70/-90	+70/-87.2	+70/-77.4	+/-69.3	+/-65.4																		
	76"	+70/-90	+70/-84.6	+70/-75.2	+/-65																			
84"	+70/-90	+70/-80.4	+70/-70.8																					



SEE SHEETS 1 & 4 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

- NOTES:
1) SEE SHEET 4 FOR ADDITIONAL SAMPLE CONFIGURATIONS.
2) SEE SHEET 4 FOR SNUBBER REQUIREMENTS.

PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. 23-0816.15
Expiration Date 04/11/2028
By *Ishay I. Chandra*
Miami-Dade Product Control

Revision: F) NO CHANGES IN THIS SHEET.

PREPARED BY A. LYNN MILLER
1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941) 480-1600

REGISTRATION #29296

08/08/12

JENS ROSOWSKI

MD-AW740LM

F

AWNING WINDOW (LM)

DESIGN PRESSURES PER GLAZING TYPES

AW-740

5 OF 11


PGI
Custom Windows and Doors

1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941) 480-1600

ANTHONY LYNN MILLER
LICENSE
No. 58705
08/07/23
STATE OF FLORIDA
PROFESSIONAL ENGINEER
A. LYNN MILLER, P.E.
P.E.# 58705

TABLE 8:

Design Pressure (psf) for Single Windows, All Anchor Groups										
	Window Width									
	under 23"	25-15/16"	27-7/8"	30-3/4"	32"	34"	37"	46"	53-1/8"	60"
	under 23"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
Window Height	25-15/16"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
	39"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-128.8
	50-5/8"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130		
	60"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130			
	63"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-129.6			
	67"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130				
	72"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130				
	76"	+90/-130	+90/-130	+90/-130	+90/-130					
	84"	+90/-130	+90/-130	+90/-130						




FOR GLASS TYPES:
2) 7/16" LAMI (3/16" AN - .090" SG - 3/16" AN)

"SG"= SENTRYGLAS®BY KURARAY AMERICA, INC.

SEE SHEETS 1
& 4 FOR
WINDOW
ANCHOR
LOCATIONS
AND
QUANTITIES.

TABLE 9:


		Design Pressure (psf) for Windows Attached to a Vertical Frame Assembly Tube																						
		Window Width																						
		under 23"				25-15/16"			27-7/8"			30-3/4"		32"		34"		37"			46"	53-1/8"	60"	
		Anchor Group				Anchor Group			Anchor Group			Anchor Group		Anchor Group		Anchor Group		Anchor Group			Anchor Group	Anchor Group	Anchor Group	
		A	B	C	D	A	B	C & D	A	B	C & D	A	B, C & D	A	B, C & D	A	B, C & D	A	B	C & D	All	All	All	
Window Height	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	39"	+70/-90	+70/-75.2	+70/-89.9	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	50-5/8"	+70/-72.3	+/-57.9	+/-69.3	+70/-90	+70/-90	+70/-90	+70/-90	+70/-89.4	+70/-90	+70/-90	+70/-81	+70/-90	+70/-77.9	+70/-90	+70/-73.3	+70/-90	+70/-89.8	+70/-90	+70/-90	+70/-90			
	60"	+/-61	+/-48.9	+/-58.5	+70/-90	+70/-81.1	+70/-86.6	+70/-90	+70/-75.5	+70/-80.6	+70/-90	+/-68.4	+70/-90	+/-65.7	+70/-90	+/-61.8	+70/-90	+70/-75.8	+70/-90	+70/-90				
	63"	+/-58.1	+/-46.5	+/-55.7	+70/-88.7	+70/-77.2	+70/-82.5	+70/-90	+70/-71.9	+70/-76.8	+70/-90	+/-65.1	+70/-90	+/-62.6	+70/-90	+/-58.9	+70/-90	+70/-72.2	+70/-86.7	+70/-90				



SEE SHEETS 1 & 4
FOR WINDOW
ANCHOR
LOCATIONS AND
QUANTITIES. SEE
SHEET 3 FOR ANY
ADDITIONAL
ANCHORS
REQUIRED FOR
THE FRAME
ASSEMBLY TUBE.

TABLE 10:

		Design Pressure (psf) for Windows Attached to a Horizontal Frame Assembly Tube																						
		Window Width																						
		under 23"	25-15/16"	27-7/8"	30-3/4"	32"	34"			37"			46"				53-1/8"				60"			
		Anchor Group	Anchor Group	Anchor Group	Anchor Group	Anchor Group	Anchor Group			Anchor Group			Anchor Group				Anchor Group				Anchor Group			
		All	All	All	All	All	A	B	C & D	A	B	C & D	A	B	C	D	A	B	C	D	A	B	C	D
Window Height	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-86.2	+70/-90	+70/-90	+70/-79.2	+70/-90	+70/-79.5	+/-63.7	+70/-76.3	+70/-90	+/-68.9	+/-55.2	+/-66	+70/-90	+/-61	+/-48.9	+/-58.5	+70/-90
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-88.1	+70/-90	+70/-90	+70/-90	+70/-76.3	+70/-90	+70/-90	+70/-90	+/-67.5	+70/-86.6	+70/-90	+70/-90
	39"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-82	+70/-90	+70/-90	+70/-90	+70/-71	+70/-81.3	+70/-90	+70/-90	+/-62.9	+70/-72	+70/-86.2	+70/-90
	50-5/8"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90								
	60"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90												
	63"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90												
	67"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90															
	72"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90																		
	76"	+70/-90	+70/-90	+70/-90	+70/-90																			
84"	+70/-90	+70/-90	+70/-90																					



SEE SHEETS 1 & 4 FOR WINDOW ANCHOR
LOCATIONS AND QUANTITIES. SEE SHEET
3 FOR ANY ADDITIONAL ANCHORS
REQUIRED FOR THE FRAME ASSEMBLY
TUBE.

NOTES:
1) SEE SHEET 4 FOR ADDITIONAL SAMPLE CONFIGURATIONS.
2) SEE SHEET 4 FOR SNUBBER REQUIREMENTS.

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0816.15
Expiration Date04/11/2028
By *Ismael L. Chando*
Miami-Dade Product Control

Revision:
F) NO CHANGES IN
THIS SHEET.

PREPARED BY A. LYNN MILLER
1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941) 480-1600

REGISTRATION #29296

08/08/12
Date

JENS ROSOWSKI
By

MD-AW740LM
DWG No.

6 OF 11
Sheet

AW-740
Title

PGI
Custom Windows and Doors
1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941) 480-1600

AWNING WINDOW (LM)
DESIGN PRESSURES PER
GLAZING TYPES

ANTHONY LYNN MILLER
LICENSE
No. 58705
08/07/23
STATE OF
FLORIDA
PROFESSIONAL ENGINEER
A. LYNN MILLER, P.E.
P.E.# 58705


TABLE 11:

		Design Pressure (psf) for Single Windows, All Anchor Groups									
		Window Width									
		under 23"	25-15/16"	27-7/8"	30-3/4"	32"	34"	37"	46"	53-1/8"	60"
Window Height	under 23"	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90
	25-15/16"	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90
	39"	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/-83.2	+70/-73.1
	50-5/8"	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 90	+70/- 80		
	60"	+70/- 90	+70/- 90	+70/- 90	+70/-88.8	+70/-85.8	+70/-81.7	+70/-76.2			
	63"	+70/- 90	+70/- 90	+70/- 90	+70/-84.4	+70/-81.5	+70/-77.5	+70/-71.9			
	67"	+70/- 90	+70/- 90	+70/-85.6	+70/-78.3	+70/- 75.3	+70/- 71.2				
	72"	+70/- 90	+70/-89.5	+70/- 79.4	+70/- 71.1	+/- 67.1					
	76"	+70/- 90	+70/-86.8	+70/- 77.2	+/- 66.6						
	84"	+70/- 90	+70/- 82.5	+70/- 72.7							

FOR GLASS TYPES:

3) 7/8" LAMI. IG: (1/8" AN - 7/16" AIR - 1/8" AN - .090" PVB - 1/8" AN)


"PVB"= TROSIFOL® PVB BY KURARAY AMERICA, INC.



SEE SHEETS 1 & 4 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES.

TABLE 12:

		Design Pressure (psf) for Windows Attached to a Vertical Frame Assembly Tube																							
		Window Width																							
		under 23"				25-15/16"			27-7/8"			30-3/4"		32"		34"		37"		46"		53-1/8"		60"	
Window Height		Anchor Group				Anchor Group			Anchor Group			Anchor Group		Anchor Group		Anchor Group		Anchor Group		Anchor Group		Anchor Group		Anchor Group	
		A	B	C	D	A	B	C & D	A	B	C & D	A	B, C & D	A	B, C & D	A	B, C & D	A	B, C & D	A	B, C & D	A	B, C & D	A	B, C & D
	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90
	39"	+70/-90	+70/-75.2	+70/-89.9	+70/-90	+70/-83.1	+70/-90	+70/-90	+70/-77.4	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-81.2	+70/-83.2	+70/-71.9	+70/-73.1
	50-5/8"	+70/-72.3	+/-57.9	+/-69.3	+70/-90	+/-64	+70/-90	+70/-90	+/-59.6	+70/-90	+70/-90	+70/-81	+70/-90	+70/-77.9	+70/-90	+70/-73.3	+70/-90	+/-67.3	+70/-90	+/-54.2	+70/-80				
	60"	+/-61	+/-48.9	+/-58.5	+70/-90	+/-54	+70/-86.6	+70/-90	+/-50.3	+70/-80.6	+70/-90	+/-68.4	+70/-88.8	+/-65.7	+70/-85.8	+/-61.8	+70/-81.7	+/-56.8	+70/-76.2						
	63"	+/-58.1	+/-46.5	+/-55.7	+70/-88.7	+/-51.5	+70/-82.5	+70/-90	+/-47.9	+70/-76.8	+70/-90	+/-65.1	+70/-84.4	+/-62.6	+70/-81.5	+/-58.9	+70/-77.5	+/-54.1	+70/-71.9						



SEE SHEETS 1 & 4 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

TABLE 13:

		Design Pressure (psf) for Windows Attached to a Horizontal Frame Assembly Tube																						
		Window Width																						
		under 23"	25-15/16"	27-7/8"	30-3/4"	32"	34"			37"			46"				53-1/8"				60"			
Window Height		Anchor Group	Anchor Group	Anchor Group	Anchor Group	Anchor Group	Anchor Group			Anchor Group			Anchor Group				Anchor Group				Anchor Group			
		All	All	All	All	All	A	B	C & D	A	B	C & D	A	B	C	D	A	B	C	D	A	B	C	D
	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-86.2	+70/-90	+70/-90	+70/-79.2	+70/-90	+70/-79.5	+/-63.7	+70/-76.3	+70/-90	+/-68.9	+/-55.2	+/-66	+70/-90	+/-61	+/-48.9	+/-58.5	+70/-90
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.6	+70/-90	+70/-90	+70/-70.5	+70/-90	+70/-90	+70/-90	+/-61	+70/-90	+70/-90	+70/-90	+/-54	+70/-86.6	+70/-90	+70/-90
	39"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.4	+70/-90	+70/-90	+70/-70.3	+70/-75.1	+70/-89.9	+70/-90	+/-50.7	+/-65.1	+70/-77.8	+70/-83.2	+/-44.9	+/-57.6	+/-68.9	+70/-73.1
	50-5/8"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-85.5	+70/-90	+70/-90	+70/-89.8	+70/-90	+70/-90	+/-63.2	+70/-80	+70/-80	+70/-80								
	60"	+70/-90	+70/-90	+70/-90	+70/-88.8	+70/-85.8	+70/-81.7	+70/-81.7	+70/-81.7	+70/-75.8	+70/-76.2	+70/-76.2												
	63"	+70/-90	+70/-90	+70/-90	+70/-84.4	+70/-81.5	+70/-77.5	+70/-77.5	+70/-77.5	+70/-71.9	+70/-71.9	+70/-71.9												
	67"	+70/-90	+70/-90	+70/-85.6	+70/-78.3	+70/-75.3	+70/-71.2	+70/-71.2	+70/-71.2															
	72"	+70/-90	+70/-89.5	+70/-79.4	+70/-71.1	+/-67.1																		
	76"	+70/-90	+70/-86.8	+70/-77.2	+/-66.6																			
	84"	+70/-90	+70/-82.5	+70/-72.7																				


NOTES:

- 1) SEE SHEET 4 FOR ADDITIONAL SAMPLE CONFIGURATIONS.
2) SEE SHEET 4 FOR SNUBBER REQUIREMENTS.

PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. 23-0816.15
Expiration Date 04/11/2028
By Ishag I. Chank
Miami-Dade Product Control

F) NO CHANGES IN THIS SHEET.


PREPARED BY A. LYNN MILLER 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600	REGISTRATION #29296	08/08/12	JENS ROSOWSKI	MD-AW740LM	F
PGI Custom Windows and Doors 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600	AWNING WINDOW (LM)	DESIGN PRESSURES PER GLAZING TYPES	AW-740	7 OF 11	Sheet



		Design Pressure (psf) for Single Windows, All Anchor Groups										
		Window Width										
		under 23"	25-15/16"	27-7/8"	30-3/4"	32"	34"	37"	46"	53-1/8"	60"	
Window Height	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90
	39"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-81.2
	50-5/8"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-88.8			
	60"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-84.6				
	63"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-86.1	+70/-79.9				
	67"	+70/-90	+70/-90	+70/-90	+70/-87	+70/-83.6	+70/-79.1					
	72"	+70/-90	+70/-90	+70/-88.2	+70/-79	+70/-74.6						
	76"	+70/-90	+70/-90	+70/-85.8	+70/- 74							
84"	+70/-90	+70/-90	+70/-80.8									


4) 7/8" LAMI. IG: (1/8" T - 7/16" AIR - 1/8" AN - .090" PVB - 1/8" AN)

"PVB"= TROSIFOL[®] PVB BY KURARAY AMERICA, INC.




SEE SHEETS 1
& 4 FOR
WINDOW
ANCHOR
LOCATIONS
AND
QUANTITIES.

		Design Pressure (psf) for Windows Attached to a Vertical Frame Assembly Tube																								
		Window Width																								
		under 23"				25-15/16"			27-7/8"			30-3/4"		32"		34"		37"		46"			53-1/8"		60"	
		Anchor Group				Anchor Group			Anchor Group			Anchor Group		Anchor Group		Anchor Group		Anchor Group		Anchor Group			Anchor Group		Anchor Group	
		A	B	C	D	A	B	C & D	A	B	C & D	A	B, C & D	A	B, C & D	A	B, C & D	A	B, C & D	A	B	C & D	A	B, C & D	All	
Window Height	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	39"	+70/-90	+70/-75.2	+70/-89.9	+70/-90	+70/-83.1	+70/-90	+70/-90	+70/-77.4	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.4	+70/-90	+70/-90	+70/-90	+70/-90	+70/-81.2	+70/-90	+70/-81.2	
	50-5/8"	+70/-72.3	+/-57.9	+/-69.3	+70/-90	+/-64	+70/-90	+70/-90	+/-59.6	+70/-90	+70/-90	+70/-81	+70/-90	+70/-77.9	+70/-90	+70/-73.3	+70/-90	+/-67.3	+70/-90	+70/-72.2	+70/-86.8	+70/-88.8				
	60"	+/-61	+/-48.9	+/-58.5	+70/-90	+/-54	+70/-86.6	+70/-90	+/-50.3	+70/-80.6	+70/-90	+/-68.4	+70/-90	+/-65.7	+70/-90	+/-61.8	+70/-90	+/-56.8	+70/-84.6							
Window Height	63"	+/-58.1	+/-46.5	+/-55.7	+70/-88.7	+/-51.5	+70/-82.5	+70/-90	+/-47.9	+70/-76.8	+70/-90	+/-65.1	+70/-90	+/-62.6	+70/-90	+/-58.9	+70/-86.1	+/-54.1	+70/-79.9							



SEE SHEETS 1 & 4 FOR WINDOW
ANCHOR LOCATIONS AND QUANTITIES.
SEE SHEET 3 FOR ANY ADDITIONAL
ANCHORS REQUIRED FOR THE FRAME
ASSEMBLY TUBE.

[illegible]

SEE SHEETS 1 & 4 FOR WINDOW ANCHOR
LOCATIONS AND QUANTITIES. SEE SHEET
3 FOR ANY ADDITIONAL ANCHORS
REQUIRED FOR THE FRAME ASSEMBLY
TUBE.

1) SEE SHEET 4 FOR ADDITIONAL SAMPLE CONFIGURATIONS
2) SEE SHEET 4 FOR SNUBBER REQUIREMENTS.

Revision:

F) NO CHANGES IN THIS SHEET.

PRODUCT REVISED
as complying with the Florida
Building Code

NOA-No. 23-0816.15

Expiration Date04/11/2028

By Ishag I. Chande
Miami-Dade Product Control

PREPARED BY A. LYNN MILLER
1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941) 480-1600

REGISTRATION #29296

0

08/08/12

Drawn By

JENS ROSOWSKI

NG
O.

MD-AW740LM

Rev.	11
------	----

PGT
Custom Windows and Doors

Custom Windows and Doors
1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941) 480-1600

AWNING WINDOW (LM)

DESIGN PRESSURES PER GLAZING TYPES

AW-740





TABLE 17:

		Design Pressure (psf) for Single Windows, All Anchor Groups									
		Window Width									
		under 23"	25-15/16"	27-7/8"	30-3/4"	32"	34"	37"	46"	53-1/8"	60"
Window Height	under 23"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
	25-15/16"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
	39"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
	50-5/8"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130		
	60"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130			
	63"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130			
	67"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130				
	72"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130					
	76"	+90/-130	+90/-130	+90/-130	+90/-130						
	84"	+90/-130	+90/-130	+90/-130							

FOR GLASS TYPES:

- 5) 7/8" LAMI. IG: (3/16" AN - 1/4" AIR - 3/16" AN - .090" SG - 3/16" AN)
- 6) 7/8" LAMI. IG: (3/16" T - 1/4" AIR - 3/16" AN - .090" SG - 3/16" AN)


"SG"= SENTRYGLAS®BY KURARAY AMERICA, INC.



SEE SHEETS 1
& 4 FOR
WINDOW
ANCHOR
LOCATIONS
AND
QUANTITIES.

TABLE 18:


		Design Pressure (psf) for Windows Attached to a Vertical Frame Assembly Tube																						
		Window Width																						
		under 23"				25-15/16"			27-7/8"			30-3/4"		32"		34"		37"			46"	53-1/8"	60"	
		Anchor Group				Anchor Group			Anchor Group			Anchor Group		Anchor Group		Anchor Group		Anchor Group			Anchor Group	Anchor Group	Anchor Group	
		A	B	C	D	A	B	C & D	A	B	C & D	A	B, C & D	A	B, C & D	A	B, C & D	A	B	C & D	All	All	All	
Window Height	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	39"	+70/-90	+70/-75.2	+70/-89.9	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	50-5/8"	+70/-72.3	+/-57.9	+/-69.3	+70/-90	+70/-90	+70/-90	+70/-90	+70/-89.4	+70/-90	+70/-90	+70/-81	+70/-90	+70/-77.9	+70/-90	+70/-73.3	+70/-90	+70/-89.8	+70/-90	+70/-90	+70/-90			
	60"	+/-61	+/-48.9	+/-58.5	+70/-90	+70/-81.1	+70/-86.6	+70/-90	+70/-75.5	+70/-80.6	+70/-90	+/-68.4	+70/-90	+/-65.7	+70/-90	+/-61.8	+70/-90	+70/-75.8	+70/-90	+70/-90				
	63"	+/-58.1	+/-46.5	+/-55.7	+70/-88.7	+70/-77.2	+70/-82.5	+70/-90	+70/-71.9	+70/-76.8	+70/-90	+/-65.1	+70/-90	+/-62.6	+70/-90	+/-58.9	+70/-90	+70/-72.2	+70/-86.7	+70/-90				



SEE SHEETS 1 & 4 FOR WINDOW
ANCHOR LOCATIONS AND QUANTITIES.
SEE SHEET 3 FOR ANY ADDITIONAL
ANCHORS REQUIRED FOR THE FRAME
ASSEMBLY TUBE.

TABLE 19:

		Design Pressure (psf) for Windows Attached to a Horizontal Frame Assembly Tube																						
		Window Width																						
		under 23"	25-15/16"	27-7/8"	30-3/4"	32"	34"			37"			46"				53-1/8"				60"			
		Anchor Group	Anchor Group	Anchor Group	Anchor Group	Anchor Group	Anchor Group			Anchor Group			Anchor Group				Anchor Group				Anchor Group			
		All	All	All	All	All	A	B	C & D	A	B	C & D	A	B	C	D	A	B	C	D	A	B	C	D
Window Height	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-86.2	+70/-90	+70/-90	+70/-79.2	+70/-90	+70/-79.5	+/-63.7	+70/-76.3	+70/-90	+/-68.9	+/-55.2	+/-66	+70/-90	+/-61	+/-48.9	+/-58.5	+70/-90
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-88.1	+70/-90	+70/-90	+70/-90	+70/-76.3	+70/-90	+70/-90	+70/-90	+/-67.5	+70/-86.6	+70/-90	+70/-90
	39"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-82	+70/-90	+70/-90	+70/-90	+70/-71	+70/-81.3	+70/-90	+70/-90	+/-62.9	+70/-72	+70/-86.2	+70/-90
	50-5/8"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90									
	60"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90													
	63"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90													
	67"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90																
	72"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90																		
	76"	+70/-90	+70/-90	+70/-90	+70/-90																			
84"	+70/-90	+70/-90	+70/-90																					



SEE SHEETS 1 & 4 FOR WINDOW ANCHOR
LOCATIONS AND QUANTITIES. SEE SHEET
3 FOR ANY ADDITIONAL ANCHORS
REQUIRED FOR THE FRAME ASSEMBLY
TUBE.

NOTES:

- 1) SEE SHEET 4 FOR ADDITIONAL SAMPLE CONFIGURATIONS.
- 2) SEE SHEET 4 FOR SNUBBER REQUIREMENTS.

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0816.15

Expiration Date04/11/2028

By Ishag I. Chank
Miami-Dade Product Control

F) NO CHANGES IN
THIS SHEET.

PREPARED BY A. LYNN MILLER 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600	REGISTRATION #29296	08/08/12	JENS ROSOWSKI	F
PGI Custom Windows and Doors 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600	AWNING WINDOW (LM)	DESIGN PRESSURES PER GLAZING TYPES	MD-AW740LM	9 OF 11





TABLE 20:

Item	Dwg. #	Description	Mat.
1	7002	Main Frame Head, Sill & Jamb	6063-T6 Alum.
2	7071	Anchor Plate	6063-T6 Alum.
3	7003	Sash Top, Bottom & Side Rail	6063-T6 Alum.
4	7008	Frame Corner Key	Steel
5	7009	Sash Corner Key	Steel
6	7078	Frame Gasket	Vinyl Foam
7	7072	Sash Corner Gasket	Vinyl Foam
8	7070	Bulb Weatherstrip .187" x .275"	Flex PVC 70
10	7024	Maxim Multi-Point Lock	Steel
11	7026	Lock Support Plate	Steel
12	7014	Multi-Lock Keeper	Steel
13	7013	Tie Bar Guide	Nylon
14	7015	Tie Bar Assembly	Steel or SS
16	7029	Maxim Projected Operator	Steel
17	7030	Operator Gasket	Vinyl Foam
18	7031	Operator Backing Plate	Steel
19	7051	Operator Spacer Block	Nylon
21	7034	Operator Track & Slider	Steel
22	7023	Projected Hinge, Manuf. by Truth	Steel
24		Snubber, Anti-blowout Clip	Steel
32	1713	Setting Block 5/32" x 3/16" x 1-1/4"	EPDM
33	1714	Setting Block 5/32" x 7/16" x 1-1/4"	EPDM
35	7036	Bead B	6063-T6 Alum.
36	7042	Bead C	6063-T6 Alum.
37	7059	Bead D	6063-T6 Alum.
38	1224	Vinyl Bulb Wstp (Thick)	Flex PVC 70
39	1225	Vinyl Bulb Wstp (Thin)	Flex PVC 70
50		Dow 791, 899 or 983 Backbedding	Silicone
60	7006	Screen Corner	3105-H14 Alum.
61	7040	Screen Frame Key	Polypropolene
62		Screen Cloth	Fiberglass
63	1635	Screen Spline	EM. PVC
64	320	Casement Screen Spring	Stainless Steel
70	134	Add-on Flange	6063-T6 Alum.
71	7004	Frame Assy Tube	6063-T6 Alum.
72		Maxim Pivot Slider Assembly	Steel
80		#8-32 x 1/2" Ph. Pn. Mach. Scr Type B	Stainless Steel
81	1157	#8 x 1/2" Ph. Pn. SMS	Stainless Steel
82		#8 x 5/8" Fl. Ph. SMS	Stainless Steel
83		#8 x 7/8" F.H. Ph. SMS	Stainless Steel
84		#8 x 1" Fl. Ph. TEK	Stainless Steel
85		#8 x 1" Quad Pn SMS	Stainless Steel
86		#8 X 1-1/2" Quad Pn SMS	Stainless Steel
87		#10 x 1/2" Ph. Pn./ TEK	Stainless Steel
89		#10-24 x 9/16" Ph. Pn. TYPE F	Stainless Steel
90		#12 x 1" Ph. Pn. TEK	Stainless Steel

ALL DETAILS SHOWN FROM THE INTERIOR

AS REQUIRED PER
TABLE 3, SHEET 4



PRODUCT REVISED
as complying with the Florida
Building Code

NOA-No. 23-0816.15


Expiration Date 04/11/2028


By Ishag I. Chank
Miami-Dade Product Control

Revision:


F) NO CHANGES IN
THIS SHEET.

PGT Custom Windows and Doors 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600		PREPARED BY A. LYNN MILLER 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600							
		REGISTRATION #29296							
		AWNING WINDOW (LM)							
		BOM & CORNER VIEW							
		10 OF 11							
Series	Desc.	Title	Sheet	AW-740	10 OF 11	DWG No.	MD-AW740LM	Rev.	F
							By	JENS ROSOWSKI	
							Date	08/08/12	







100 **KODISPACE**
4SG TPS



101 **SUPER**
SPACER® NXT™




102 **DURASEAL®**
SPACER




103 **XL EDGE™**
SPACER

Part #	Description	Material
100	Kommerling 4SG TPS Spacer System	See this Sheet for Materials
101	Quanex Super Spacer nXT with Hot Melt Butyl	
102	Quanex Duraseal Spacer	
103	Cardinal XL Edge Spacer	


REFERENCE TEST REPORTS: FTL-8717, 8968 & 8970




1 **FRAME HEAD,
SILL & JAMB**
#7002, 6063-T6




2 **ANCHOR PLATE**
#7071, 6063-T6




35 **BEAD B**
#7036, 6063-T6




37 **BEAD D**
#7059, 6063-T6




3 **SASH TOP,
BOTTOM & SIDE**
#7003, 6063-T6




60 **FIXED
SCREEN FRAME**
#7006, 3105-H14



36 **BEAD C**
#7042, 6063-T6



71 **FRAME
ASSEMBLY TUBE**
#7004, 6063-T6



70 **ADDON FLANGE**
#134, 6063-T6

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. 23-0816.15
Expiration Date 04/11/2028
By Ishag I. Chande
Miami-Dade Product Control

Revision: F) NO CHANGES IN THIS SHEET.

PREPARED BY A. LYNN MILLER 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600	REGISTRATION #29296	08/08/12 Date	JENS ROSOWSKI By	MD-AW740LM Rev.	F
PGI Custom Windows and Doors 1070 TECHNOLOGY DRIVE N. VENICE, FL 34275 (941) 480-1600	AWNING WINDOW (LM)	11 OF 11 Sheet	EXTRUSIONS & APACERS Title	AW-740 Series	11 OF 11 Desc.

