



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599

www.miamidade.gov/economy

IKO Industries, LTD.
40 Hansen Road South
Brampton, ON
L6W 3H4

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas, where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: IKO Innovati TPO Single Ply Roofing Systems over Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 7.

The submitted documentation was reviewed by Alex Tigera.

09/04/25



NOA No.: 24-0117.18
Expiration Date: 09/04/30
Approval Date: 09/04/25
Page 1 of 7

ROOFING SYSTEM APPROVAL

<u>Category:</u>	Roofing
<u>Sub-Category:</u>	Single Ply Roofing
<u>Material:</u>	TPO
<u>Deck Type:</u>	Concrete
<u>Maximum Design Pressure:</u>	-262.5 psf.
<u>Fire Classification:</u>	See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
IKO Innovati TPO	45mil, 60mil, 80mil	ASTM D6878	Highly reflective “Cool Roof” TPO membrane
IKO MVP	39.4”x 105’	ASTM D5147	Modified SBS vapor retarder only for use as a vapor barrier.
IKO MVP Sand	36” x 80’	ASTM D5147	Modified SBS vapor retarder only for use as a vapor barrier.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
IKOTherm-A	Polyisocyanurate Foam Insulation	IKO Industries Ltd.
IKOTherm-A III	Polyisocyanurate Foam Insulation	IKO Industries Ltd.
IKOTherm-A CoverShield	Polyisocyanurate Foam Insulation	IKO Industries Ltd.
ACFoam-HD Coverboard	Polyisocyanurate Foam Insulation	Atlas Roofing Corporation
ACFoam-II	Polyisocyanurate Foam Insulation	Atlas Roofing Corporation
ACFoam-III	Polyisocyanurate Foam Insulation	Atlas Roofing Corporation
DensDeck	Gypsum Core Board	Georgia-Pacific Gypsum LLC
DensDeck Prime	Gypsum Core Board	Georgia-Pacific Gypsum LLC
SECUROCK Gypsum-Fiber Roof Board	Gypsum based board stock	USG Corporation



APPROVED FASTENERS/ADHESIVES:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	IKO Millennium Adhesive	Foamable Adhesive.	Various	IKO Industries, LTD.
2.	InnoviBond Membrane Adhesive LVOC	Roller applied Adhesive	Various	IKO Industries, LTD.
3.	InnoviBond Membrane Adhesive SPR	Sprayable Adhesive.	Various	IKO Industries, LTD.
4.	InnoviBond Membrane Adhesive	Roller applied Adhesive	Various	IKO Industries, LTD.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
NEMO ETC, LLC	4q-IKO-21-SSMBB-01.A	Proprietary	12/10/21
	4r-IKO-21-SSTHP.A	ASTM D6878	01/18/22
FM Approvals	PR454078	FM 4470	04/29/21
	PR459544	FM 4470	12/14/23



APPROVED ASSEMBLIES

Membrane Type:	Single Ply, TPO
Deck Type 3I:	Structural Concrete
Deck Description:	Structural Concrete
System Type A(1):	All layers of insulation adhered, membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Thermal Barrier	½” DensDeck, SECUROCK Gypsum-Fiber Roof Board or DensDeck Prime, adhered with IKO Millennium Adhesive applied in ribbons spaced 12” o.c.
Vapor Retarder	IKO MVP Sand or IKO MVP, self-adhered

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ACFoam-III, IKOTerm-A, IKOTerm-A III Minimum: 1 ½” thick	N/A	N/A

Note: Base insulation shall be adhered to the deck with IKO Millennium Adhesive applied in ½ to ¾ ” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
IKOTerm-A CoverShield, ACFoam-HD Coverboard, SECUROCK Gypsum-Fiber Roof Board, DensDeck, or DensDeck Prime Minimum: ½” thick	N/A	N/A

Note: Top insulation shall be adhered to the base insulation with IKO Millennium Adhesive applied in ½ to ¾ ” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Roof Cover:	Min. 45 mil IKO Innovi TPO, adhered with InnoviBond Membrane Adhesive SPR at 0.21 to 0.24 gal/square with a 2” overlap to the bottom surface of the roof cover and the top surface of the substrate for a total of 0.41 to 0.47 gal/square.
--------------------	---

Maximum Design Pressure:	-82.5 psf. (See General Limitation #9)
---------------------------------	--



Membrane Type: Single Ply, TPO
Deck Type 3I: Structural Concrete
Deck Description: Structural Concrete
System Type A(2): All layers of insulation adhered, membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Thermal Barrier ½” DensDeck, SECUROCK Gypsum-Fiber Roof Board or DensDeck Prime, adhered with IKO Millennium Adhesive applied in ribbons spaced 12” o.c.

Vapor Retarder IKO MVP Sand or IKO MVP, self-adhered

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
IKOTherm-A, ACFoam-II, IKOTherm-A III, ACFoam-III Minimum: 1 ½” thick	N/A	N/A

Note: Base insulation shall be adhered to the deck with IKO Millennium Adhesive applied in ½ to ¾ ” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
IKOTherm-A CoverShield, ACFoam-HD Coverboard, SECUROCK Gypsum-Fiber Roof Board, or DensDeck Prime. Minimum: ½” thick	N/A	N/A

Note: Top insulation shall be adhered to the base insulation with IKO Millennium Adhesive applied in ½ to ¾ ” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Roof Cover: Min. 45 mil IKO Innovi TPO, adhered with InnoviBond Membrane Adhesive at a rate of 0.83 to 1.0 gal./square on both the bottom side of the roof cover and top side of the substrate for a total of 1.67 to 2.0 gal./square.

Maximum Design Pressure: -82.5 psf. (See General Limitation #9)



Membrane Type: Single Ply, TPO
Deck Type 3I: Structural Concrete
Deck Description: Structural Concrete
System Type A(3): All layers of insulation adhered, membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
IKOTherm-A, ACFoam-II, IKOTherm-A III, ACFoam-III Minimum: 1 ½” thick	N/A	N/A

Note: Base insulation shall be adhered to the deck with IKO Millennium Adhesive applied in ½ to ¾ ” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Roof Cover: Min. 45 mil IKO Innovati TPO, adhered with InnovatiBond Membrane Adhesive at a rate of 0.83 to 1.0 gal./square on both the bottom side of the roof cover and top side of the substrate for a total of 1.67 to 2.0 gal./square
 Or
 Min. 45 mil IKO Innovati TPO, adhered with InnovatiBond Membrane Adhesive SPR at 0.21 to 0.24 gal/square with a 2” overlap to the bottom surface of the roof cover and the top surface of the substrate for a total of 0.41 to 0.47 gal/square.

Maximum Design Pressure: -262.5 psf. (See General Limitation #9)



CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.
Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE