



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION  
**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**SRS Distribution Inc.**  
**7440 S. Hwy 121**  
**Mckinney, TX 75070**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Top Shield Pro Roofing Adhesives**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge L. Acebo.

10/10/24



NOA No.: 24-0521.03  
Expiration Date: 05/16/27  
Approval Date: 10/10/24  
Page 1 of 3

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Cement-Adhesive-Coatings  
**Materials:** Polyurethane

### SCOPE:

This approves **Top Shield Pro Roofing Adhesives**, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricanes Zone. The use of this acceptance is limited to those roof assemblies where Top Shield Pro Roofing Adhesives is specifically listed as an accepted component.

### PRODUCT DESCRIPTION:

Spray Polyurethane Foam with the properties described below:

<b><u>Description</u></b>	<b><u>Test</u></b>	<b><u>Properties</u></b>
<b>Top Shield Pro Roofing Adhesive</b>		
Flame Spread Index	ASTM E84 / UL723	23
Smoke Develop Index	ASTM E84 / UL723	28
Self-Ignition Temperature	ASTM D1929	970°F
Density @ 73°F	ASTM D1622	5.4 lb./ft <sup>3</sup>
Compressive Strength @ 10% deformation		
Parallel to rise	ASTM D1621	27 psi
Perpendicular to rise		14 psi
Tensile Strength	ASTM D1623	37 psi
Water Absorption	ASTM D2842	3%

<b><u>Description</u></b>	<b><u>Test</u></b>	<b><u>Properties</u></b>
<b>Top Shield Pro Roofing Adhesive-Tanks</b>		
Self-Ignition Temperature	ASTM D1929	986°F
Density @ 73°F	ASTM D1622	2.2 lb./ft <sup>3</sup>
Compressive Strength @ 10% deformation		
Parallel to rise	ASTM D1621	14 psi
Tensile Strength	ASTM D1623	25 psi
Water Absorption	ASTM D2842	1%
Volatile Content	ASTM D2369	2.8%

**Note: The physical properties listed above are presented at typical average values as determined by accepted ASTM test methods and are subject to normal manufacturing variation.**



NOA No.: 24-0521.03  
Expiration Date: 05/16/27  
Approval Date: 10/10/24  
Page 2 of 3

## EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
NEMO ETC, LLC	4p-AB-20-SSLAP-01.A 4p-AB-23-SSLAP-01.A	Various Various	06/30/20 04/11/24
UL LLC	R40430	ASTM E84 / UL723	01/26/22

## MANUFACTURING LOCATION:

1. ML #1

## LIMITATIONS:

1. Top Shield Pro Roofing Adhesives shall have a quality control testing program by an approved independent listing agency having unannounced follow-up visits. Follow up test results shall be made available to Miami-Dade County Product Control upon request.
2. Top Shield Pro Roofing Adhesives shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

## INSTALLATION:

Top Shield Pro Roofing Adhesives shall be installed in strict compliance with the Roof Assembly Noticed of Acceptance and manufacturer's published literature.

## BUILDING PERMIT REQUIREMENTS:

As required by the Building Official or applicable Building Code in order to properly evaluate the installation of this system. This Notice of Acceptance on its own cannot be used to obtain a building permit.

## LABELING:

Top Shield Pro Roofing Adhesives shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



**END OF THIS ACCEPTANCE**



NOA No.: 24-0521.03  
Expiration Date: 05/16/27  
Approval Date: 10/10/24  
Page 3 of 3