



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99
www.miamidade.gov/economy

The Garland Company, Inc.
3800 East 91st Street
Cleveland, OH 44105-2197

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Garland Modified Bitumen Roofing Systems over Lightweight Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA# 23-1130.03 and consists of pages 1 through 32.
The submitted documentation was reviewed by Alex Tigera.

12/19/24



NOA No.: 24-1114.05
Expiration Date: 12/02/29
Approval Date: 12/19/24
Page 1 of 32

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Modified Bitumen
Material: SBS/SIS/SEBS
Deck Type: Lightweight Concrete
Maximum Design Pressure: -225 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
VersiPly 40	39" x 68' 7"	ASTM D 4601 Type II	Smooth surfaced, SBS modified, fiberglass scrim reinforced roofing membrane for use as a base sheet only.
HPR Tri-Base Premium	36" x 72'	ASTM D 4601	Double asphalt coated, polyester/fiberglass/polyester scrim reinforced base sheet.
HPR Glasfelt	36" x 180'	ASTM D 2178, Type IV	Asphalt impregnated glass felt
HPR Premium Glasfelt	36" x 180'	ASTM D 2178, Type VI	Asphalt impregnated glass felt
HPR Glasbase	36" x 108'	ASTM D 4601, Type II	Asphalt coated fiberglass base sheet.
HPR Premium Glasbase	36" x 72'	ASTM D 4601, Type II	Asphalt coated fiberglass base sheet.
Millennium Base	39" x 51'5"	ASTM D 6162	Smooth surfaced, SBS modified coal tar, fiberglass/polyester reinforced base sheet.
HPR Torch Base Sheet	39" x 34'8"	ASTM D 6163	SBS modified, fiberglass reinforced, torch applied base sheet.
FlexBase Plus 80	39" x 34'8"	ASTM D 6162, Type III	SBS modified, fiberglass/polyester reinforced base sheet
FlexBase E 80	39" x 34'8"	ASTM D 6162, Type III	SBS/SIS modified, fiberglass/polyester reinforced base sheet.
StressBase 80	39" x 52'	ASTM D 6163, Type I	SBS modified, fiberglass reinforced base sheet.
StressBase 120	39" x 52'	ASTM D 6163, Type I	SBS modified, fiberglass reinforced base sheet.



NOA No.: 24-1114.05
Expiration Date: 12/02/29
Approval Date: 12/19/24
Page 2 of 32

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
FlexBase 80	39" x 34'8"	ASTM D 6163, Type III	SBS modified, fiberglass reinforced base sheet.
HPR Polyscrim Plus	40" x 324'	ASTM D 5726	Polyester felt
Millennium FR Mineral	39" x 26'	ASTM D 6162	Mineral surfaced, SBS modified coal tar, fiberglass/polyester reinforced membrane.
StressPly EUV FR Mineral	39" x 26'2"	ASTM D 6162, Type III	Mineral surfaced, SBS/SIS modified, fiberglass/polyester reinforced membrane.
StressPly Plus	39" x 34'8"	ASTM D 6162, Type III	Smooth surfaced, SBS modified, fiberglass/polyester scrim membrane.
StressPly Plus FR Mineral	39" x 26'2"	ASTM D 6162, Type III	Mineral surfaced, SBS modified, fire retardant, UV resistant, fiberglass/polyester scrim membrane.
StressPly E FR Mineral	39" x 26'2"	ASTM D 6162, Type III	Mineral surfaced, SBS/SIS modified, fire retardant, fiberglass/polyester reinforced membrane.
StressPly IV Plus	39" x 26'2"	ASTM D 6162, Type III	Smooth surfaced, SBS modified, fiberglass/polyester reinforced, torch applied cap sheet.
StressPly IV Plus Mineral	39" x 26'2"	ASTM D 6162, Type III	Mineral surfaced, SBS modified, fiberglass/polyester reinforced, torch applied cap sheet.
StressPly IV Plus UV Mineral	39" x 26'2"	ASTM D 6162, Type III	Mineral surfaced, SBS modified, fiberglass/polyester reinforced, torch applied cap sheet.
StressPly FR Mineral	39" x 26'2"	ASTM D 6163, Type III	Mineral surfaced, SBS modified, fire retardant, fiberglass scrim membrane.
VersiPly Mineral	39" x 26'2"	ASTM D 6163, Type III	Mineral surfaced, SBS modified, fiberglass scrim reinforced roofing membrane.
StressPly IV Mineral	39" x 26'2"	ASTM D 6163, Type III	Mineral surfaced, SBS modified, fiberglass reinforced, torch applied cap sheet.
OptiMax FR Mineral	39" x 26'2"	ASTM D6163, Type III	Mineral surfaced, SBS modified, fiberglass reinforced, cap sheet.
Garla-Prime VOC	5, 55 gallon	ASTM D 41	Non-fibered, quick drying asphalt roof primer



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Insul-Lock HR	1.5 liters	Proprietary	Polyurethane two component high rise insulation adhesive
Black-Knight	70 lb. keg	Proprietary	Polymer modified coal tar pitch.
Black-Knight Cold	5, 55 gallon	Proprietary	Polymer modified coal tar pitch.
Green-Lock Plus Membrane Adhesive	5 gallon	Proprietary	Cold process roof coating and adhesive.
Weatherking	5, 55 gallon	ASTM D 3019, Type III	Cold process roof coating and adhesive.
Weatherking Plus WC	5, 55 gallon	ASTM D 3019, Type III	Cold process roof coating and adhesive.
Weatherking Flashing Adhesive	5, 55 gallon	ASTM D 3019, Type III	Cold process roof flashing adhesive.
Garlastic KM Plus	60 lb. keg	TAS 121	SEBS modified, hot applied asphalt.
HPR All Temp Asphalt	100 lb. keg	TAS 121	Hot asphalt adhesive for modified bitumen and BUR roof systems.
GarMesh	6" x 150'	ASTM D 1668	SBR coated woven fiberglass reinforcing membrane.
Grip Polyester Firm	10 sq.	ASTM D 1682	Polyester reinforcing fabric for use in cold applied systems.
Grip Polyester Soft	10 sq.	ASTM D 1682	Polyester reinforcing fabric, for use in cold applied systems.
Silver-Shield	5, 55 gallon	ASTM D 2824, Type III	High solids, aluminized roof coating.
WeatherScreen	5, 55 gallon	ASTM D 4479, Type I	Asbestos-free, heavy-bodied, fiber-reinforced, fire-rated asphalt roof coating.
Garla-Brite	5, 55 gallon	ASTM D 4479, Type I	Asbestos-free, heavy-bodied, fiber-reinforced, fire-rated asphalt roof coating.
Energizer K Plus FR	5, 55 gallon	ASTM D 4479, Type I	Multipurpose, rubberized, liquid waterproofing membrane.



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:**TABLE 1**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Green-Lock Flashing Adhesive	3.5 gallon	Proprietary	Trowel grade, roofing mastic for use in repair and patching against leaks in built-up roofs.
Black-Knight Mastic	5 gallon	Proprietary	Trowel grade, tar based roofing mastic for use in repair and patching.
Flashing Bond	5 gallon	ASTM D 4586	Trowel grade, asphalt based roofing mastic for use in repair and patching against leaks in built-up asphalt roofs.
Silver-Flash	5 gallon	ASTM D 4586	Trowel grade, asphalt based roofing mastic for use in repair and patching against leaks in built-up asphalt roofs.
Garla-Flex	2, 5 gallon pail	ASTM D 4586	Elastomeric, asphaltic compound formulated from a special weather and ozone-resistant thermoplastic rubber, plasticizing oils and bitumen. Asbestos free.

APPROVED INSULATIONS:**TABLE 2**

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
ACFoam-II	Polyisocyanurate foam insulation	Atlas Roofing Corporation
ISO 95+ GL	Polyisocyanurate foam insulation	Holcim Solutions and Products US, LLC.
EnergyGuard Polyiso Insulation	Polyisocyanurate foam insulation	GAF Materials Corp.
DensDeck, DensDeck Prime	Water resistant gypsum board	Georgia Pacific Gypsum LLC
ENRGY 3, ENRGY 3 25 PSI	Polyisocyanurate foam insulation	Johns Manville Corp.
SECUROCK Gypsum-Fiber Roof Board	Gypsum/Cellulosic fiber panels	United States Gypsum Corp.
H-Shield	Polyisocyanurate insulation	Hunter Panels, a div. of Carlisle Const. Materials, LLC
Fesco Board	Expanded mineral fiber insulation	Johns Manville Corp.
Structodek High Density Fiberboard Roof Insulation	High Density wood fiber insulation board	Blue Ridge Fiberboard, Inc.
Retro-Fit Board	A high density perlite roof insulation.	Johns Manville Corp.



NOA No.: 24-1114.05
 Expiration Date: 12/02/29
 Approval Date: 12/19/24
 Page 5 of 32

APPROVED FASTENERS/ADHESIVES:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	Trufast FM-90 Base Sheet Fastener	Base ply fastening systems for lightweight concrete decks.	Various	Altenloh, Brinck & Co. U.S., Inc.
2.	Trufast Twin Loc-Nail Assembled Fastener	Base ply fastening systems for lightweight concrete decks.	Various	Altenloh, Brinck & Co. U.S., Inc.
3.	CR Base Sheet Fastener and Plate	Base sheet fastening assembly.	Various	OMG, Inc.
4.	CR Assembled Base Sheet Fastener (1.7")	G-90 galvanized base sheet fastener & plate	1.125" x 1.75"	OMG, Inc.
5.	OlyBond 500 Adhesive Fastener	A two component polyurethane foam adhesive		OMG, Inc.



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
NEMO ETC, LLC.	4p-GRL-21-SSLAP-01.A	Physical Properties	07/23/21
Factory Mutual Research Corporation	0D3A3.AM	FM 4470	04/04/97
	1D7A4.AM	FM 4470	11/09/98
	2D0A0.AM	FM 4470	12/23/98
	3004392	FM 4470	09/21/99
	3014692	FM 4470	08/05/03
	3019046	FM 4470	03/04/05
	3021718	FM 4470	04/11/05
	3023458	FM 4450	07/18/06
	3032163	FM 4470	07/21/08
	3032647	FM 4470	07/28/08
	797-04451-267	FM 4470	04/08/09
	3036229	FM 4470	10/09/09
	3054493	FM 4470	01/04/16
PRI Construction Materials Technologies	GRD-051-02-01	ASTM D 2178	10/28/11
	GRD-052-02-01	ASTM D 2178	10/28/11
	GRD-054-02-01	ASTM D 2626	11/17/11
Trinity ERD	4545.11.06	TAS 114(J)	11/22/06
	G10800.09.08	TAS 114	09/15/08
	C8500SC.11.07-R1	TAS 117 / ASTM D6862	08/07/09
	G30050.08.09	TAS 117 (B) / TAS 114 (H)	08/20/09
	G32950.05.10	ASTM D4601	05/03/10
	G32950.06.10	ASTM D4601	06/11/10
	G17060.10.09-R1	TAS 114 (D)	07/16/10
	4533.05.98-1-R1	TAS 114(J)	09/09/11
	G32700.09.11-1	ASTM D4601	09/16/11
	G39620.07.12	ASTM D4990	07/02/12
	G39630.07.12	Physical Properties	07/12/12
	G37200.10.12-1-R1	ASTM D6163/D4798	12/05/12
	G37200.10.12-4-R1	ASTM D6162	12/05/12
	G37200.10.12-7-R1	ASTM D6162	12/05/12
	G37200.10.12-9-R1	ASTM D6162/D4798	12/05/12
	G37200.10.12-10-R1	ASTM D6163/D4798	12/05/12
	G37200.10.12-5-R2	ASTM D6162	09/23/13
	G37200.10.12-6-R2	ASTM D6162/D4798	09/23/13
	G37200.10.12-2-R2	ASTM D6162/D4798	09/24/13
	G37200.10.12-3-R2	ASTM D6162/D4798	09/24/13
	G37200.10.12-11-R2	ASTM D6163/D4798	09/24/13
	G37200.10.12-12-R2	ASTM D6163/D4798	09/24/13
	G37200.09.13-10	ASTM D6163/D4798	09/24/13
	G37200.09.13-1	ASTM D6163/D4798	09/24/13
	G37200.08.12-13-R2	ASTM D6162/D4798	09/26/13
	GRL-SC8185.05.16	ASTM D6163/D4798	05/31/16
Atlantic & Caribbean Roof	ACRC 08-029	TAS 114	04/24/08



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Consulting, LLC			
Certified Testing Laboratories	CTLA 114R-1A	TAS 114	09/17/09
	CTLA 114R-2A	TAS 114	09/17/09
	CTLA 114R-3A	TAS 114	09/17/09
	CTLA 116R-2A	TAS 114	11/16/09
	CTLA 116R-1A	TAS 114	11/16/09
	CTLA 116R	TAS 114	11/16/09

DECK STRESS ANALYSIS CALCULATIONS/REPORTS

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
Robert Nieminen, P.E.	Signed/Sealed Calculations	E(4), E(11), E(13)	11/02/16
FM Approval Deck Limitation	N/A	E(5), E(9), E(10)	01/01/13



APPROVED ASSEMBLIES:

Membrane Type: SBS/SIS/SEBS
Deck Type 4I: Lightweight Concrete, Insulated
Deck Description: Elastizell Lightweight Concrete, min 300 psi.
System Type A(1): One or more layers of insulation adhered with approved asphalt or cold bonding adhesive

All General and System Limitations apply.

Deck: 2500 psi structural concrete or concrete plank.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
ACFoam-II Minimum 2" thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum ¼" thick	N/A	N/A

Note: All insulation shall be adhered with OMG OlyBond 500 Adhesive Fastener in ¾" ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base/Ply Sheet: One or more plies of StressBase 80, StressBase 120 or FlexBase 80, FlexBase Plus 80, FlexBase E 80 adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq. or Green-Lock Plus Membrane Adhesive at a min rate of 1.5 gal/sq or WeatherKing or Weatherking Plus WC Adhesive at a rate of 2½ gal/sq.

Membrane: One ply of OptiMax FR Mineral, StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly FR Mineral, StressPly Plus or StressPly Plus FR Mineral adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq. or Green-Lock Plus Membrane Adhesive at a min rate of 1.5 gal/sq or WeatherKing or Weatherking Plus WC Adhesive at a rate of 2 ½ gal/sq.



Surfacing:

Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq. or in Black-Knight Flood Coat at 70 lb./sq. or Black-Knight Cold at 5 gal/sq.
2. Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

**Maximum Design
Pressure:**

-67.5 psf. (See General Limitation #9.)



Membrane Type: SBS/SIS/SEBS
Deck Type 4I: Lightweight Concrete, Insulated
Deck Description: Elastizell Lightweight Concrete, min. 300 psi.
System Type A(2): One or more layers of insulation adhered with approved asphalt or cold bonding adhesive.

All General and System Limitations apply.

Deck: 2500 psi structural concrete or concrete plank

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
ACFoam II, H-Shield Minimum 2" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: All insulation shall be adhered with OMG OlyBond 500 Adhesive Fastener in 3/4" ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One or more plies of Millennium Base adhered with Green-Lock Plus Membrane Adhesive at a min rate of 1.5 gal/sq (0.61 L/m²), Black-Knight at a rate of 30 lb/sq, or Black-Knight Cold adhesive at a rate of 1.5 - 2.0 gal/sq.

Membrane: One ply of Millennium FR Mineral adhered with Green-Lock Plus Membrane Adhesive at a min rate of 1.5 gal/sq (0.61 L/m²), Black-Knight at a rate of 30 lb/sq., or Black-Knight Cold adhesive at a rate of 1.5 – 2.0 gal/sq.



Surfacing:

Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq. or in Black-Knight at 70 lb/sq. or Black-Knight Cold at 5 gal/sq.
2. Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

**Maximum Design
Pressure:**

-225 psf. (See General Limitation #9.)



Membrane Type: SBS/SIS/SEBS
Deck Type 4I: Lightweight Concrete, Insulated
Deck Description: Elastizell Lightweight Concrete, min. 300 psi.
System Type A(3): One or more layers of insulation adhered with approved asphalt or cold bonding adhesive.

All General and System Limitations apply.

Deck: 2500 psi structural concrete or concrete plank

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
ACFoam-II, H-Shield Minimum 2" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: All insulation shall be adhered with OMG OlyBond 500 Adhesive Fastener in 3/4" ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base/Ply Sheet: One or more plies of StressBase 80, StressBase 120 or FlexBase 80, FlexBase Plus 80, FlexBase E 80 adhered with hot asphalt at a rate of 25 lb/sq (1.0 kg/m²), HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq. or Green-Lock Plus Membrane Adhesive at a min rate of 2 gal/sq

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly Plus FR Mineral or VersiPly Mineral adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq., or Green-Lock Plus Membrane Adhesive at a min rate of 2 gal./sq.



Surfacing:

Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq. or in Black-Knight at 70 lb/sq. or Black-Knight Cold at 5 gal/sq.
2. Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

**Maximum Design
Pressure:**

-225 psf. (See General Limitation #9.)



Membrane Type: SBS/SIS/SEBS
Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Elastizell cellular lightweight concrete, min. 200 psi, over concrete deck.
System Type E(1): Base sheet mechanically fastened.

All General and System Limitations apply.

Structural Deck: 2500 psi structural concrete or concrete plank

Base Sheet: One ply of HPR Glasbase, HPR Premium Glasbase, HPR Tri-Base Premium, mechanically attached using OMG CR Base Sheet Fasteners or Trufast FM-90 Base Sheet Fastener spaced 7" o.c. in a 4" side lap and 7" o.c. in two staggered rows in the center of the sheet.

Ply Sheet: One or more plies of HPR Glasbase, HPR Premium Glasbase, HPR Tri-Base Premium, HPR Glasfelt, HPR Premium Glasfelt, HPR Polyscrim Plus adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly FR Mineral, StressPly Plus, StressPly Plus FR Mineral or VersiPly Mineral adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq.
2. Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design Pressure: -45 psf. (See General Limitation #7.)



NOA No.: 24-1114.05
Expiration Date: 12/02/29
Approval Date: 12/19/24
Page 15 of 32

Membrane Type: SBS/SIS/SEBS
Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Elastizell cellular lightweight concrete, min. 200 psi, over concrete deck.
System Type E(2): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: 2500 psi structural concrete or concrete plank.

Base Sheet: One ply of HPR Glasbase, HPR Premium Glasbase, HPR Tri-Base Premium mechanically attached using OMG CR Base Sheet Fasteners or Trufast FM-90 Base Sheet Fastener spaced 7" o.c. in a 4" side lap and 7" o.c. in two staggered rows in the center of the sheet.

Ply Sheet: One more plies of HPR Glasbase, HPR Premium Glasbase, HPR Tri-Base Premium, HPR Glasfelt or HPR Premium Glasfelt adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.
Or
One ply of HPR Torch Base Sheet torch applied to base sheet.

Membrane: One ply of StressPly IV Mineral, StressPly IV Plus, StressPly IV Plus UV Mineral or StressPly IV Plus Mineral torch applied.

Surfacing: Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq.
2. Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design Pressure: -45 psf. (See General Limitation #7.)



Membrane Type: SBS/SIS/SEBS
Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Elastizell cellular lightweight concrete, min. 200 psi, over concrete deck.
System Type E(3): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: 2500 psi structural concrete or concrete plank.

Base Sheet: One ply of HPR Glasbase, HPR Premium Glasbase or HPR Tri-Base Premium mechanically attached using OMG CR 1.7" Base Ply Fasteners spaced 7" o.c. in a 4" side lap and 7" o.c. in two staggered rows in the center of the sheet.

Ply Sheet: One or more plies of HPR Glasbase, HPR Premium Glasbase or HPR Tri-Base Premium adhered with Weatherking or Weatherking Plus WC Adhesive at a rate of 2½ gal/sq.

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly FR Mineral, StressPly Plus, StressPly Plus FR Mineral or VersiPly Mineral adhered with Weatherking or Weatherking Plus WC Adhesive at a rate of 2½ gal/sq.

Surfacing: Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq. (asphalt applied systems only, Not compatible with Weatherking and Weatherking Plus WC applied systems).
2. Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design Pressure: -45 psf. (See General Limitation #7.)



Membrane Type: SBS/SIS/SEBS
Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Celcore cellular lightweight concrete, min. 200 psi, over steel or concrete deck
System Type E(4): Base sheet mechanically fastened.

All General and System Limitations apply.

Structural Deck: 2500 psi structural concrete or concrete plank.
Or
Min. 22 ga., type B, Grade 33 galvanized steel deck attached to supports spaced maximum 6 ft. o.c. with ½" puddle welds and washers. Side laps attached using Traxx/1 screws at mid-span.

This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

Base Sheet: One ply of HPR Tri-Base Premium, mechanically attached using OMG CR Base Sheet Fasteners or Trufast FM-90 Base Sheet Fastener spaced 7" o.c. in a 4" side lap and 7" o.c. in two staggered rows in the center of the sheet.

Ply Sheet: One or more plies of Millennium Base applied in hot coal tar at a rate of 30 lbs./sq.

Membrane: One ply of Millennium FR Mineral applied in hot coal tar at a rate of 30 lbs./sq.

Surfacing: Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq.
2. Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat .
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design Pressure: -45 psf. (See General Limitation #7.)



NOA No.: 24-1114.05
Expiration Date: 12/02/29
Approval Date: 12/19/24
Page 18 of 32

Membrane Type: SBS/SIS/SEBS
Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Min. 200 psi, Celcore cellular lightweight concrete with min. 42 pcf wet cast density; 1/8" thick slurry is poured over the steel deck (above the top flange). Min 1" thick Dyplast Carpernter or Cellofoam Holey Board Polystyrene Insulation is placed into the slurry. The following day, a minimum 2" thick top coat is placed. After setting, Celcore PVA Curing Compound is applied at a rate of 300 ft²/gal.
System Type E(5): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: Min. 22 ga., 1.5" type B, Grade 33 galvanized deck attached to supports spaced maximum 5 ft. o.c. with 1/2" puddle welds and washers. Side laps attached using Traxx/1 screws at mid-span. **This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.**

Base Sheet: One ply of HPR Glasbase or HPR Tri-Base Premium is mechanically attached using Trufast FM-90 Base Sheet Fastener or OMG CR Base Sheet Fasteners and plates spaced 7" o.c. in a 3" side lap and 7" o.c. in two rows (evenly spaced between the side laps) in the field of the sheet in line and perpendicular to the laps.

System 1

Ply Sheet: Two plies of HPR Glasbase, HPR Premium Glasbase, HPR Glasfelt, HPR Premium Glasfelt, HPR Polyscrim Plus, fully adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly FR Mineral, StressPly Plus, StressPly Plus FR Mineral or VersiPly Mineral adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

System 2

Ply Sheet: One or more plies of StressBase 80, StressBase 120 or FlexBase 80, FlexBase Plus 80, FlexBase E 80 adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly FR Mineral, StressPly Plus, StressPly Plus FR Mineral or VersiPly Mineral adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

System 3

Ply Sheet: One or more plies of Millennium Base applied in hot coal tar at a rate of 30 lbs./sq. (only when HPR Tri-Base Premium is used).

Membrane: One ply of Millennium FR Mineral applied in hot coal tar at a rate of 30 lbs./sq. (only when HPR Tri-Base Premium is used).



Surfacing:

Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping coal tar at an application rate of 60 lb./sq. or in Black-Knight at 70 lb/sq. or Black-Knight Cold at 5 gal/sq.
2. (Mineral or Smooth Millennium only) Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design**Pressure:**

-45 psf. (See General Limitation #7.)



Membrane Type: SBS/SIS/SEBS
Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Min. 200 psi, Mearlcrete cellular lightweight concrete with min. 40 pcf wet cast density. A 1/8" thick slurry is poured over the concrete deck followed by a minimum 1.5" thick Holey Board EPS Insulation placed into the slurry. A minimum 2" thick top coat is then poured over the EPS insulation.
System Type E(6): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: 2500 psi structural concrete or concrete plank.

Base Sheet: HPR Glasbase, HPR Premium Glasbase or HPR Tri-Base Premium is mechanically fastened with OMG CR Base Sheet Fasteners at 7 in. (178 mm) o.c. in the 4 in. (102 mm) wide lap and in two rows spaced equally between the overlaps and staggered in the field of the sheet.

Base/Ply Sheet: One or more plies of HPR Glasbase, HPR Premium Glasbase, HPR Tri-Base Premium, HPR Glasfelt, HPR Premium Glasfelt or HPR Polyscrim Plus adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly FR Mineral, StressPly Plus, StressPly Plus FR Mineral or VersiPly Mineral adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq.
2. Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design Pressure: -52.5 psf. (See General Limitation #7.)



Membrane Type:	SBS/SIS/SEBS
Deck Type 4:	Lightweight Concrete, Non-insulated
Deck Description:	Min. 200 psi, Mearlcrete cellular lightweight concrete with min. 40 pcf wet cast density. A 1/8" thick slurry is poured over the concrete deck followed by a minimum 1.5" thick Holey Board EPS Insulation placed into the slurry. A minimum 2" thick top coat is then poured over the EPS insulation..
System Type E(7):	Base sheet mechanically fastened.
All General and System Limitations apply.	
Deck:	2500 psi structural concrete or concrete plank.
Base Sheet:	HPR Glasbase, HPR Premium Glasbase or HPR Tri-Base Premium is mechanically fastened with OMG CR Base Sheet Fasteners at 7 in. (178 mm) o.c. in the 4 in. (102 mm) wide lap and in two rows spaced equally between the overlaps and staggered in the field of the sheet.
Ply Sheet:	One more plies of HPR Glasbase, HPR Premium Glasbase, HPR Tri-Base Premium, HPR Glasfelt, HPR Premium Glasfelt adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq. Or One or more plies of HPR Torch Base Sheet torch applied to Base Sheet.
Membrane:	One ply of StressPly IV Mineral, StressPly IV Plus, StressPly IV Plus UV Mineral or StressPly IV Plus Mineral torch applied.
Surfacing:	Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings: <ol style="list-style-type: none"> 1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq. 2. Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat. 3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat. 4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat. 5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq. 6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq. 7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.
Maximum Design Pressure:	-52.5 psf. (See General Limitation #7.)



Membrane Type: SBS/SIS/SEBS

Deck Type 4: Lightweight Concrete, Non-insulated

Deck Description: Min. 300 psi, Celcore cellular lightweight concrete with min. 42 pcf wet cast density; 1/8" thick slurry is poured over the steel deck (above the top flange). Min 1" thick Dyplast Carpernter or Cellofoam Holey Board Polystyrene Insulation is placed into the slurry. The following day, a minimum 2" thick top coat is placed. After setting, Celcore PVA Curing Compound is applied at a rate of 300 ft²/gal.

System Type E(8): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: 2500 psi structural concrete or concrete plank.

Base Sheet: One ply of HPR Glasbase or HPR Tri-Base Premium is mechanically attached using Trufast FM-90 Base Sheet Fastener or OMG CR Base Sheet Fasteners and plates spaced 7" o.c. in a 3" side lap and 7" o.c. in two rows (evenly spaced between the side laps) in the field of the sheet in line and perpendicular to the laps.

System 1

Ply Sheet: Two plies of HPR Glasbase, HPR Premium Glasbase, HPR Glasfelt, HPR Premium Glasfelt, HPR Polyscrim Plus, fully adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly FR Mineral, StressPly Plus, StressPly Plus FR Mineral or VersiPly Mineral adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

System 2

Ply Sheet: One or more plies of StressBase 80, StressBase 120 or FlexBase 80, FlexBase Plus 80, or FlexBase E 80 adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly FR Mineral, StressPly Plus, StressPly Plus FR Mineral or VersiPly Mineral adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

System 3

Ply Sheet: One or more plies of Millennium Base applied in hot coal tar at a rate of 30 lbs./sq. (only when HPR Tri-Base Premium is used).

Membrane: One ply of Millennium FR Mineral applied in hot coal tar at a rate of 30 lbs./sq. (only when HPR Tri-Base Premium is used).

Surfacing: Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping coal tar at an application rate of 60 lb./sq. or in Black-Knight at 70 lb/sq. or Black-Knight Cold at 5 gal/sq.



**Surfacing:
(Continued)**

2. (Mineral or Smooth Millennium only) Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

**Maximum Design
Pressure:**

-75 psf. (See General Limitation #7.)



Membrane Type: SBS/SIS/SEBS

Deck Type 4: Lightweight Concrete, Non-insulated

Deck Description: Min. 400 psi, Concrecel concrete with min. 43 pcf wet cast density; ¼” thick slurry is poured over the steel deck (above the top flange). Min 1” thick Apache Holey Board Polystyrene insulation is tapped into the slurry and allowed to dry overnight. A minimum 2.25” thick Concrecel concrete top coat is applied. After setting, Concrecel Curing Compound is applied at a rate of 600 ft²/gal (14.7 m²/L). Concrecel Bonding Agent spray applied at a rate of 600 ft²/gal (14.7 m²/L) shall be used prior to applying Concrecel concrete when steel decking is used.

System Type E(9): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: 2500 psi structural concrete or concrete plank.

Or

22 ga., type B, Grade 33 galvanized, slotted steel decking attached to supports spaced maximum 5 ft. o.c. with 5/8” puddle welds spaced 6” o.c. Side laps attached using Traxx/1 screws at mid-span.

This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

Base Sheet: One ply of HPR Tri-Base Premium mechanically attached using CR assembled base sheet fasteners (1.7 in.), CR Base sheet disc and CR Base Sheet Fasteners (1.7 in.) or Trufast FM-90 Base Sheet Fastener applied at maximum 7” o.c. in a 3" side lap and 7" o.c. in two evenly spaced rows in the field of the sheet.

System 1

Ply Sheet: Two plies of HPR Glasbase, HPR Premium Glasbase, HPR Glasfelt, HPR Premium Glasfelt or HPR Poly scrim Plus fully adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly FR Mineral, StressPly Plus, StressPly Plus FR Mineral or VersiPly Mineral adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

System 2

Ply Sheet: One or more plies of Millennium Base applied in hot coal tar at a rate of 30 lbs./sq.

Membrane: One ply of Millennium FR Mineral applied in hot coal tar at a rate of 30 lbs./sq.



Surfacing:

Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping coal tar at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq.
2. (Mineral or Smooth Millennium only) Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design

Pressure: -82.5 psf. (See General Limitation #7.)



Membrane Type: SBS/SIS/SEBS
Deck Type 4: Lightweight Concrete, Non-insulated
Deck Description: Minimum 400 psi, min. 2.25" thick, min. 43 pcf wet cast density, Concrecel concrete is applied followed by Concrecel Curing Compound at a rate of 600 ft²/gal (14.7 m²/L).
System Type E(10): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: 2500 psi structural concrete or concrete plank.

Base Sheet: One ply of HPR Tri-Base Premium mechanically attached using CR assembled base sheet fasteners (1.7 in.), CR Base sheet disc and CR Base Sheet Fasteners (1.7 in.) or Trufast FM-90 Base Sheet Fastener applied at maximum 7" o.c. in a 3" side lap and 7" o.c. in two evenly spaced rows in the field of the sheet.

System 1
Ply Sheet: Two plies of HPR Glasbase, HPR Premium Glasbase, HPR Glasfelt, HPR Premium Glasfelt or HPR Polyscrim Plus fully adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly FR Mineral, StressPly Plus, StressPly Plus FR Mineral or VersiPly Mineral adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

System 2
Ply Sheet: One or more plies of Millennium Base applied in hot coal tar at a rate of 30 lbs./sq.

Membrane: One ply of Millennium FR Mineral applied in hot coal tar at a rate of 30 lbs./sq.

Surfacing: Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping coal tar at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq.
2. (Mineral or Smooth Millennium only) Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design Pressure: -82.5 psf. (See General Limitation #7.)



NOA No.: 24-1114.05
Expiration Date: 12/02/29
Approval Date: 12/19/24
Page 27 of 32

Membrane Type: SBS/SIS/SEBS

Deck Type 4: Lightweight Concrete, Non-insulated

Deck Description: 38 – 42 pcf wet cast density; 1/8” thick slurry of Celcore MF Cellular lightweight concrete, Min. 330 psi, with Celcore HS Rheology Modifying Admixture is poured over the steel deck (above the top flange). Min 1” thick Insulfoam EPS holey board is placed, in a brick-like pattern, into the slurry, followed by a minimum 2” thick layer of Celcore MF Cellular lightweight concrete, min. 350 psi, with Celcore HS Rheology Modifying Admixture. The following day a Celcore PVA Curing Compound is sprayed applied at a minimum rate of 0.5 gallons per 100 ft².

System Type E(11): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: 22 ga., type B, Grade 33, galvanized, secured to supports spaced maximum 5 ft. o.c. with ½” puddle welds at the bottom of each corrugation. Steel deck side laps attached using three evenly spaced ITW-Buildex fasteners between supports (15”, 30” and 45”).
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

Base Sheet: One ply of HPR Tri-Base Premium mechanically attached using Trufast FM-90 Base Sheet Fasteners applied at 8” o.c. in a 4” wide lap and 8” o.c in three evenly spaced rows between the laps.

Ply Sheet: One or more plies of HPR Torch Base Sheet torch applied with a minimum 4” lap.

Membrane: One ply of StressPly IV Mineral or StressPly IV Plus UV Mineral torch applied with a minimum 4” lap.

Surfacing: Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping coal tar at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq.
2. (Mineral or Smooth Millennium only) Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design Pressure: -90 psf. (See General Limitation #7.)



NOA No.: 24-1114.05
Expiration Date: 12/02/29
Approval Date: 12/19/24
Page 28 of 32

Membrane Type: SBS/SIS/SEBS

Deck Type 4: Lightweight Concrete, Non-insulated

Deck Description: 38 – 42 pcf wet cast density; 1/8” thick slurry of Celcore MF Cellular concrete, min. 330 psi, with Celcore HS Rheology Modifying Admixture is poured over the steel deck (above the top flange). Min 1” thick Insulfoam EPS holey board is placed, in a brick-like pattern, into the slurry, followed by a minimum 2” thick layer of Celcore MF Cellular concrete, min. 330 psi, with Celcore HS Rheology Modifying Admixture. The following day a Celcore PVA Curing Compound is sprayed applied at a minimum rate of 0.5 gallons per 100 ft².

System Type E(12): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: 22 ga., type B, Grade 33, galvanized, secured to supports spaced maximum 5 ft. o.c. with ½” puddle welds at the bottom of each corrugation. Steel deck side laps attached using three evenly spaced ITW-Buildex fasteners between supports (15”, 30” and 45”).
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

Base Sheet: One ply of VersiPly 40 Base mechanically attached using Trufast FM-90 Base Sheet Fasteners applied at 8” o.c. in a 4” wide lap and 8” o.c in three evenly spaced rows between the laps.

Ply Sheet: One or more plies of StressBase 80, StressBase 120 or FlexBase 80, FlexBase Plus 80, or FlexBase E 80 adhered with a minimum 4” lap in a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq. or Green-Lock Plus Membrane Adhesive at a min rate of 2 gal/sq.

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly Plus FR Mineral or VersiPly Mineral with a minimum 4” lap adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-25 lbs/sq. or Green-Lock Plus Membrane Adhesive at a min rate of 2 gal/sq.



Surfacing:

Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping coal tar at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq.
2. (Mineral or Smooth Millennium only) Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design

Pressure: -90 psf. (See General Limitation #7.)



Membrane Type: SBS/SIS/SEBS

Deck Type 4: Lightweight Concrete, Non-insulated

Deck Description: 38 – 42 pcf wet cast density; 1/8” thick slurry of Celcore MF Cellular lightweight concrete, min. 320 psi, with Celcore HS Rheology Modifying Admixture is poured over the steel deck (above the top flange). Min 1” thick Insulfoam EPS holey board is placed, in a brick-like pattern, into the slurry, followed by a minimum 2” thick layer of Celcore MF Cellular lightweight concrete, min. 290 psi, with Celcore HS Rheology Modifying Admixture. The following day a Celcore PVA Curing Compound is sprayed applied at a minimum rate of 0.5 gallons per 100 ft².

System Type E(13): Base sheet mechanically fastened.

All General and System Limitations apply.

Deck: 22 ga., type B, Grade 33, galvanized steel, secured to supports spaced maximum 5 ft. o.c. with ½” puddle welds at the bottom of each corrugation. Steel deck side laps attached using three evenly spaced ITW-Buildex fasteners between supports (15”, 30” and 45”).
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

Base Sheet: One ply of HPR Tri-Base Premium mechanically attached using Trufast FM-90 Base Sheet Fasteners applied at 8” o.c. in a 4” wide lap and 8” o.c in three evenly spaced rows between the laps.

Ply Sheet: Two or more plies of HPR Glasfelt, HPR Premium Glasfelt, HPR Polyscrim Plus fully adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of StressPly E FR Mineral, StressPly EUV FR Mineral, StressPly Plus FR Mineral or VersiPly Mineral with a minimum 4” lap adhered with a full mopping of approved asphalt, HPR All Temp Asphalt or Garlastic KM Plus within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: Optional for FR or mineral surfaced Membranes. Required for non-FR or smooth surfaced membranes. Apply one of the below or any approved coatings:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping coal tar at an application rate of 60 lb./sq. or in Black-Knight at 70 lb./sq. or Black-Knight Cold at 5 gal/sq.
2. (Mineral or Smooth Millennium only) Minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
3. Energizer K Plus FR applied at 3.5 gal/sq with minimum two coats of Garla-Brite applied at min 0.5 gal/sq/coat.
4. WeatherScreen applied at min. 4 gal./sq. with minimum two coats of Garla-Brite applied at min. 0.5 gal/sq/coat.
5. WeatherScreen applied at min. 4 gal./sq. with #11 roofing granules at 60 lb./sq.
6. WeatherScreen applied at applied at min. 4 gal./sq. with roofing gravel applied at 400 lb./sq.
7. Green-Lock Plus Membrane Adhesive applied at min 3-5 gal./sq. with roofing gravel applied at 400 lb./sq.

Maximum Design Pressure: -90 psf. (See General Limitation #7.)



NOA No.: 24-1114.05
Expiration Date: 12/02/29
Approval Date: 12/19/24
Page 31 of 32

LIGHTWEIGHT CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117; calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 24-1114.05
Expiration Date: 12/02/29
Approval Date: 12/19/24
Page 32 of 32