



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

**Carlisle SynTec Systems, a division of Carlisle Construction Materials LLC.
1285 Ritner Highway
Carlisle, PA 17013**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Carlisle Sure-Weld Single Ply TPO Roof Systems over Cementitious Wood Fiber Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 24-0502.03 and consists of pages 1 through 13.
The submitted documentation was reviewed by Alex Tigera.

03/12/26



NOA No: 24-1210.03
Expiration Date: 08/31/29
Approval Date: 03/12/26
Page 1 of 13

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Single Ply
Material:	TPO
Deck Type:	Cementitious Wood Fiber
Maximum Design Pressure	-322.5 psf
Fire Classification:	See General Limitation #1

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product Name</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Sure-Weld	various	TAS 131	Reinforced white or colored, 45-mil or 60-mil thick, TPO membrane.
Sure-Weld EXTRA	various	TAS 131	Reinforced white or colored, 80-mil thick, TPO membrane.
Sure-Weld HS	various	TAS 131	Reinforced white or colored, 45-mil, 60-mil or 80-mil thick, TPO membrane.
Sure-Weld AFX 120	Various	TAS 131	Reinforced white or colored, 120-mil thick, TPO membrane with fleece backing.
Sure-Weld AFX 135	Various	TAS 131	Reinforced white or colored, 135-mil thick, TPO membrane with fleece backing.
Sure-Weld AFX 155	Various	TAS 131	Reinforced white or colored, 155-mil thick, TPO membrane with fleece backing.
Sure-Weld FleeceBACK 100	various	TAS 131	Reinforced white or colored, 100-mil thick, TPO membrane with fleece backing.
Sure-Weld FleeceBACK 115	various	TAS 131	Reinforced white or colored, 115-mil thick, TPO membrane with fleece backing.
Sure-Weld FleeceBACK 135	various	TAS 131	Reinforced white or colored, 135-mil thick, TPO membrane with fleece backing.



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product Name</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Sure-Weld Pressure Sensitive RUSS	various	TAS 131	TPO Reinforced Universal Securement Strip.
Aqua Base 120 Bonding Adhesive	Various	TAS 110	Water-based bonding adhesive
Carlisle OlyBond 500 BA	Various	TAS 110	Two-part, low-rise polyurethane adhesive
Carlisle Sure MB MC Adhesive	Various	TAS 110	Asphalt-Modified Polyether Adhesive
Flexible FAST 5-Gallon Jug Adhesive	5-gal. Box	TAS 110	Two-part, low-rise polyurethane adhesive
Flexible FAST Dual Cartridge Adhesive	Per carton - 4 cartridge sets	TAS 110	Two-part, low-rise polyurethane adhesive
Flexible FAST Dual Tank Adhesive	Per carton - 4 cartridge sets	TAS 110	Two-part, low-rise polyurethane adhesive
Flexible FAST Adhesive	15 & 50-gal. drum	TAS 110	Two-part, low-rise polyurethane adhesive
HydroBond Adhesive	5-gal. pail		Water-based bonding adhesive
Sure-Weld Bonding Adhesive	5-gal. pail	TAS 110	Solvent-based bonding adhesive.
Sure-Weld Low VOC Bonding Adhesive	5-gal. pail	TAS 110	Low VOC solvent based bonding adhesive



APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
StormBase	Polyisocyanurate roof insulation.	Carlisle Syntec, a div of Carlisle construction Materials, LLC.
InsulBase	Polyisocyanurate roof insulation.	Carlisle Syntec, a div of Carlisle construction Materials, LLC.
SecurShield	Polyisocyanurate foam core with a coated glass facer.	Carlisle Syntec, a div of Carlisle construction Materials, LLC.
SecurShield HD	Polyisocyanurate foam core and high-density cover board	Carlisle Syntec, a div of Carlisle construction Materials, LLC.
SecurShield HD Composite	Polyisocyanurate foam core with a coated glass facer.	Carlisle Syntec, a div of Carlisle construction Materials, LLC.
H-Shield, H-Shield NB, H-Shield CG, H-Shield HD	Isocyanurate Insulation	Hunter Panels, a div of Carlisle construction Materials, LLC.
H-Shield HD Composite CG	Polyisocyanurate foam core with a coated glass facer.	Hunter Panels, a div of Carlisle construction Materials, LLC.
Insulfoam EPS, InsulFoam SP, InsulFoam R-TECH	Expanded polystyrene	Insulfoam, a Div. of Carlisle Const. Materials

APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	N/A	N/A	N/A	N/A



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Architectural Testing Inc.	ATI-37490.01	Membrane Brittleness Testing	7/7/00
Factory Mutual Research Corp.	3Z9A1.AM	Wind Uplift Classification	10/15/97
	Approval Guide Excerpt	Wind Uplift Classification	5/00
	3003337	Class 4470	06/11/99
	3011220	Class 4470	08/16/01
	3012879	Class 4470	04/04/03
	30013584	Class 4470	
Celotex Corporation Testing Services	520257	Membrane Physical Property Testing	4/19/00
SGS U.S. Testing Company Incorporated	131248-R2	Membrane Ozone Resistance Testing	1/6/00
Trinity ERD	C46470.07.14-1A	TAS 131	07/16/14
	C46470.07.14-1B	TAS 131	07/16/14
	C46470.07.14-2A	TAS 131	07/30/14
	C46470.07.14-4-R1	TAS 131	07/21/14
	4r-CRL-20-SSTHP-.02.D	TAS 131	04/27/21
	4r-CRL-20-SSTHP-.02.C	TAS 131	04/27/21
	4-CRL-18-002.04.18-2A	TAS 131	04/30/18
	4r-CRL-20-SSTHP-02.B.R2	TAS 131	04/27/21
	4r-CRL-20-SSTHP-.02.A	TAS 131	04/27/21
	4r-CRL-20-SSTHP-.03.A	TAS 131	04/27/21



APPROVED ASSEMBLIES

- Membrane Type:** Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK
- Deck Type 5I:** Cementitious Wood Fiber, Insulated
- Deck Description:** Minimum 2” thick Tectum Panel secured to ¼” thick supports at a maximum spacing of 3ft o.c. secured with two #14 Dekfast fasteners and 2” diameter metal plates per panel per support.
- System Type A(1):** One or more layers of insulation adhered with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive. Membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite CG, StormBase, H-Shield NB Minimum 1” thick	N/A	N/A

Note: All insulation shall be adhered to the deck with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive at minimum rate 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: None.

Barrier: None.

Membrane Fastening Option #1: Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive (applied to the substrate at a rate of 1 gal/sq., full coverage Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
 Or
 Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 120 ft²/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
 Or
 Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using HydroBond Water-Based Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 100 ft²/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -120 psf. (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Minimum 2” thick Tectum Panel secured to ¼” thick supports at a maximum spacing of 3ft o.c. secured with two #14 Dekfast fasteners and 2” diameter metal plates per panel per support.
System Type A(2): One or more layers of insulation adhered with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive. Membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite CG, StormBase, H-Shield NB Minimum 1” thick	N/A	N/A

Note: All insulation shall be adhered to the deck with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive at minimum rate 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: None.

Barrier: None.

Membrane Fastening Option #2: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
 Or
 Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 120 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -90 psf. (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Minimum 2” thick Tectum Panel secured to ¼” thick supports at a maximum spacing of 3ft o.c. secured with two #14 Dekfast fasteners and 2” diameter metal plates per panel per support.
System Type A(3): One or more layers of insulation adhered with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive. Membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite CG, StormBase, H-Shield NB Minimum 1” thick	N/A	N/A

Note: All insulation shall be adhered to the deck with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive at minimum rate 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: None.

Barrier: None.

Membrane Fastening: Sure-Weld AFX 120, 135, of 155 membrane adhered to the insulation using SureMB MC Adhesive. The adhesive is applied to the substrate only at a rate of 67 ft²/ Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -120 psf. (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Minimum 2” thick Tectum Panel secured to ¼” thick supports at a maximum spacing of 3ft o.c. secured with two #14 Dekfast fasteners and 2” diameter metal plates per panel per support.
System Type A(4): One or more layers of insulation adhered with Olybond 500 BA. Membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite CG StormBase, H-Shield NB Minimum 1” thick	N/A	N/A

Note: All insulation shall be adhered to the deck with Carlisle Olybond 500 BA in applied in ribbons 12”o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: None.

Barrier: None.

Membrane Fastening Option #1: Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using, Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate at a rate of 1 gal/sq., full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld
 Or
 Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 120 ft²/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
 Or
 Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using HydroBond Water-Based Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 100 ft²/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.



**Membrane
Fastening
Option #2:**

Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Or

Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 120 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

**Maximum Design
Pressure:**

-45 psf. (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Cementitious Wood Fiber
System Type A(5): One or more layers of insulation adhered with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive or Flexible FAST Dual Tank Adhesive.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite CG, or StormBase or H-Shield NB Minimum 1” thick	N/A	N/A

Note: All insulation shall be adhered to the deck with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive or Flexible FAST Dual Tank Adhesive applied in ½” to ¾” ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in ½” to ¾” ribbons spaced 12” o.c. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
 Or
 Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 120 ft²/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld
 Or
 Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using HydroBond Water-Based Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 100 ft²/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -322.5 psf (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Cementitious Wood Fiber
System Type A(6): One or more layers of insulation adhered with, Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive or Flexible FAST Dual Tank Adhesive. Membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Insulfoam SP Minimum 1" thick	N/A	N/A

Note: All insulation shall be adhered to the deck with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive or Flexible FAST Dual Tank Adhesive applied in 1/2" to 3/4" ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in 1/2" to 3/4" ribbons spaced 12" o.c. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -202.5 psf (See General Limitation #9)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



11. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No: 24-1210.03
Expiration Date: 08/31/29
Approval Date: 03/12/26
Page 13 of 13