



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Tag and Stick, LLC
3771 NW 126 Avenue
Coral Springs, FL. 33065

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Tag & Stick MTP Anchor/Base Sheet

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 19-1030.07 and consists of pages 1 through 4.
The submitted documentation was reviewed by Jorge L. Acebo.

02/20/25



NOA No.: 25-0123.01
Expiration Date: 02/27/30
Approval Date: 02/20/25
Page 1 of 4

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Materials: SBS

SCOPE:

This acceptance is for **Tag & Stick MTP Anchor/Base Sheet**, as described in this Notice of Acceptance, for use with approved prepared roof assemblies wherever a ASTM D1970 and/or ASTM D4601 roof membrane is specified and installed with prescribed approved adhesives, fasteners and fastener densities, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

PRODUCT DESCRIPTION

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Tag & Stick MTP	Width = 36" Length = 66.8' (200 sq.ft.)	ASTM D1970 ASTM D4601	A fiberglass reinforced SBS modified bitumen membrane with an 18-inch selvage edge, an 18-inch woven fabric top surface to form a 36" wide roll. The underside of the 18-inch woven fabric is a self-adhering modified bitumen with a removable silicone release film. The product design allows for mechanical attachment of the 18-inch selvage edge (base layer of membrane) followed by a self-adhering top layer membrane, (the woven fabric top surface), resulting in a two-ply Anchor/Base Sheet underlayment, within the same roll.

MANUFACTURING LOCATION

1. Tuscaloosa, AL.

EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Report Identifier</u>	<u>Test Name</u>	<u>Date</u>
Trinity ERD	E40480.03.12-R2	TAS 117 (B)/TAS 114 (C)	03/01/12
NEMO ETC, LLC.	4q-TAG-19-SSMBB-01.A 4j-TAG-22-SSUDL-01.A	ASTM D4601 ASTM D1970	10/03/19 02/23/23



NOA No.: 25-0123.01
Expiration Date: 02/27/30
Approval Date: 02/20/25
Page 2 of 4

APPROVED ASSEMBLIES:

Deck Type 1:	Wood, non-insulated
Deck Description:	19/32-inch or greater plywood or wood plank for new constructions and 15/32-inch or greater plywood or wood plank for reroof constructions.
Anchor/Base Sheet:	Tag & Stick MTP underlayment System
Fastening:	See Installation Procedure Below
Surfacing:	Approved asphaltic shingles, metal roof systems, wood shakes and shingles and quarry slate. Tile Roofing is not an approved roof covering for use with this assembly.

INSTALLATION PROCEDURES

Starter Course:	Apply 18-inch wide Half Sheet (the nailable portion of the Tag & Stick MTP) parallel to the eave and fasten 12-inch o.c. at a row within 2-inches of the top edge, 12-inch o.c. at a row 9-inch from the top edge off set six inches from the other row of fasteners and 6-inch wide end (vertical) laps. Tack-down the eave edge sufficiently to hold in place prior to installation of the edge metal detail. See details herein.
Subsequent Courses:	Align and apply subsequent courses overlapping the previous course or starter course with the 18-inch wide self-adhering portion of the sheet. Fasten nailable portion 12-inch o.c. at a row within 2-inches of the top edge of the sheet, 12-inch o.c. at a row within 2-inches of the lap-line (surface fabric) and 12-inch o.c. at one row centered between the top and bottom rows. Remove plastic release film and step-in / roll-in in accordance with Tag & Stick, LLC published instructions. See details herein.
Surfacing:	Approved Roofing Assembly as specified in their NOA approval.

LABELING

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



BUILDING PERMIT REQUIREMENTS

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or the applicable code in order to properly evaluate the installation of this system.



NOA No.: 25-0123.01
Expiration Date: 02/27/30
Approval Date: 02/20/25
Page 3 of 4

LIMITATIONS:

1. Fire classification is not part of this acceptance. Refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Tag & Stick MTP is designed for roofs having a minimum slope of 2:12.
3. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code. Tag & Stick MTP shall be installed in strict compliance with applicable Building Codes, Product Approvals and Manufacturers' specifications and guidelines.
4. Change in materials or manufacturing process or location of Tag & Stick MTP shall be cause for termination of this Notice of Acceptance.
5. Tag & Stick MTP shall be applied to a smooth, clean and dry surface with deck free of irregularities.
6. Tag & Stick MTP shall not be applied over an existing roof membrane.
7. Tag & Stick MTP may be used with any approved roof covering Notice of Acceptance listing Tag & Stick MTP as a component part of an assembly in the Notice of Acceptance. If Tag & Stick MTP is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval, provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
8. All nails in the deck shall be carefully checked for protruding heads. Re-fasten any loose decking panels. Sweep the deck thoroughly to remove any dust and debris prior to application. Install when temperatures are 45° F and rising.
9. Roll or broom the entire membrane surface so as to have 100% contact with the surface, giving special attention to overlap areas.
10. Flash vent pipes, stacks, chimneys and penetration in compliance with Roof Assembly current Product Control Notice of Acceptance and applicable Building Code.
11. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 25-0123.01
Expiration Date: 02/27/30
Approval Date: 02/20/25
Page 4 of 4