



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Westlake Royal Roofing LLC
2801 Post Oak, Suite 600
Houston, TX. 77056

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Westlake Royal Roof Mastic

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Alex Tigera.

05/08/25



NOA No.: 25-0414.02
Expiration Date: 09/13/26
Approval Date: 05/08/25
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cements and Coatings
Materials: Asphalt

SCOPE:

This approves **Westlake Royal Roof Mastic**, for use on existing roof assemblies, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
UL LLC	R12199	UL 790	06/09/21
PRI Construction Materials Technologies, LLC	KAR-033-02-01	ASTM D 4586	02/09/12
	KAR-034-02-01	ASTM D 4586	02/09/12
	KAR-035-02-01	ASTM D 4586	02/09/12
	KAR-036-02-01	ASTM D 4586	02/09/12
	KAR-037-02-01	ASTM D 4586	02/09/12
	KAR-038-02-01	ASTM D 4586	02/09/12
	KAR-039-02-01	ASTM D 3019	02/15/12
	KAR-040-02-01	ASTM D 4479	02/15/12
	KAR-041-02-01	ASTM D 4479	02/15/12
	KAR-042-02-01	ASTM D 1227	02/15/12
	KAR-046-02-01	ASTM D 1227	02/15/12
	KAR-048-02-01	ASTM D 1227	02/15/12
	KAR-049-02-01	ASTM D 3019	02/15/12
	KAR-050-02-01	ASTM D 3019	02/15/12
	KAR-051-02-01	ASTM D 3019	02/15/12
	KAR-052-02-01	ASTM D 3019	02/15/12
	KAR-055-02-01	ASTM D 2824	04/18/12
	KAR-057-02-01	ASTM D 4479	05/02/12
	KAR-058-02-01	ASTM D 4586	05/02/12
	KAR-070-02-01	ASTM D 4479	05/28/13
	KAR-072-02-01	ASTM D 41	05/28/13
	KAR-073-02-01	ASTM D 2824	08/08/13
	KAR-076-02-01	ASTM D 5895	11/06/13
	KAR-077-02-01	ASTM D 2824	08/21/14
	512T0002	ASTM D 1227	01/09/20
	512T0003	ASTM D 1227	01/09/20

MANUFACTURING LOCATIONS:

1. Ft. Lauderdale, FL



NOA No.: 25-0414.02
Expiration Date: 09/13/26
Approval Date: 05/08/25
Page 2 of 3

INSTALLATION:

Westlake Royal Roof Mastic shall be applied in accordance with manufacturer's Product Data Sheet. For use in roof system approvals, refer to the specific Roofing System's, Product Control Notice of Acceptance for the proper application specifications.

PHYSICAL PROPERTIES OF COMPONENTS

Tradename: Westlake Royal Roof Mastic

Application Rate: This material is applied by trowel to an average thickness of 1/8", approximately 8 gal./sq.ft.

Specifications: ASTM D 4586 type I

Description: Rubber reinforced asbesto-free, wet/dry flashing cement for repairing of leaks in shingles, concrete, metal or asphalt roofs, flashings on walls, chimneys, flues skylight flashings, downspouts and cornices.

Container Sizes: 1, 3, 5 gallons and 10.3 oz. tube. Notice all precautions on container.

Manufacturing Location #2

LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this products.
2. Westlake Royal Roof Mastic shall not be applied in inclement weather conditions.
3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list the products listed herein as part of their Roof Assembly Notice of Acceptance.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test result shall be made available to Miami-Dade Product Control upon request.
5. Change in materials, use or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
6. These roof coatings shall not be applied over, prepared roofing; i.e., fibercement shingles, quarry slate, cement or clay roof tile, metal shingles, wood shingles or shakes.
7. Westlake Royal Roof Mastic shall be used as components within approved roofing systems in accordance with applicable building code. Westlake Royal Roof Mastic is not approved to be used as repair or recover roof systems.
8. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.
9. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency, and shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code. Follow up test results shall be made available to Miami-Dade Product Control upon request.



END OF THIS ACCEPTANCE



NOA No.: 25-0414.02
Expiration Date: 09/13/26
Approval Date: 05/08/25
Page 3 of 3