



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Seaman Corporation
1000 Venture Boulevard
Wooster, OH 44691

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: FiberTite Single Ply Roof Systems over Steel Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA #24-0214.03 and consists of pages 1 through 81.
The submitted documentation was reviewed by Alex Tigera.

01/15/26



NOA No.: 25-0722.05
Expiration Date: 01/05/31
Approval Date: 01/15/26
Page 1 of 81

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply
Material: KEE
Deck Type: Steel
Maximum Design Pressure -112.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
FiberTite SBS 190 TG Base	39" x 33'	ASTM D 6164	SBS modified asphalt coated polyester reinforced base sheet.
FiberTite SBS 190 Base	39" x 33'	ASTM D 6164	SBS modified asphalt coated polyester reinforced base sheet.
FiberTite	Various	ASTM D 6754	KEE, polyester reinforced, single ply membrane
FiberTite FB	Various	ASTM D 6754	KEE, fleece-backed, single ply membrane
FiberTite-SM	Various	ASTM D 6754	KEE, polyester reinforced, single ply membrane
FiberTite-SM FB	Various	ASTM D 6754	KEE, fleece-backed, polyester reinforced, single ply membrane
FiberTite-XT	Various	ASTM D 6754	KEE, polyester reinforced, single ply membrane
FiberTite-XT FB	Various	ASTM D 6754	KEE, fleece-backed, polyester reinforced, single ply membrane
FiberTite-XTreme	Various	ASTM D 6754	KEE, polyester reinforced, single ply membrane
Style 80	Various	ASTM D 6754	KEE, polyester reinforced, single ply membrane
Style 80 FB	Various	ASTM D 6754	KEE, fleece-backed, polyester reinforced, single ply membrane
Style 80-M	Various	ASTM D 6754	KEE, polyester reinforced, single ply membrane
Style 80-M FB	Various	ASTM D 6754	KEE, fleece-backed, polyester reinforced, single ply membrane
Elastoflex S6	39-3/8" x 32'10"	ASTM D 6164	Polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a polyethylene or sanded top surface



NOA No.: 25-0722.05
Expiration Date: 01/05/31
Approval Date: 01/15/26
Page 2 of 81

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
FTR 60-mil Non-Reinforced	0.060" x 48" x 24'	ASTM D 6754	KEE flashing accessory
FTR Cones	1" to 8"	ASTM D 6754	premolded "KEE" pipe flashing
FTR Corners	2' x 2'	ASTM D 6754	premolded "KEE" corner flashing (4 per unit)
FTR 190e	5 gal. pails	Proprietary	Low VOC solvent based "contact" adhesive
FTR 290	5 gal. pails	Proprietary	One side "substrate only" fleece back solvent based adhesive
FTR 490	5 gal. pails	Proprietary	One side "substrate only" fleece backed water based adhesive
FTR 601		Proprietary	Elastomeric, One step foamable adhesive
FTR 601 PG	5 gal. or 50 gal. pails	Proprietary	Two-component, VOC free, polyurethane adhesive
FiberClad	48" x 120"	N/A	Polymeric coated G-90 galvanized steel, stainless steel or aluminum
Tuff Trac	0.080" x 28" or 56" x 43' ¼" x 24" x 48"	N/A	Vinyl walk way Vinyl protection pad
FiberTite Simulated Metal Roof Profile	100' coil	ASTM D 6754	Simulated metal roofing composed of "KEE" compound and adhesive strip.
VaporTite	45" x 133'	Proprietary	A self-adhering air/vapor barrier membrane composed of a SBS modified bitumen adhesive bottom layer and a tri-laminated woven polyethylene top late.
Elastocol Stick	Various	Proprietary	Primer composed of SBS synthetic rubbers, adhesion-enhancing resins and volatile solvents manufactured by Soprema, Inc.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
FTR-Value	Polyisocyanurate insulation	Seaman Corporation
FTR-Value A	Polyisocyanurate insulation	Seaman Corporation
FTR-Value H	Polyisocyanurate insulation	Seaman Corporation
FTR-Value H Glass Facer	Polyisocyanurate insulation	Seaman Corporation
ACFoam-II	Polyisocyanurate insulation	Atlas Roofing Corporation
ACFoam Composite	Polyisocyanurate insulation with perlite facer	Atlas Roofing Corporation
DensDeck	Silicon treated gypsum	Georgia-Pacific Gypsum LLC
DensDeck Prime	Silicon treated gypsum	Georgia-Pacific Gypsum LLC
Ultra-Max	Polyisocyanurate foam insulation	Rmax Operating, LLC
Multi-Max FA-3	Polyisocyanurate foam insulation	Rmax Operating, LLC
Thermarroof Composite-3	Polyisocyanurate/perlite composite insulation	Rmax Operating, LLC
Tapered Thermarroof-3	Polyisocyanurate/perlite composite insulation	Rmax Operating, LLC
SECUROCK Gypsum-Fiber Roof Board	Gypsum Coverboard	USG Corporation
SECUROCK Glass-Mat Roof Board	Gypsum Coverboard	USG Corporation
SECUROCK Cement Roof Board	Gypsum based Coverboard	USG Corporation
H-Shield	Polyisocyanurate insulation	Hunter Panels, a div. of Carlisle Const. Materials
H-Shield CG	Polyisocyanurate insulation	Hunter Panels, a div. of Carlisle Const. Materials
H-Shield WF	Polyisocyanurate insulation	Hunter Panels, a div. of Carlisle Const. Materials
H-Shield NB	Polyisocyanurate insulation	Hunter Panels, a div. of Carlisle Const. Materials
H-Shield HD	Polyisocyanurate insulation	Hunter Panels, a div. of Carlisle Const. Materials



APPROVED INSULATIONS:**TABLE 2**

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
ENRGY 3	Polyisocyanurate insulation	Johns Manville Corporation
ENRGY 3 25 PSI	Polyisocyanurate insulation	Johns Manville Corporation
ENRGY 3 CGF 25 PSI	Polyisocyanurate insulation	Johns Manville Corporation
R-Panel	Polyisocyanurate insulation	Johns Manville Corporation
ValuTherm CGF	Polyisocyanurate insulation	Johns Manville Corporation
ValuTherm CGF 25 PSI	Polyisocyanurate insulation	Johns Manville Corporation
DEXcell FA Glass Mat Roof Board	Gypsum Coverboard	National Gypsum Company a dba of New NGC, Inc
DEXcell Cement Roof Board	Cementitious Coverboard	National Gypsum Company a dba of New NGC, Inc

APPROVED FASTENERS/ADHESIVES:**TABLE 3**

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	FTR Magnum	Membrane fastener	Various	Seaman Corporation
2.	FTR #14	Membrane fastener	Various	Seaman Corporation
3.	FTR Magnum plate	Galvalume AZ50 stress plate	1.5" x 2.5"	Seaman Corporation
4.	FTR Magnum 2 _s	Barbed, galvalume AZ50 stress plate	2-3/8" Dia.	Seaman Corporation
5.	Dekfast PLT-R-2-3/8-6B	Barbed, galvalume AZ50 stress plate	2-3/8" Dia.	SFS Group USA, Inc.
6.	<i>isofast</i> PLT-R-2-3/8-BL plates	Galvalume AZ50 stress plate, #15 belted fasteners	2-3/8" Dia.	SFS Group USA, Inc.
7.	Dekfast DF-#14-PH3	Insulation and membrane fasteners	Various	SFS Group USA, Inc.
8.	Dekfast PLT-H-2-7/8	Galvalume AZ50 steel plate	2 7/8" x 3 1/4"	SFS Group USA, Inc.
9.	OMG Heavy Duty	Self-drilling fastener for use in steel, wood or concrete decks	Various	OMG, Inc.



APPROVED FASTENERS/ADHESIVES:**TABLE 3**

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
10.	OMG 3-in Galvalume Steel Plate	Galvalume coated steel plate	3" round	OMG, Inc.
11.	OMG 3-in Ribbed Galvalume Plate	Galvalume coated steel plate	3" round	OMG, Inc.
12.	Dekfast DF-#15-PH3	Self-drilling, carbon fastener	Various	SFS Group USA, Inc.
13.	Dekfast PLT-O-2-3/4-12B	Oval stress plate	1½" x 2¾"	SFS Group USA, Inc.
14.	FTR Magnum T	#15 threaded fastener	Various	Seaman Corp.
15.	FTR Magnum R275	AZ-55 Galvalume steel stress plate	2.75" round	Seaman Corp.
16.	Trufast #15 EHD fasteners	Insulation fastener for wood, steel and concrete decks	Various	Altenloh, Brinck & Co. U.S., Inc.
17.	Trufast 2-3/4" Barbed Seam Plate (EHD)	AZ-55 Galvalume steel stress plate	2.75" round	Altenloh, Brinck & Co. U.S., Inc.
18.	FTR Magnum Plus	Oval stress plate	1½" x 2¾"	Seaman Corp.
19.	Dekfast PLT-R-3	Galvalume AZ50 stress plate	3" round	SFS Group USA, Inc.
20.	FTR 3-in Steel Plate	Galvalume AZ50 stress plate	3" round	Seaman Corp.
21.	Trufast 3" Metal Insulation Plate	Galvalume AZ50 stress plate	3.23" round	Altenloh, Brinck & Co. U.S., Inc.
22.	Trufast #14 HD Stainless Steel Bi-Metal Fastener	Insulation fastener for steel and wood decks	Various	Altenloh, Brinck & Co. U.S., Inc.
23.	OMG XHD	Self-drilling fastener for use in steel or wood decks	Various	OMG, Inc.
24.	OMG #15 Roofgrip	Carbon steel fastener	Various	OMG, Inc.
25.	FTR Magnum O Fastener	Self-drilling fastener for use in steel or wood decks	Various	Seaman Corporation
26.	<i>isoweld</i> FI-P-6.8-PVC	Galvanized steel plate with PVC coating	3" round	SFS Group USA, Inc.
27.	FTR IW-Plate	Galvanized steel plate with PVC coating	3" round	Seaman Corporation

APPROVED FASTENERS/ADHESIVES:**TABLE 3**

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
28.	OMG #14 Roofgrip	Carbon steel fastener	Various	OMG, Inc.
29.	FTR #14 T	Insulation fastener for steel and wood decks	Various	Seaman Corporation
30.	FTR IPM T	Galvalume AZ50 stress plate	3.23" round	Seaman Corporation
31.	Polyset Commercial Roof Adhesive	A two component elastomeric polyurethane foam adhesive		ICP Construction, Inc.
32.	Millennium One Step Foamable Insulation Adhesive	A two component, low rise, polyurethane foam adhesive		H.B. Fuller Company
33.	Millennium PG-1 Low Viscosity Insulation Adhesive	A two component, low rise, polyurethane foam adhesive		H.B. Fuller Company
34.	OlyBond	A two component polyurethane foam adhesive		OMG, Inc.
35.	OlyBond 500	A two component polyurethane foam adhesive		OMG, Inc.
36.	Polyset Board Max	A two component polyurethane foam adhesive		ICP Construction, Inc.
37.	FTR SBS Adhesive	A single component asphalt modified urethane adhesive	5 gal pail	Seaman Corporation
38.	COLPLY EF Adhesive	A single component polymeric adhesive	5 gal pail 55 gal drum 350 gal tote	SOPREMA, Inc.

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	FM 4470	1Z2A5.AM	01/12/96
	FM 4470	1Z3A8.AM	08/13/97
	FM 4470	3003689	09/22/99
	FM 4470	3003251	10/15/99
	FM 4470	3006872	06/13/00
	FM 4470	3009071	01/03/02
	FM 4470	3014050	07/08/03
	FM 4470	3013125	09/23/03
	FM 4470	3013068	09/23/03
	FM 4470	3023458	07/18/06
	FM 4470	3024311	11/01/06
	FM 4470	3026964	07/25/07
	FM 4470	3028651	04/17/08
	FM 4470	3030785	08/12/08
	FM 4470	3033396	09/04/09
	FM 4470	3037770	10/22/09
	FM 4470	3036192	11/23/09
	FM 4470	3037168	04/12/10
	FM 4470	3038211	06/30/10
	FM 4470	3044075	04/06/12
	FM 4470	3046131	10/17/12
	FM 4470	3045983	10/18/12
	FM 4470	3048494	11/19/13
	FM 4470	3051574	09/11/14
	FM 4470	3051607	03/25/15
	FM 4470	3055227	05/21/15
	FM 4470	3051608	10/23/16
	FM 4470	3061365	10/25/17
	FM 4470	3059662	02/05/19
Underwriters Laboratories	UL 790	98NK12810	08/11/98
	UL 790	98NK17212	08/21/98
	UL 790	12CA39420	01/08/13
Trinity ERD	TAS 114	02843.02.05-08	02/04/05
	TAS 114	4006.08.00-1-R1	10/18/05
	TAS 117 & ASTM D6862	C8500SC.11.07-R1	08/07/09
	TAS 114/117	C12410.08.09	08/14/09
	TAS 114	4006.07.97-1-R1	07/15/10
	TAS 114	4015.10.96-1-R1	07/20/10
	FM 4470 / TAS 114	S32410.09.10	09/21/10
	FM 4470 / TAS 114	S44050.09.13	09/10/13
	ASTM D 6754	S47410.12.14	12/15/14
PRI Construction Materials Technologies LLC	ASTM D 3747	HGC-142-02-03-R1	06/16/16
	FM 4474	SMCP-005-02-01	09/14/15
	ASTM D 6164	SRI-121-02-01	02/01/19
NEMO ETC, LLC.	FM 4474 / TAS 114	SFS-SC10010.02.16-R1	07/06/16

DECK STRESS ANALYSIS CALCULATIONS/REPORTS

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
Robert Nieminen, P.E.	Signed/Sealed Calculations	D(28)	12/11/15
	Signed/Sealed Calculations	C(6), C(8), C(10), C(12)	02/20/20
	Signed/Sealed Calculations	B(11), C(9), C(13), C(17), D(2)	12/27/24
FM Approval Deck Limitation	RoofNav Listing	B(6), B(8), B(9), B(10), B(12) through B(17), C(7), C(10), C(14), C(16), D(1), D(2) through D(7), D(8) through D(12), D(14) through D(27), D(29), D(30)	12/27/24
Zachary Priest, P.E.	Signed/Sealed Calculations	D(13)	09/14/15



APPROVED ASSEMBLIES

Membrane Type:	Single Ply, KEE
Deck Type 2I:	Steel Decks, Insulated
Deck Description:	Min. 18-22 ga. steel deck
System Type B(1):	Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, AC Foam-II, H-Shield, ENRGY 3, Multi-Max FA-3 Minimum 1.5" thick	1, 2, 7, 12 with 8	1:2 ft²
DensDeck, DensDeck Prime Minimum 1/4" thick	1, 2, 7, 12 with 8	1:2 ft²

Note: Insulation layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Membrane: FiberTite-SM, FiberTite-XTreme or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied to substrate and cover at 100 ft² per 1 gal.

Or

FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered to the insulation with FTR-490 water based adhesive at 100 ft² per 1 gal.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: Min. 18-22 ga. steel deck
System Type B(2): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum 0.5" thick	2 with 20; 9, 23, 24, 25 with 10; 7 with 19	1:4 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Vapor Barrier: VaporTite, self-adhered over SECUROCK Gypsum-Fiber Roof Board.
(Optional)

<u>Middle Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, ENRGY-3 Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: Apply insulation layer in a ¾" to 1" wide beads 12" o.c. of FTR 601 or FTR 601 PG or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.



Membrane: FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered with approved asphalt at 20-25 lbs./sq. or FTR-290 solvent adhesive at 100 ft² per 1 gal. or FTR-490 water based adhesive at 120 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Or

FiberTite, FiberTite-XT, FiberTite-SM, Style 80, Style 80-M roof cover adhered with FTR-190e Bonding Adhesive applied at an application rate 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -45 psf (See General Limitation #9.)

Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: Min. 18-22 ga. steel deck
System Type B(3): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, AC Foam-II, H-Shield, ENRGY 3 Minimum 2" thick	2 with 20; 9, 25 with 10; 7 with 19	1:2.67 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: Apply top layer of insulation in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 25 lbs/100 ft² or OlyBond Adhesive applied in a full coating application of 100 ft² per 1 gal. or ¾" to 1" wide beads 12" o.c. of FTR 601, FTR 601 PG, OlyBond 500, Millennium One Step Foamable Insulation Adhesive, Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Or

FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., FTR-290 solvent adhesive at 90 ft² per 1 gal. or FTR-490 water based adhesive at 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: Min. 18-22 ga. steel deck
System Type B(4): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ACFoam-II, H-Shield, ENRGY 3		
Minimum 1.5" thick	1, 2, with 20; 7, 12 with 19	1:2 ft²
Minimum 2" thick	1, 2, with 20; 7, 12 with 19	1:4 ft²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board		
Minimum 0.25" thick	N/A	N/A

Note: Apply top insulation layer in a full mopping of any approved asphalt within the EVT range and at a rate of 20-25 lbs/sq. or in ½" to ¾" wide beads 12" o.c. of FTR 601 or FTR 601 PG or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Base Sheet: One ply of FiberTite SBS 190 Base fully adhered with approved asphalt at 20-25 lbs./sq.
Membrane: One ply of FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB fully adhered with approved asphalt at 20-25 lbs./sq. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -45 psf (See General Limitation #9.)



Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: Min. 18-22 ga. steel deck
System Type B(5): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ACFoam-II, H-Shield, ENRGY 3		
Minimum 1.5" thick	1, 2, with 20; 7, 12 with 19	1:2 ft²
Minimum 2" thick	1, 2, with 20; 7, 12 with 19	1:4 ft²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board		
Minimum 0.25" thick	N/A	N/A

Note: Apply top insulation layer in a full mopping of any approved asphalt within the EVT range and at a rate of 20-25 lbs/sq. or in ½" to ¾" wide beads 12" o.c. of FTR 601 or FTR 601 PG or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Base Sheet: One ply of FiberTite SBS 190 TG Base, torch-applied.
Ply Sheet: One ply of FiberTite SBS 190 TG Base, torch-applied
(Optional)
Membrane: One ply of FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB fully adhered with approved asphalt at 20-25 lbs./sq. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -45 psf (See General Limitation #9.)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-22 ga., Type B, Grade 33 steel deck secured to minimum ¼" thick structural supports spaced 6' o.c. with Traxx/5 fasteners spaced 6" o.c. along the center of the supports. Deck side laps are secured 24" o.c. with Traxx/1 fasteners.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type B(6): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, AC Foam-II, H-Shield, ENRGY 3 Minimum 2" thick	2 with 21; 10, 30 with 11; 8 with 20; 23 with 22	1:1.33 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: Apply top layer of insulation in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 25 lbs/100 ft² or ¾" to 1" wide beads 6" o.c. of FTR 601, FTR 601 PG, OlyBond 500, Millennium One Step Foamable Insulation Adhesive, Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.



Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Or

FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., FTR-290 solvent adhesive at 90 ft² per 1 gal. or FTR-490 water based adhesive at 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -60 psf (See General Limitation #7.)

Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: 18-22 ga. steel deck
System Type B(7): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value A, ACFoam-II, Multi-Max FA-3, FTR-Value H, H-Shield Minimum 1.5" thick	2 or 7	1:2 ft ²
Minimum 2" thick	2 or 7	1:4 ft ²
DensDeck, DensDeck Prime Minimum 0.25" thick	2 or 7	1:2 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value A, ACFoam-II, Multi-Max FA-3, FTR-Value H, H-Shield Minimum 1.5" thick	N/A	N/A

Note: Apply optional top layer of insulation in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or in ¾" to 1" wide beads 12" o.c. of FTR 601, FTR 601 PG, Millennium One Step Foamable Insulation Adhesive, Millennium PG-1 Low Viscosity Insulation Adhesive or OlyBond Adhesive at application rate of 100 ft² per 1 gal.. Refer to Roofing Application Standard RAS 117 and insulation adhesive manufacturer's Roofing Component Product Control Approval for insulation attachment requirements. Insulations listed as base layer shall be used only as base layers with an optional top layer insulation installed as the final membrane substrate.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft² per 1 gal. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
 Or
 FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., FTR-290 solvent adhesive at 100 ft² per 1 gal. or FTR-490 water based adhesive at 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Membrane Type:	Single Ply, KEE
Deck Type 2I:	Steel Decks, Insulated
Deck Description:	Min. 18-22 ga., Type B, Grade 80 steel deck secured to minimum ¼" thick structural supports spaced 6' o.c. with Traxx/5 fasteners spaced 6" o.c. along the center of the supports. Deck side laps are secured 24" o.c. with Traxx/1 fasteners. This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.
System Type B(8):	Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ACFoam-II, H-Shield, ENRGY 3 Minimum 2.0" thick	2 with 20 or 7 with 19	1:2 ft²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: Top insulation shall be adhered with FTR 601, FTR 601 PG, Millennium One Step Foamable Insulation Adhesive, Millennium PG-1 Low Viscosity Insulation Adhesive, Polyset Board Max in ½" to ¾" wide beads spaced 12" o.c. Refer to Roofing Application Standard RAS 117 and insulation adhesive manufacturer's Roofing Component Product Control Approval for insulation attachment requirements. Insulations listed as base layer shall be used only as base layers with an optional top layer insulation installed as the final membrane substrate.



Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft² per 1 gal. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Or

FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered with approved asphalt at 20-25 lbs./sq., or FTR-290 solvent adhesive at 100 ft² per 1 gal. or FTR-490 water based adhesive at 120 ft² per 1 gal.. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -52.5 psf (See General Limitation #7.)

Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-22 ga., ASTM A653 SS, Grade 33 steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type B(9): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Cement Roof Board, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board, DEXcell Cement Roof Board Minimum 0.5" thick	7 with 19; 2 with 20	1:2 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Primer: Elastocol Stick applied at 200 ft² per 1 gal. (0.2 l/m²).

Vapor Barrier: VaporTite, self-adhered.

<u>Middle Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ENRGY-3, AC Foam-II, H-Shield Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board Minimum 0.25" thick	N/A	N/A

Note: Apply insulation layer in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-25 lbs/100 ft² or in ½" to ¾" wide beads 12" o.c. of FTR 601 or FTR 601 PG or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.



Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft² per 1 gal. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Or

FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered with approved asphalt at 20-25 lbs./sq. or FTR-290 solvent adhesive at 100 ft² per 1 gal. or FTR-490 water based adhesive at 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -52.5 psf (See General Limitation #7.)

Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-22 ga., ASTM A653 SS, Grade 33 steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type B(10): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Cement Roof Board, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board, DEXcell Cement Roof Board Minimum 0.5" thick	7 with 19; 2 with 20	1:2 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Primer: ASTM D41 primer applied at 200 ft² per 1 gal. (0.2 l/m²).

Vapor Barrier: One ply of FiberTite SBS 190 Base fully adhered with approved asphalt at 20-25 lbs./sq.
Or
One ply of FiberTite SBS 190 TG Base, torch-applied.

<u>Middle Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ENRGY-3, ACFoam-II, H-Shield Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board Minimum 0.25" thick	N/A	N/A



Note: Apply insulation layer in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-25 lbs/100 ft² or in ½” to ¾” wide beads 12” o.c. of FTR 601 or FTR 601 PG or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane:	FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft ² per 1 gal. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
	Or
	FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered with approved asphalt at 20-25 lbs./sq. or FTR-290 solvent adhesive at 100 ft ² per 1 gal. or FTR-490 water based adhesive at 100 ft ² per 1 gal. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure:	-52.5 psf (See General Limitation #7.)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 22 ga., Type B, Grade 80 steel deck secured to structural supports spaced 6' o.c. with Traxx/5 fasteners spaced 6" o.c. along the center of the supports. Deck side laps are secured 24" o.c. with Traxx/1 fasteners.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type B(11): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DEXcell FA Glass Mat Roof Board Minimum 0.5" thick	1 with 20	1:1 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Vapor Barrier: Elastoflex S6 fully adhered with FTR SBS Adhesive at 1.5 – 2.0 gal/sq.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value H, H-Shield Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DEXcell FA Glass Mat Roof Board Minimum 0.25" thick	N/A	N/A

Note: All insulation shall be adhered to the vapor barrier in continuous ribbons 6" o.c. of FTR-601. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Base Sheet: Elastoflex S6 fully adhered with FTR SBS Adhesive applied 1.5 – 2.0 gal/sq.



Membrane: FiberTite-SM FB roof cover fully adhered with COLPLY EF Adhesive applied at 1.5 – 2.0 gal/sq. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -60.0 psf (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-22 ga., ASTM A653 SS, Grade 33 steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type B(12): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Cement Roof Board, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board, DEXcell Cement Roof Board		
Fastening #1: Minimum 0.5" thick	7 with 19; 2 with 20	1:1.33 ft ²
Fastening #2: Minimum 0.5" thick	7 with 19; 2 with 20	1:1 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Primer: Elastocol Stick applied at 200 ft² per 1 gal. (0.2 l/m²).

Vapor Barrier: VaporTite, self-adhered.

<u>Middle Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ENRGY-3, ACFoam-II, H-Shield Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board Minimum 0.25" thick	N/A	N/A

Note: Apply insulation layer in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-25 lbs/100 ft² or in ½" to ¾" wide beads 6" o.c. of FTR 601 or FTR 601 PG or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.



Membrane:	FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft ² per 1 gal. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
	Or
	FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered with approved asphalt at 20-25 lbs./sq. or FTR-290 solvent adhesive at 100 ft ² per 1 gal. or FTR-490 water based adhesive at 100 ft ² per 1 gal. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure:	-75.0 psf for Fastening #1 (See General Limitation #7.) -82.5 psf for Fastening #2 (See General Limitation #7.)

Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-22 ga., ASTM A653 SS, Grade 33 steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type B(13): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Cement Roof Board, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board, DEXcell Cement Roof Board		
Fastening #1: Minimum 0.5" thick	7 with 19; 2 with 20	1:1.33 ft ²
Fastening #2: Minimum 0.5" thick	7 with 19; 2 with 20	1:1 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Primer: ASTM D41 primer applied at 200 ft² per 1 gal. (0.2 l/m²).

Vapor Barrier: One ply of FiberTite SBS 190 Base fully adhered with approved asphalt at 20-25 lbs./sq.
Or
One ply of FiberTite SBS 190 TG Base, torch-applied.

<u>Middle Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ENRGY-3, AC Foam-II, H-Shield Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board Minimum 0.25" thick	N/A	N/A



Note: Apply insulation layer in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-25 lbs/100 ft² or in ½” to ¾” wide beads 6” o.c. of FTR 601 or FTR 601 PG or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

- Membrane:**

FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft² per 1 gal. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
- Or

FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered with approved asphalt at 20-25 lbs./sq. or FTR-290 solvent adhesive at 100 ft² per 1 gal. or FTR-490 water based adhesive at 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.
- Maximum Design Pressure:**

-75.0 psf for Fastening #1 (See General Limitation #7.)
-82.5 psf for Fastening #2 (See General Limitation #7.)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-22 ga., ASTM A653 SS, Grade 80 or A1008 SS Grade 80 steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type B(14): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board, DEXcell Cement Roof Board Minimum 0.5" thick	7 with 19; 2 with 20	1:1 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Primer: Elastocol Stick applied at 200 ft² per 1 gal. (0.2 l/m²).

Vapor Barrier: VaporTite, self-adhered.

<u>Middle Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ENRGY-3, AC Foam-II, H-Shield Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board Minimum 0.25" thick	N/A	N/A

Note: Apply insulation layer in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-25 lbs/100 ft² or in ½" to ¾" wide beads 6" o.c. of FTR 601 or FTR 601 PG or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.



Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft² per 1 gal. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Or

FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered with approved asphalt at 20-25 lbs./sq. or FTR-290 solvent adhesive at 100 ft² per 1 gal. or FTR-490 water based adhesive at 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -90 psf (See General Limitation #7.)

Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-22 ga., ASTM A653 SS, Grade 80 or A1008 SS Grade 80 steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type B(15): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Cement Roof Board, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board, DEXcell Cement Roof Board Minimum 0.5" thick	7 with 19; 2 with 20	1:1 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Primer: ASTM D41 primer applied at 200 ft² per 1 gal. (0.2 l/m²).

Vapor Barrier: One ply of FiberTite SBS 190 Base fully adhered with approved asphalt at 20-25 lbs./sq.
Or
One ply of FiberTite SBS 190 TG Base, torch-applied.

<u>Middle Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ENRGY-3, ACFoam-II, H-Shield Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board Minimum 0.25" thick	N/A	N/A



Note: Apply insulation layer in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-25 lbs/100 ft² or in ½” to ¾” wide beads 6” o.c. of FTR 601 or FTR 601 PG or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

- Membrane:**

FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft² per 1 gal. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.
- Or

FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered with approved asphalt at 20-25 lbs./sq. or FTR-290 solvent adhesive at 100 ft² per 1 gal. or FTR-490 water based adhesive at 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.
- Maximum Design Pressure:**

-90 psf (See General Limitation #7.)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-22 ga., ASTM A653 SS, Grade 80 or A1008 SS Grade 80 steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type B(16): Base layer of insulation mechanically attached, top layer adhered; membrane adhered

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Cement Roof Board Minimum 0.5" thick	7 with 19; 2 with 20	1:1 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Primer: Elastocol Stick applied at 200 ft² per 1 gal. (0.2 l/m²).

Vapor Barrier: VaporTite, self-adhered.

<u>Middle Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ENRGY-3, AC Foam-II, H-Shield Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board Minimum 0.25" thick	N/A	N/A

Note: Apply insulation layer in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-25 lbs/100 ft² or in ½" to ¾" wide beads 6" o.c. of FTR 601 or FTR 601 PG or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.



Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 100 ft² per 1 gal. to the backside of the membrane and to the substrate. Laps are sealed with 1.5-inch heat weld.

Or

FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered with approved asphalt at 20-25 lbs./sq. or FTR-290 solvent adhesive at 100 ft² per 1 gal. or FTR-490 water based adhesive at 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -105 psf (See General Limitation #7.)

Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: Min. 18-22 ga. steel deck
System Type C(1): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following.

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ACFoam-II, H-Shield, ENRGY 3 Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	2 with 20; 7 with 8 or 19; 9 with 10; 22 with 21; 29 with 30	1:2 ft²

Note: All layers shall be simultaneously fastened; see top or base layer above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover adhered to the insulation with FTR-190e Bonding Adhesive applied at an application rate of 50 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.
 Or
 FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., FTR-290 solvent adhesive at 90 ft² per 1 gal. or FTR-490 water based adhesive at 100 ft² per 1 gal. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -45 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: Min. 18-22 ga. steel deck.
System Type C(2): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
FTR-Value A, FTR-Value H, FTR-Value H Glass Facer, ACFoam-II, H-Shield, H-Shield CG Minimum 1.5" thick	16 with 21; 14 with 30	1:2 ft²
SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	16 with 21; 14 with 30	1:2 ft²

Note: All layers shall be simultaneously fastened; see top or base layer above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover fully adhered with spatter-applied Polyset Commercial Roof Adhesive. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -45.0 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: Min. 18-22 ga. steel deck
System Type C(3): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ACFoam-II, H-Shield, ENRGY 3 Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime Minimum 0.25" thick	1, 2, with 20; 7, 12 with 19	1:2 ft ²

Note: All layers shall be simultaneously fastened; see top or base layer above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of FiberTite SBS 190 Base fully adhered with approved asphalt at 20-25 lbs./sq.
Membrane: One ply of FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB fully adhered with approved asphalt at 20-25 lbs./sq. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressures: -45 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: Min. 18-22 ga. steel deck
System Type C(4): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ACFoam-II, H-Shield, ENRGY 3 Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Prime Minimum 0.25" thick	1, 2, with 20; 7, 12 with 19	1:2 ft ²

Note: All layers shall be simultaneously fastened; see top or base layer above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of FiberTite SBS 190 TG Base, torch-applied.
Ply Sheet: One ply of FiberTite SBS 190 TG Base, torch-applied
(Optional)
Membrane: One ply of FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB fully adhered with approved asphalt at 20-25 lbs./sq. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressures: -45 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: Min. 22 ga., Type B, Grade 33 steel deck
System Type C(5): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ACFoam-II, H-Shield, ENRGY 3, Multi-Max FA-3 Minimum 1.5" thick	1 with 27, 12 with 26	1:5.33 ft²

Note: All layers shall be simultaneously fastened; see top or base layer above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover shall be bonded to FTR IW-Plates or *isoweld* FI-P-6.8-PVC plates with *isoweld* Induction Bonding Tool. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -45 psf (See General Limitation #9)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-22 ga., Type B, ASTM A653, Grade 80 steel attached to structural steel supports spaced max. 6' o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced 36" o.c.

Or

Min. 18-22 ga., Type B, ASTM A653, Grade 40 steel attached to structural steel supports spaced max. 6' o.c. with 5/8" puddle welds. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced 36" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type C(6): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value A, ACFoam-II Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment prior to the application of approved welding plates and fasteners as outlined below. See membrane description for fastener details. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover shall be bonded to FTR IW-Plates or *isoweld* FI-P-6.8-PVC plates as specified below:

Fastening: Insulation shall be mechanically attached with FTR #14, FTR Magnum fasteners with FTR IW-Plates or Dekfast DF-#14-PH3, Dekfast DF-#15-PH3 with *isoweld* FI-P-6.8-PVC plates spaced 12" o.c. in fastener rows spaced 60" o.c. Membrane shall be bonded to plates with *isoweld* Induction Bonding Tool. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -45 psf (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-22 ga., Type WR, Grade 33 steel attached to structural steel supports spaced max. 6 ft o.c. attached with SFS Intec SD5-#12-HW5/16 fasteners and ¾” steel washers spaced max. 6 in. o.c. Deck side laps secured with SFS Intec SDL-#14-HW5/16 fasteners spaced 24” o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type C(7): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ACFoam-II, H-Shield, ENRGY 3, Multi-Max FA-3 Minimum 1.5” thick	1 with 27; 12 with 26	See Design Pressure

Note: All insulation shall have preliminary attachment prior to the application of approved welding plates and fasteners as outlined below. See membrane description for fastener details. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover shall be bonded to FTR IW-Plates or *isoweld* FI-P-6.8-PVC plates with *isoweld* Induction Bonding Tool. Laps are sealed with 1.5-inch heat weld.

	Maximum Pressure	Fastener Spacing	Fastener Row Spacing
Maximum Design Pressures:	-45 psf (See General Limitation #7)	2 ft	2 ft
	-67.5 psf (See General Limitation #7)	1.5 ft	2 ft
	-82.5 psf (See General Limitation #7)	1.5 ft	1.5 ft



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-22 ga., Type B, Grade 80 steel attached to structural steel supports spaced max. 5 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced 24" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type C(8): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
H-Shield, FTR-Value H Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment prior to the application of approved welding plates and fasteners as outlined below. See membrane description for fastener details. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite 36 mil roof cover shall be bonded to Dekfast DF-#15-PH3 with *isoweld* FI-P-6.8-PVC plates spaced 12" o.c. in fastener rows spaced 60" o.c. Membrane shall be bonded to plates with *isoweld* Induction Bonding Tool. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -52.5 psf (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-22 ga., Type B, Grade 33 steel attached to structural steel supports spaced max. 6 ft o.c. attached with SFS Intec SD5-#12-HW5/16 fasteners and ¾" steel washers spaced max. 6 in. o.c. Deck side laps secured with SFS Intec SDL-#14-HW5/16 fasteners spaced 24" o.c. **This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table**

System Type C(9): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value A, FTR-Value H, ACFoam-II, H-Shield, ENRGY 3, Multi-Max FA-3 Minimum 1.5" thick	1 with 27, 12 with 26	See Design Presure

Note: All insulation shall have preliminary attachment prior to the application of approved welding plates and fasteners as outlined below. See membrane description for fastener details. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover shall be bonded to FTR IW-Plates or *isoweld* FI-P-6.8-PVC plates with *isoweld* Induction Bonding Tool. Laps are sealed with 1.5-inch heat weld.

Fastening: Insulation shall be mechanically attached with FTR Magnum fasteners with FTR IW-Plates or Dekfast DF-#15-PH3 with *isoweld* FI-P-6.8-PVC plates spaced 6" o.c. in fastener rows spaced 60" o.c. Membrane shall be bonded to plates with *isoweld* Induction Bonding Tool. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -60 psf (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-22 ga., Type B, ASTM A653, Grade 80 steel attached to structural steel supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced 36" o.c.

Or

Min. 18-22 ga., Type B, ASTM A653, Grade 40 steel attached to structural steel supports spaced max. 6 ft o.c. attached with 5/8" puddle welds. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced 36" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type C(10): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
FTR-Value A, ACFoam-II Minimum 1.5" thick	1 with 27, 12 with 26	1:3 ft ²

Note: All layers shall be simultaneously fastened; see top or base layer above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover shall be bonded to FTR IW-Plates or *isoweld* FI-P-6.8-PVC plates with *isoweld* Induction Bonding Tool. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -82.5 psf (See General Limitation #7)

Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: Min. 18-22 ga., Type B, Grade 80 steel attached to structural steel supports spaced max. 5 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced 24" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type C(11): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: FiberTite VBX Air and Vapor Barrier Membrane, mechanically attached using FiberTite #14 Heavy Duty Fasteners with FiberTite Magnum-Plus Seam Plates, 24-in. o.c. within the 8-in. wide side laps.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, ENRGY 3 Minimum 1.5" thick	1 with 26	1:1 ft ²

Note: All layers shall be simultaneously fastened; see top or base layer above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite roof cover shall be bonded to *isoweld* FI-P-6.8-PVC plates with *isoweld* Induction Bonding Tool. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -82.5 psf (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-22 ga., Type B, Grade 80 steel attached to structural steel supports spaced max. 5 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced 24" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type C(12): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
H-Shield, FTR-Value H Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment prior to the application of approved welding plates and fasteners as outlined below. See membrane description for fastener details. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite 36 mil roof cover shall be bonded to Dekfast DF-#15-PH3 with *isoweld* FI-P-6.8-PVC plates spaced 6" o.c. in fastener rows spaced 60" o.c. Membrane shall be bonded to plates with *isoweld* Induction Bonding Tool. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -82.5 psf (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-22 ga., Type B (*See Maximum Design Pressure below for steel strength*) steel deck secured to ¼” structural supports spaced 6’ with Traxx/5 fasteners spaced 6” o.c. Deck side laps secured with Traxx/1 fasteners spaced 24” o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type C(13): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Fire Barrier: (*Only if using XPS*) Minimum ¼” thick SECUROCK Gypsum-Fiber Roof Board, DensDeck (Optional) or DensDeck Prime, loose-laid.

One or more layers of the following insulations:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Approved XPS or any approved polyisocyanurate Listed in Table 2 Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum 0.5” thick	22 with 21; 9, 23, 24, 25 with 10; 29 with 30	1:1 ft ²

Note: All layers shall be simultaneously fastened; see top or base layer above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover fully adhered with spatter-applied Polyset Commercial Roof Adhesive. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -82.5 psf (ASTM A653 Grade 33 Steel Deck) (See General Limitation #7.)
-105.0 psf (ASTM A653 Grade 80 Steel Deck) (See General Limitation #7.)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-22 ga., Type B, Grade 80 steel attached to structural steel supports spaced max. 5 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced 30" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table

System Type C(14): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: VaporTite, self-adhered.
(Optional)

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value A, ACFoam-II Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment prior to the application of approved welding plates and fasteners as outlined below. See membrane description for fastener details. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover shall be bonded to FTR IW-Plates or *isoweld* FI-P-6.8-PVC plates as specified below:

Fastening: Insulation shall be mechanically attached with FTR Magnum fasteners with FTR IW-Plates or Dekfast DF-#15-PH3 with *isoweld* FI-P-6.8-PVC plates spaced 6" o.c. in fastener rows spaced 60" o.c. Membrane shall be bonded to plates with *isoweld* Induction Bonding Tool. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -90 psf (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-20 ga., Type B, Grade 33 steel deck secured to structural supports spaced 6' o.c. with Traxx/5 fasteners spaced 6" o.c. Deck side laps secured with Traxx/1 fasteners spaced 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type C(15): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Approved XPS Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum 0.5" thick	21 with 22; 29 with 30	1:1 ft ²

Note: All layers shall be simultaneously fastened; see above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: FiberTite-FB, FiberTite-XT FB, FiberTite-SM FB, Style 80 FB or Style 80-M FB roof cover fully adhered with spatter-applied Polyset Commercial Roof Adhesive. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -97.5 psf (See General Limitation #7.)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 22 ga., Type B, Grade 80 steel deck secured to structural supports spaced 6' o.c. with Traxx/5 fasteners spaced 6" o.c. Deck side laps secured with Traxx/1 fasteners spaced 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type C(16): All layers of insulation simultaneously attached; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value H, H-Shield Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DEXcell FA Glass Mat Roof Board Minimum 0.5" thick	1 with 20	1:1 ft ²

Note: All layers shall be simultaneously fastened; see top layer above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: Elastoflex S6 fully adhered with FTR SBS Adhesive applied 1.5 – 2.0 gal/sq.

Membrane: FiberTite-SM FB roof cover fully adhered with COLPLY EF Adhesive applied at 1.5 – 2.0 gal/sq. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -105 psf (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min. 22 ga., ASTM A653, Grade 80 steel deck attached to structural steel supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(1): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
H-Shield, FTR-Value H Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XT, FiberTite-XT FB, Style 80, Style 80-M, Style 80 FB, Style 80-M FB or FiberTite-XTreme secured through the preliminarily attached insulation with FTR Magnum fasteners and FTR Magnum₂ plates, spaced 6" o.c. within the 6" laps in rows spaced 95" o.c. The side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -45.0 psf (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min. 22 ga., Grade 80, Type B steel deck attached to structural supports spaced max. 7 ft o.c. attached with 5/8" puddle welds spaced max. 6 in. o.c. Deck side laps secured with Tek/1 fasteners spaced max. 18" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(2): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
H-Shield, FTR-Value H, Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XT, FiberTite-XT FB, Style 80, Style 80-M, Style 80 FB, Style 80-M FB or FiberTite-XTreme secured through the preliminarily attached insulation with FTR Magnum fastener with FTR Magnum Plus plates, spaced 6" o.c. within the 5" laps in rows spaced 69" o.c. The side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -45.0 psf (See General Limitation #7).



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: 16-22 ga., ASTM A653, Grade 33 steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(3): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ENRGY 3, FTR-Value Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XT, FiberTite-XT FB, FiberTite-XTreme, Style 80, Style 80-M, Style 80 FB or Style 80-M FB secured through the preliminarily attached insulation with FTR Magnum fastener with FTR Magnum plates or FTR Magnum Plus plates, spaced 12" o.c. within the 5" laps in rows spaced 69" o.c. The side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -45.0 psf (See General Limitation #7).

Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: 18-22 ga., ASTM A653 SS, Grade 80 or A1008 SS Grade 80 steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports (one fastener was installed at each bearing attachment). Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(4): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ENRGY 3, FTR-Value, Multi-Max FA-3, H-Shield, FTR-Value H, ACFoam II, FTR-Value A Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime Minimum 1/4" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XT, FiberTite-XT FB, Style 80, Style 80-M, Style 80 FB, Style 80-M FB or FiberTite-XTreme secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum T fasteners and FTR Magnum R275 stress plates or with Trufast #15 EHD fasteners and Trufast 2-3/4" Barbed Seam Plate (EHD) spaced 12" o.c. within the 6" wide side laps in rows spaced 94" o.c. The roof cover side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -45 psf. (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: 18-22 ga., ASTM A653 Grade 80, steel deck attached to structural steel supports spaced max. 6 ft o.c. attached with 12-24 x 1¼ HWH Impax 45 fasteners spaced max. 6" o.c. at supports. Deck side laps secured 24" o.c. with 14x7/8 HWH Lap-S/D fasteners.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(5): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, FTR-Value A Minimum 1.0" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-XT, FiberTite-XT FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XTreme, Style 80, Style 80-M, Style 80 FB or Style 80-M FB secured through the preliminarily attached insulation as specified below.

Fastening #1: Dekfast DF-#15-PH3 fasteners with Dekfast PLT-O-2-3/4-12B plates, or FTR Magnum fasteners with FTR Magnum Plus plates, spaced 12" o.c. within the 5" laps in rows spaced 95" o.c. The side laps are sealed with a minimum 1.5" heat weld.
Maximum Design Pressure –45.0 psf. (See General Limitation #7)

Fastening #2: Dekfast DF-#15-PH3 fasteners with Dekfast PLT-O-2-3/4-12B plates, or FTR Magnum fasteners with FTR Magnum Plus plates, spaced 6" o.c. within the 5" laps in rows spaced 95" o.c. The side laps are sealed with a minimum 1.5" heat weld.
Maximum Design Pressure -52.5 psf. (See General Limitation #7)

Maximum Design Pressures: See Fastening Options Above



Membrane Type: Single Ply, KEE
Deck Type 2I: Steel Decks, Insulated
Deck Description: 18-22 ga. steel deck
System Type D(6): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value A, AC Foam-II, H-Shield, FTR-Value H Minimum 1" thick	N/A	N/A
ENRGY 3, AC Foam-II, H-Shield, H-Shield WF, H-Shield NB, FTR-Value A, FTR-Value, FTR-Value H Minimum 1.4" thick	N/A	N/A
Ultra-Max, AC Foam Composite, Thermaroom Composite-3, ENRGY-3 Composite Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover attached through the preliminary fastened insulation to the deck as specified below:

Fastening: Fasten with FTR Magnum fasteners and stress plates spaced 12" o.c. through the 3.5" head laps or fastening tabs spaced 51" o.c. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -52.5 psf (See General Limitation #9.)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: 18-22 ga., ASTM A653 SS/A1008 SS Grade 80 Steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports (one fastener was installed at each bearing attachment). Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(7): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ENRGY 3, FTR-Value, Multi-Max FA-3, H-Shield, FTR-Value H, ACFoam-II, FTR-Value A Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime Minimum 1/4" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XT, FiberTite-XT FB, Style 80, Style 80-M, Style 80 FB, Style 80-M FB or FiberTite-XTreme secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum T fasteners and FTR Magnum R275 stress plates or with Trufast #15 EHD fasteners and Trufast 2-3/4" Barbed Seam Plate (EHD) spaced 12" o.c. within the 6" wide side laps in rows spaced 94" o.c. The roof cover side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -45 psf. (See General Limitation #7)



Membrane Type:	Single Ply, KEE
Deck Type 2I:	Steel Decks, Insulated
Deck Description:	Min. 22 ga., ASTM A653 or A1008 SS Grade 80 steel deck secured to structural supports spaced maximum 5 ft o.c.. attached with Traxx/5 fasteners spaced 6" o.c. Deck side laps are secured with Traxx/1 fasteners spaced 30" o.c. This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.
System Type D(8):	Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value H, FTR-Value A, ENRGY 3, ACFoam-II, H-Shield, H-Shield WF, H-Shield NB Minimum 1.5" thick	N/A	N/A
Ultra-Max, ACFoam Composite, Thermarroof Composite-3, ENRGY-3 Composite Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane:	FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.
Fastening:	FTR Magnum fasteners with FTR Magnum 2 _s plates, or Dekfast DF-#15-PH3 fasteners with Dekfast PLT-R-2-3/8-6B or <i>isofast</i> PLT-R-2-3/8-BL, spaced 6" o.c. within the 5" open laps in rows spaced 144.0" o.c., or installed through integral 3-1/2" fastening tab. The outside 1.5" of the lap is heat welded.
Maximum Design Pressures:	-45 psf. (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-22 ga. ASTM A 611, Grade 80 steel deck secured to structural supports spaced maximum 6 ft o.c. fastened with ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with Traxx/1 screws at a maximum spacing of 30 inches o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(9): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value H, FTR-Value A, ENRGY 3, ACFoam-II, H-Shield, H-Shield WF, H-Shield NB Minimum 1.5" thick	N/A	N/A
Ultra-Max, ACFoam Composite, Thermarook Composite-3, ENRGY-3 Composite Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite XT, FiberTite SM, FiberTite XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum fasteners with plates spaced 18" o.c. within the 5" open laps in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.

Maximum Design Pressures: -45 psf. (See General Limitation #7)

Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18-22 ga., (*See Specific Deck type below*) steel deck fastened to steel support at a maximum span of 6' o.c. Steel deck shall be fastened with SFS Intec Impax 5 or ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with SFS Intec ¼-14 Lap Tek or Traxx/1 screws at a maximum spacing of 30 inches o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(10): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value H, FTR-Value A, ENRGY 3, ACFoam-II, H-Shield, H-Shield WF, H-Shield NB Minimum 1.5" thick	N/A	N/A
Ultra-Max, ACFoam Composite, Thermarook Composite-3, ENRGY-3 Composite Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite XT, FiberTite SM, FiberTite XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening #1: (*ASTM A1008/A1008M-01a or A653/A653M-01a SS, Grade 80*) FTR Magnum fasteners with plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 72" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -45 psf. (See General Limitation #7)

Fastening #2: (*Type B, Grade 80*) FTR Magnum fasteners with plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 96" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Maximum Design Pressures: See Fastening Options Above



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 22 ga., ASTM A653 or A1008 SS Grade 80 steel deck secured to structural supports spaced maximum 4 ft o.c. attached with Traxx/5 fasteners spaced 6" o.c. Deck side laps are secured with Traxx/1 fasteners spaced 30" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(11): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value H, FTR-Value A, ENRGY 3, ACFoam-II, H-Shield, H-Shield WF, H-Shield NB Minimum 1.5" thick	N/A	N/A
Ultra-Max, ACFoam Composite, Thermarook Composite-3, ENRGY-3 Composite Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum fasteners with FTR Magnum 2s plates or Dekfast DF-#15-PH3 fasteners with Dekfast PLT-R-2-3/8-6B or *isofast* PLT-R-2-3/8-BL plates, spaced 6" o.c. through the top of the roof cover in rows spaced 144.0" o.c.. Rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab (closed lap configuration) over the fasteners. The edge of tab or both edges of cover strip are heat welded min. 1.5". The outside 1.5" of the lap is heat welded.

Maximum Design Pressures: -52.5 psf. (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 22 ga., Type B, Grade 33 steel deck secured to structural supports spaced maximum 6 ft o.c. attached with 5/8" puddle welds at each flute along intermediate supports. Deck side laps secured 24" o.c. with 14x7/8 HWH fasteners.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(12): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
H-Shield HD Minimum ½" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum fastener with FTR Magnum Plus plates spaced 6" o.c. within the 5" laps in rows spaced 69" o.c. The side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -52.5 psf. (See General Limitation #7)

Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-22 ga., Type B, Grade 33 steel deck fastened to steel support at a maximum span of 6' o.c. Steel deck shall be fastened with SFS Intec Impax 5 or ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with SFS Intec ¼-14 Lap Tek or Traxx/1 screws at a maximum spacing of 30 inches o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(13): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value H, FTR-Value A, ENRGY 3, ACFoam-II, H-Shield, H-Shield WF, H-Shield NB Minimum 1.5" thick	N/A	N/A
Ultra-Max, ACFoam Composite, Thermarook Composite-3, ENRGY-3 Composite Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite XT, FiberTite SM, FiberTite XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum fasteners with plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -60 psf. (See General Limitation #7)

Maximum Design Pressures: See Fastening Options Above



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-20 ga., Grade 33, Type B steel deck or 18-22 ga., Type B, Grade 80 steel deck fastened to steel support at a maximum span of 6' o.c. Steel deck shall be fastened with SFS Intec Impax 5 or ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with SFS Intec ¼-14 Lap Tek or Traxx/1 screws at a maximum spacing of 30 inches o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(14): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
FTR-Value, FTR-Value H, FTR-Value A, ENRGY 3, ACFoam-II, H-Shield, H-Shield WF, H-Shield NB Minimum 1.5" thick	N/A	N/A
Ultra-Max, ACFoam Composite, Thermarook Composite-3, ENRGY-3 Composite Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite XT, FiberTite SM, FiberTite XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening #1: FTR Magnum fasteners with plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Fastening #2: FTR Magnum fasteners with plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -67.5 psf. (See General Limitation #7)

Maximum Design Pressures: See Fastening Options Above



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18-22 ga. Type B, Grade 80 steel deck secured to structural supports spaced maximum 6 ft o.c. fastened with ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with Traxx/1 screws at a maximum spacing of 30 inches o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(15): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value H, FTR-Value A, ENRGY 3, ACFoam-II, H-Shield, H-Shield WF, H-Shield NB Minimum 1.5" thick	N/A	N/A
Ultra-Max, ACFoam Composite, Thermarook Composite-3, ENRGY-3 Composite Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite XT, FiberTite SM, FiberTite XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum fasteners with plates spaced 12" o.c. in the 5" open laps in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.

Maximum Design Pressures: -60 psf. (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min. 22 ga., Type B, Grade 80 steel deck secured to structural supports spaced maximum 4 ft-6 in. o.c. with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(16): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
H-Shield, FTR-Value H Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XT, FiberTite-XT FB, Style 80, Style 80-M, Style 80 FB, Style 80-M FB or FiberTite-XTreme secured through the preliminarily attached insulation using FTR Magnum fastener with FTR Magnum plates or FTR Magnum Plus plates, spaced 6" o.c. within the 6" laps in rows spaced 104.5" o.c. The side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -60.0 psf (See General Limitation #7).



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min 22 ga., Type B, Grade 33 steel deck attached to structural steel supports spaced max. 4 ft-6 in. o.c. with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(17): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ENRGY 3, FTR-Value Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XT, FiberTite-XT FB, FiberTite-XTreme, Style 80, Style 80-M, Style 80 FB or Style 80-M FB secured through the preliminarily attached insulation using FTR Magnum fastener with FTR Magnum plates or FTR Magnum Plus plates, spaced 6" o.c. within the 5" laps in rows spaced 69" o.c. The side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -60.0 psf (See General Limitation #7).



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min. 22 ga. Type B, Grade 80 steel deck attached to structural supports spaced max. 5 ft o.c. with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports (one fastener was installed at each bearing attachment). Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(18): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ENRGY 3, FTR-Value, Multi-Max FA-3, H-Shield, FTR-Value H, ACFoam-II, FTR-Value A Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime Minimum 1/4" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XT, FiberTite-XT FB, Style 80, Style 80-M, Style 80 FB, Style 80-M FB or FiberTite-XTreme secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum T fasteners and FTR Magnum R275 stress plates or with Trufast #15 EHD fasteners and Trufast 2-3/4" Barbed Seam Plate (EHD) spaced 6" o.c. within the 6" wide side laps in rows spaced 94" o.c. The roof cover side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -67.5 psf. (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: 18- 22 ga., Type B, Grade 80 steel deck attached to structural supports spaced maximum 6 ft o.c. with Traxx/5 fasteners spaced 6" o.c. Deck side laps are secured with Traxx/1 fasteners spaced 30" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(19): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value H, FTR-Value A, ENRGY 3, ACFoam-II, H-Shield, H-Shield WF, H-Shield NB Minimum 1.5" thick	N/A	N/A
Ultra-Max, ACFoam Composite, Thermarook Composite-3, ENRGY-3 Composite Minimum 1.5" thick	N/A	N/A

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum fasteners with FTR Magnum 2s plates, or Dekfast DF-#15-PH3 fasteners with Dekfast PLT-R-2-3/8-6B or *isofast* PLT-R-2-3/8-BL plates, spaced 6" o.c. within the 5" open laps in rows spaced 72.0" o.c., or installed through integral 3-1/2" fastening tab. The outside 1.5" of the lap is heat welded.

Maximum Design Pressures: -67.5 psf. (See General Limitation #7)



Membrane: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min. 18-22 ga., Type B, Grade 80 steel deck secured to structural supports spaced 6 ft o.c. with Traxx/5 fasteners spaced 6" o.c. Deck side laps are secured with Traxx/1 fasteners spaced 30" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(20): Membrane fastened over preliminarily secured insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Miami-Dade Approved Lightweight Concrete Minimum 2.0" thick, Minimum 300 psi.	N/A	N/A

Note: Load capacity of the structural substrate must be verified for the additional load of the LWC. The LWC must be properly vented.

Membrane: FiberTite, FiberTite-SM, FiberTite-XT, FiberTite-XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum Fasteners with FTR Magnum 2s plates, Dekfast DF-#15-PH3 fasteners with Dekfast PLT-R-2-3/8-6B or *isofast* PLT-R-2-3/8-BL plates spaced 6" o.c. within the 5" over laps in rows spaced 72.0" o.c., or installed through integral 3-1/2" fastening tab. The outside 1.5" of the lap is heat welded.

Maximum Design Pressure: -67.5 psf. (See General Limitation #7)

Membrane: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min. 18-22 ga., Type B, Grade 33 steel deck secured to structural supports spaced at a maximum span of 6 ft o.c. Steel deck shall be fastened with SFS Intec Impax 5 or ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with SFS Intec 1/4-14 Lap Tek or Traxx/1 screws at a maximum spacing of 30 inches o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(21): Membrane fastened over preliminarily secured insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Miami-Dade Approved Lightweight Concrete Minimum 2.0" thick, Minimum 300 psi.	N/A	N/A

Note: Load capacity of the structural substrate must be verified for the additional load of the LWC. The LWC must be properly vented.

Membrane: FiberTite, FiberTite-SM, FiberTite-XT, FiberTite-XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening #1: FTR Magnum and FTR Magnum plates or FTR Magnum Plus plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Maximum Design Pressure: See Fastening Options Above

Membrane: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min. 18-22 ga., Type B, Grade 80 steel deck secured to steel support at a maximum span of 6 ft o.c. Steel deck shall be fastened with SFS Intec Impax 5 or ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with SFS Intec ¼-14 Lap Tek or Traxx/1 screws at a maximum spacing of 30 inches o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(22): Membrane fastened over preliminarily secured insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Miami-Dade Approved Lightweight Concrete Minimum 2.0" thick, Minimum 300 psi.	N/A	N/A

Note: Load capacity of the structural substrate must be verified for the additional load of the LWC. The LWC must be properly vented.

Membrane: FiberTite, FiberTite-SM, FiberTite-XT, FiberTite-XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening #1: FTR Magnum and FTR Magnum plates or FTR Magnum Plus plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 72" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -45 psf. (See General Limitation #7)

Fastening #2: FTR Magnum and FTR Magnum plates or FTR Magnum Plus plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 96" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Maximum Design Pressure: See Fastening Options Above

Membrane: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min.18-20 ga., Type B, Grade 33 or min. 18-22 ga., Type B, Grade 80 steel deck secured to steel support at a maximum span of 6 ft o.c. Steel deck shall be fastened with SFS Intec Impax 5 or ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with SFS Intec ¼-14 Lap Tek or Traxx/1 screws at a maximum spacing of 30 inches o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(23): Membrane fastened over preliminarily secured insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations.

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
Miami-Dade Approved Lightweight Concrete Minimum 2.0" thick, Minimum 300 psi.	N/A	N/A

Note: Load capacity of the structural substrate must be verified for the additional load of the LWC. The LWC must be properly vented.

Membrane: FiberTite, FiberTite-SM, FiberTite-XT, FiberTite-XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening #1: FTR Magnum and FTR Magnum plates or FTR Magnum Plus plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Fastening #2: FTR Magnum and FTR Magnum plates or FTR Magnum Plus plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -67.5 psf. (See General Limitation #7)

Maximum Design Pressure: See Fastening Options Above

Membrane: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min. 18-22 ga., Grade 80, Type B steel deck secured to steel support at a span of 5 ft or 6 ft o.c. (See Fastening Options Below). Steel deck shall be fastened with ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with Traxx/1 screws at a maximum spacing of 30 inches o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(24): Membrane fastened over preliminarily secured insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Miami-Dade Approved Lightweight Concrete Minimum 2.0" thick, Minimum 300 psi.	N/A	N/A

Note: Load capacity of the structural substrate must be verified for the additional load of the LWC. The LWC must be properly vented.

Membrane: FiberTite, FiberTite-SM, FiberTite-XT, FiberTite-XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening #1: (18-22 ga. steel deck with 6 ft. span) FTR Magnum and FTR Magnum plates or FTR Magnum Plus plates spaced 18" o.c. within the 5" open laps in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -45 psf. (See General Limitation #7)

Fastening #2: (18-22 ga. steel deck with 6 ft. span) FTR Magnum and FTR Magnum plates or FTR Magnum Plus plates spaced 12" o.c. in the 5" open laps in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.
Maximum Design Pressure: -60 psf. (See General Limitation #7)

Fastening #3: (18 ga steel deck with 6 ft span or 20 ga. steel deck with 5 ft span) Fasten with FTR Magnum and FTR Magnum plates or FTR Magnum Plus plates spaced 6" o.c. through the top of the roof cover spaced at maximum intervals of 104.5" Fastener rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab.(closed lap configuration) over the fasteners. The edge of the stripping and/or surface tabs shall be welded a minimum of 1". Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -75 psf. (See General Limitation #7)

Maximum Design Pressure: See Fastening Options Above



Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 18 ga. Type B, Grade 80 steel deck attached to structural supports spaced maximum 6 ft o.c. with ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with Traxx/1 screws at a maximum spacing of 30 inches o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(25): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FTR-Value, FTR-Value H, FTR-Value A, ENRGY 3, ACFoam-II, H-Shield, H-Shield WF, H-Shield NB Minimum 1.5" thick	N/A	N/A
Ultra-Max, ACFoam Composite, Thermarroof Composite-3, ENRGY-3 Composite Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite XT, FiberTite SM, FiberTite XTreme, Style 80 or Style 80-M secured through the preliminarily attached insulation as specified below.

Fastening: Fasten with FTR Magnum fasteners and plates spaced 6" o.c. through the top of the roof cover spaced at maximum intervals of 104.5". Fastener rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab.(closed lap configuration) over the fasteners. The edge of the stripping and/or surface tabs shall be welded a minimum of 1". Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressures: -75 psf. (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel Decks, Insulated

Deck Description: Min. 22 ga., Type B, Grade 80 steel decking placed over minimum 0.25" thick structural supports having maximum 5 ft spans. Deck shall be anchored with ITW Buildex Traxx/4 or Traxx/5 fasteners spaced at maximum 6" o.c. at supports. Deck side laps shall be secured with ITW Buildex Traxx/1 fasteners spaced at a maximum 18" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(26): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: (Optional) Any UL or FM approved vapor barrier applied to the roof deck or over a base layer of insulation.

Fire Barrier: (Optional) Min. ¼" DensDeck or DensDeck Prime attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved polyisocyanurate Listed in Table 2 Minimum 1" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M roof cover attached through the presecured insulation to the deck using FTR Magnum fasteners and plates spaced 6" o.c. through the tabs spaced a maximum of 51" o.c. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressures: -75 psf (See General Limitation #7)

Or

FiberTite TopSider system consisting of FiberTite, FiberTite-XT, FiberTite-SM, FiberTite-XTreme, Style 80 or Style 80-M attached using FTR Magnum fasteners and plates spaced 6" o.c. through the top of the membrane spaced at intervals of 104.5". Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressures: -79.8 psf (See General Limitation #7)

Maximum Design Pressures: See Membrane attachment above.



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: Min. 18 ga., Type B, Grade 80 Steel deck attached to structural supports spaced max. 6 ft o.c. with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(27): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
H-Shield, FTR-Value H Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XT, FiberTite-XT FB, Style 80, Style 80-M, Style 80 FB, Style 80-M FB or FiberTite-XTreme secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum fastener with FTR Magnum plates or FTR Magnum Plus plates, spaced 6" o.c. within the 6" closed laps in rows spaced 94" o.c. The side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -82.5 psf. (See General Limitation #7)



Membrane Type: Single Ply, KEE

Deck Type 2I: Steel, Insulated

Deck Description: 18-22 ga. Type B, Grade 80 Steel deck attached to structural supports spaced max. 6 ft o.c. with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at each rib. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.

System Type D(28): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
H-Shield, FTR-Value H Minimum 1.5" thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: FiberTite, FiberTite-FB, FiberTite-SM, FiberTite-SM FB, FiberTite-XT, FiberTite-XT FB, Style 80, Style 80-M, Style 80 FB, Style 80-M FB or FiberTite-XTreme secured through the preliminarily attached insulation as specified below.

Fastening: FTR Magnum fastener with FTR Magnum plates or FTR Magnum Plus plates, spaced 6" o.c. within the 6" closed laps in rows spaced 47" o.c. The side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressures: -112.5 psf. (See General Limitation #7)

STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., adhered using the adhesives and application rates as reported herein or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE