



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Alpha ProTech Engineered Products, Inc.
301 South Blanchard Street
Valdosta, GA 31601

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Alpha ProTech Underlayments

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises and renews NOA# 23-0817.06 and consists of pages 1 through 4.
The submitted documentation was reviewed by Rafael Macedo.

09/18/25



NOA No.: 25-0729.10
Expiration Date: 10/04/30
Approval Date: 09/18/25
Page 1 of 4

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Polypropylene

SCOPE:

This acceptance is for **Alpha ProTech Underlayments** Roof Underlayment as manufactured by Alpha ProTech Engineered Products, as described in this Notice of Acceptance, for use with approved prepared roof assemblies.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
REX SynFelt;	48" x various length rolls	ASTM D 8257	Woven polypropylene coated with a layer of UV stabilized polypropylene on both sides.
TECHNOply;	48" x various length rolls	ASTM D 8257	Woven polypropylene coated with a layer of UV stabilized polypropylene on both sides.
TECHNO SB 25	48" x various length rolls	ASTM D 8257	Woven polypropylene with a laminated layer of UV stabilized polypropylene spunbound walking surface and polypropylene coating on the non-walking surface.
TECHNO SB 50	48" x various length rolls	ASTM D 8257	Woven polypropylene with a laminated layer of UV stabilized polypropylene spunbound walking surface and polypropylene coating on the non-walking surface.
TECHNO SB ULTRA	48" x various length rolls	ASTM D 8257	Woven polypropylene with a laminated layer of UV stabilized polypropylene spunbound walking surface and polypropylene coating on the non-walking surface.

MANUFACTURING LOCATION:

1. Valdosta, GA



NOA No.: 25-0729.10
Expiration Date: 10/04/30
Approval Date: 09/18/25
Page 2 of 4

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies LLC.	20T0009	ASTM D 8257	08/02/21
	20T0010	ASTM D 8257	06/14/21
	20T0011	ASTM D 8257	07/12/21
	20T0012	ASTM D 8257	07/01/21
	20T0013	ASTM D 8257	06/23/21

APPROVED ASSEMBLIES:

Deck Type 1:	Wood, Non-insulated
Deck Description:	¹⁹ / ₃₂ " or greater plywood or wood plank
System E(1):	Anchor sheet mechanically fastened to deck.
Anchor Sheet:	One or more plies of REX SynFelt; TECHNOply; TECHNO SB 25, TECHNO SB 50, TECHNO SB ULTRA shall be installed with a minimum 4-inch head lap in a shingle layer fashion and be fastened as specified in Florida Building Code, Building volume 1518.2.
Surfacing:	Shall be acceptable for use in approved asphaltic shingles, wood shakes, & shingles, quarry slate and Non-structural metal roof applications. Alpha Protech Underlayments shall not be used as roof tile underlayment. Must Comply with applicable Roofing Application Standards and Building Codes.

Tile Roofing is not an approved roof covering for use with this assembly.



NOA No.: 25-0729.10
Expiration Date: 10/04/30
Approval Date: 09/18/25
Page 3 of 4

LABELING:

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state, and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
3. Alpha Protech Underlayments shall be applied to a smooth, clean and dry surface with deck free of irregularities. All nails in the deck shall be carefully checked for protruding heads. Re-fasten any loose decking panels. Sweep the deck thoroughly to remove any dust and debris prior to application.
4. Alpha Protech Underlayments shall not be hot mopped, refer to manufacturer's published literature for product compatibility.
5. Alpha Protech Underlayments may be used with any approved roof covering Notice of Acceptance listing Alpha Protech Underlayments as a component part of an assembly in the Notice of Acceptance. If Alpha Protech Underlayments are not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
6. REX SynFelt; TECHNOply; TECHNO SB 25, TECHNO SB 50, TECHNO SB ULTRA shall not be left exposed as a temporary roof for longer than 30 days of application.
7. Alpha Protech Underlayments shall not be applied over an existing roof membrane as a recover system.

END OF THIS ACCEPTANCE



NOA No.: 25-0729.10
Expiration Date: 10/04/30
Approval Date: 09/18/25
Page 4 of 4