



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION  
**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Amrize Building Envelope LLC (Elevate)**  
**26 Century Blvd. Suite 205**  
**Nashville, TN, 37214**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Amrize Modified Bitumen Roofing Membranes and Accessories**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA # 25-0109.03 and consists of pages 1 through 7.  
The submitted documentation was reviewed by Alex Tigera.

06/18/26



NOA No.: 25-0917.06  
Expiration Date: 03/13/30  
Approval Date: 06/18/26  
Page 1 of 7

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Roofing Membranes and Accessories  
**Material:** Modified Bitumen Roofing

### SCOPE:

This approves **Amrize Modified Bitumen Roofing Membranes and Accessories** as roofing components, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricanes Zone. Please refer to “Limitations” herein for limits of use.

### PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
BASEGUARD™ SA <i>Manufacturing location #1</i>	39" x 65' 4" (2 sq.)	ASTM D4601, Type II	SBS modified bitumen, polyester reinforced, sand-surfaced base sheet. <b>For use as a base/ply sheet only.</b>
BASEGUARD™ SA <i>Manufacturing location #1</i>	39" x 65' 4" (2 sq.)	ASTM D6163, Type I, Grade S	Glass reinforced modified bitumen membrane coated with a fine-mineral top surface. <b>For use as a cap sheet only.</b>
Elevate MB Base Sheet <i>Manufacturing location #2</i>	39" x 98' 8" (3 sq.)	ASTM D4601, Type I & II	SBS modified bitumen, polyester reinforced, sand-surfaced base sheet.
SBS Base <i>Manufacturing location #1</i>	39" x 50' (1.5 sq.)	ASTM D6163, Type I, Grade S	SBS modified bitumen reinforced with a non-woven fiberglass mat.
SBS Premium Poly Base <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164, Type II, Grade S	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top.
SBS Poly Base <i>Manufacturing location #1</i>	39" x 50' (1.5 sq.)	ASTM D6164, Type I, Grade S	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
SBS Poly Torch Base <i>Manufacturing location #1</i>	39" x 33' 5" (1 sq.)	ASTM D6164, Type I, Grade S	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
APP 80 Glass Base <i>Manufacturing location #1</i>	39" x 65' 4" (2 sq.)	ASTM D6509	Fiberglass reinforced modified bitumen, smooth surfaced base sheet.
APP Premium Base <i>Manufacturing location #1</i>	39" x 65' 4" (2 sq.)	ASTM D6509	Fiberglass reinforced APP modified bitumen, smooth surfaced base sheet.
APP 160 Cool <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6222, Type I, Grade S TAS 110	Polyester reinforced APP modified bitumen, smooth surfaced membrane.
APP 160 <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6222, Type I, Grade S TAS 110	Polyester reinforced APP modified bitumen, smooth surfaced membrane. Torch applied for use as a base or ply sheet only.
APP 170 <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6222, Type I, Grade S TAS 110	Polyester reinforced APP modified bitumen, smooth surfaced membrane.



**PRODUCT DESCRIPTION:**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
APP 170 Cool <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6222, Type I, Grade S	Polyester reinforced modified bitumen, smooth surfaced membrane.
SBS Glass Torch Base <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6163 Type I, Grade S	SBS modified bitumen membrane reinforced with a non-woven fiberglass mat.
SBS Glass Torch Base 1.5 <i>Manufacturing location #1</i>	39" x 50' (1.5 sq.)	ASTM D6163, Type I, Grade S	Glass reinforced modified bitumen membrane coated with a fine-mineral top surface. <b>For use as a cap sheet only.</b>
SBS Torch Base 1.5 HT <i>Manufacturing location #1</i>	39" x 50' (1.5 sq.)	ASTM D6162, Type III, Grade S	SBS modified bitumen base ply with polyester and fiberglass composite reinforcement
SBS Cap <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6164 Type I, Grade G TAS 110	SBS modified bitumen membrane reinforced with a non-woven polyester mat with fiberglass yarns.
SBS Cap UltraWhite <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6164 Type I, Grade G TAS 110	SBS modified bitumen membrane reinforced with a non-woven polyester mat with fiberglass yarns, surfaced with UltraWhite granules.
SBS FR Cap <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6164, Type I, Grade G, TAS 110	SBS modified bitumen membrane, polyester & fiberglass reinforced, with fire-retardant materials.
SBS FR HT <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6162, Type III, Grade G, TAS 110	SBS modified bitumen membrane, polyester & fiberglass reinforced, with fire-retardant materials and granule top surface.
SBS FR Cap UltraWhite <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6164, Type I, Grade G TAS 110	SBS modified bitumen membrane, polyester & fiberglass reinforced, with fire-retardant materials, surfaced with UltraWhite granules.
SBS Smooth <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164 Type I, Grade S	SBS modified bitumen inter-ply membrane enhanced with a non-woven polyester mat with fiberglass strands.
SBS Smooth HT <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6162, Type III, Grade S	SBS modified bitumen ply membrane with polyester and fiberglass composite reinforcement
SBS Torch <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6164 Type I, Grade G TAS 110	SBS modified bitumen membrane reinforced with a non-woven polyester mat with fiberglass yarns.
SBS Torch Base HT <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6162, Type III, Grade S	SBS modified bitumen membrane reinforced with a polyester with fiberglass composite reinforcement.
SBS Torch UltraWhite <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6164 Type I, Grade G TAS 110	SBS modified bitumen membrane reinforced with a non-woven polyester mat with fiberglass yarns, surfaced with UltraWhite granules.



**PRODUCT DESCRIPTION:**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
SBS FR Torch <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6164 Type I, Grade G TAS 110	SBS modified bitumen membrane, polyester & fiberglass reinforced, with fire-retardant materials.
SBS FR Torch HT <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6162, Type III, Grade G TAS 110	SBS modified bitumen cap ply, with polyester and fiber glass composite reinforcement, with fire retardant and topside surfaced with granules
SBS FR Torch UltraWhite <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6164 Type I, Grade G TAS 110	SBS modified bitumen membrane, polyester & fiberglass reinforced, with fire-retardant materials, surfaced with UltraWhite granules.
SBS Glass <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6163, Type I, Grade G TAS 110	Glass reinforced modified bitumen membrane coated with a fine-mineral top surface. <b>For use as a cap sheet only.</b>
SBS Glass FR <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6163, Type I, Grade G TAS 110	Glass reinforced modified bitumen membrane coated with a fine-mineral top surface. <b>For use as a cap sheet only.</b>
SBS Glass FR Torch <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6163, Type I, Grade G TAS 110	Glass reinforced modified bitumen membrane coated with a fine-mineral top surface. <b>For use as a cap sheet only.</b>
SBS Glass FR UltraWhite <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6163, Type I, Grade G TAS 110	Glass reinforced modified bitumen membrane coated with a fine-mineral top surface. <b>For use as a cap sheet only.</b>
SBS Glass FR Torch UltraWhite <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6163, Type I, Grade G TAS 110	Glass reinforced modified bitumen membrane coated with a fine-mineral top surface. <b>For use as a cap sheet only.</b>
APP 180 <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6222, Type I, Grade G TAS 110	Polyester reinforced modified bitumen, granule surfaced membrane. Torch applied.
APP 180 Cool <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6222, Type I, Grade G TAS 110	Polyester reinforced modified bitumen, granule surfaced membrane. Torch applied.
APP 180 UltraWhite <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6222, Type I, Grade G TAS 110	Polyester reinforced modified bitumen, UltraWhite granule surfaced membrane. Torch applied.
APP 180 FR <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6222, Type I, Grade G TAS 110	Polyester reinforced, fire-retardant modified bitumen, granule surfaced membrane. Torch applied.
APP 180 FR Cool <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6222, Type I, Grade G TAS 110	Polyester reinforced APP modified bitumen, smooth surfaced membrane.



**PRODUCT DESCRIPTION:**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
APP 180 FR UltraWhite <i>Manufacturing location #1</i>	39" x 32' 10" (1 sq.)	ASTM D6222, Type I, Grade G TAS 110	Polyester reinforced, fire-retardant modified bitumen, UltraWhite granule surfaced membrane. Torch applied.
SBS Premium <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164, Type II, Grade G TAS 110	Non-woven polyester reinforced modified bitumen membrane with fire retardants, a sanded bottom and mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SBS Premium Torch <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164, Type II, Grade G TAS 110	Non-woven polyester reinforced modified bitumen membrane with fire retardants, a sanded bottom and mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SBS Premium Torch UltraWhite <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164, Type II, Grade G TAS 110	Non-woven polyester reinforced modified bitumen membrane with fire retardants, a sanded bottom and mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SBS Premium FR <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164, Type II, Grade G TAS 110	Non-woven polyester reinforced modified bitumen membrane with fire retardants, a sanded bottom and mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SBS Premium FR UltraWhite <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164, Type II, Grade G TAS 110	Non-woven polyester reinforced modified bitumen membrane with fire retardants, a sanded bottom and mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SBS Premium FR Torch <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164, Type II, Grade G TAS 110	Non-woven polyester reinforced modified bitumen membrane with fire retardants, a sanded bottom and mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SBS Premium FR Torch UltraWhite <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164, Type II, Grade G TAS 110	Non-woven polyester reinforced modified bitumen membrane with fire retardants, a sanded bottom and mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SBS Premium Base <i>Manufacturing location #1</i>	39" x 50' (1.5sq.)	ASTM D6163, Type I & III, Grade S	Glass reinforced modified bitumen membrane coated with a fine-mineral top surface. <b>For use as a base/ply sheet only.</b>



**PRODUCT DESCRIPTION:**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
SBS Premium SRG <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164, Type II, Grade G TAS 110	Polyester reinforced SBS modified bitumen cap ply, topside surfaced with granules.
SBS Premium FR SRG <i>Manufacturing location #1</i>	39" x 33' 6" (1 sq.)	ASTM D6164 Type II, Grade G TAS 110	Polyester reinforced SBS modified bitumen cap ply with fire retardants, topside surfaced with granules.

**MANUFACTURING LOCATIONS:**

1. Indianapolis, IN
2. Tuscaloosa, AL

**EVIDENCE SUBMITTED:**

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
NEMO ETC, LLC.	4q-FBP-22-SSMBB-01.B	ASTM D6164	08/15/2022
	4q-HSP-23-SSMBB-01.A.R1	ASTM D4601	03/29/2024
	4q-HSP-23-SSMBB-02.B	ASTM D4601	05/23/2024
	4q-HSP-23-SSMBB-02.C	ASTM D6164	05/23/2024
	4q-HSP-23-SSMBB-02.D	ASTM D6164	05/23/2024
	4q-HSP-23-SSMBB-02.F	ASTM D6509	08/29/2024
	4q-HSP-23-SSMBB-02.H	ASTM D6222	08/29/2024
	4q-HSP-23-SSMBB-02.I	ASTM D6222	09/13/2024
	4q-HSP-23-SSMBB-01.E	ASTM D6222	09/23/2024
	4q-HSP-23-SSMBB-01.C	ASTM D6163	09/23/2024
	4q-HSP-23-SSMBB-01.D	ASTM D6163	09/23/2024
	4q-HSP-23-SSMBB-02.E	ASTM D6163	10/28/2024
	4q-HSP-23-SSMBB-02.L.R1	ASTM D6164	06/04/2026
	4q-HSP-23-SSMBB-02.G	ASTM D6163	11/19/2024
	4q-HSP-SSMBB-001.A.R1	ASTM D6163	12/04/2024
	4q-HSP-23-SSMBB-02.M	ASTM D6163	05/29/2025
	4q-HSP-23-SSMBB-02.J	ASTM D6164	07/28/2025
	4q-HSP-SSMBB-003.A	ASTM D6164	10/30/2025
	4q-AMZ-SSMBB-003.A.R1	ASTM D6162	03/11/2026
	4q-AMZ-SSMBB-003.B	ASTM D6162	05/18/2026



## **LABELING:**

All membranes and accessories or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



## **LIMITATIONS:**

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Amrize Modified Bitumen Roofing Membranes and Accessories are designed for use as specified within approved roofing system NOA assemblies.
3. This acceptance establishes the required physical properties testing and traceability of roofing membrane and accessory components listed in approved roofing applications. Minimum deck requirements shall be in compliance with applicable building code. Amrize Modified Bitumen Roofing Membranes and Accessories shall be installed in strict compliance with applicable Building Codes, Product Approvals and Manufacturers' specifications and guidelines.
4. Change in materials or manufacturing process or location of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
5. Amrize Modified Bitumen Roofing Membranes and Accessories may be used with any approved Roof Assembly Notice of Acceptance listing Amrize Modified Bitumen Roofing Membranes and Accessories as a component part of an assembly in the Notice of Acceptance. If Amrize Modified Bitumen Roofing Membranes and Accessories are not listed; a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
6. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 25-0917.06  
Expiration Date: 03/13/30  
Approval Date: 06/18/26  
Page 7 of 7