



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

Manta Roofing Products, LLC
1835 Wright Ave.
La Verne, CA 91750

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Manta Roof Coatings

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA #25-0402.01 and consists of pages 1 through 10.

The submitted documentation was reviewed by Rafael Macedo.

01/29/26



NOA No.: 25-0930.01
Expiration Date: 06/19/30
Approval Date: 01/29/26
Page 1 of 10

ROOFING COMPONENT APPROVAL

<u>Category:</u>	Roofing
<u>Sub-Category:</u>	Cements, Coatings and Adhesives
<u>Materials</u>	Elastomeric

SCOPE:

This approves **Manta Roof Coatings** as manufactured by Manta Roofing Products and as described in this Notice of Acceptance. These products have been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Container Size</u>	<u>Test Specification</u>	<u>Product Description</u>
MantaCryl #410 Alpine White Roof Coating <i>Manufacturing Location #1</i>	5, 50, 55, and 275 gallons	ASTM D6083	A liquid-applied coating membrane.
MantaCryl 415 White Diamond White Roof Coating <i>Manufacturing Location #1</i>	5, 50, 55, and 275 gallons	ASTM D6083	A liquid-applied coating membrane.
MantaSil 430 HS Premium Silicone Coating White Roof Coating <i>Manufacturing Location #1</i>	5 and 55 gallons	ASTM D6694	A liquid-applied coating membrane.
MantaPrime #205 Asphalt Quick Dry Primer <i>Manufacturing Location #1</i>	5 and 55 gallons	ASTM D 41, Type II	Asphalt-based primer
MantaPrime #207 Cold Applied Roll Roof Adhesive <i>Manufacturing Location #1</i>	1, 5 and 55 gallons	ASTM D 3019, Type III	Cold-applied roofing adhesive
MANTA #301 Multipurpose Roof Cement <i>Manufacturing Location #1</i>	Quarts, 1, 3 and 5 gallons	ASTM D 4586, Type I, Class I	A trowel-grade compound
MANTA #303 Flash-N-Go Roof Cement <i>Manufacturing Location #1</i>	Quarts, 1, 3 and 5 gallons	ASTM D 4586, Type I, Class I	A trowel-grade compound
MANTA #304 RAIN-PATCH <i>Manufacturing Location #1</i>	Quarts, 1, 3 and 5 gallons	ASTM D 4586, Type I, Class I	Asphalt-based Patching cement



NOA No.: 25-0930.01
Expiration Date: 06/19/30
Approval Date: 01/29/26
Page 2 of 10

MANTA #305 WET-N-DRY Modified Mastic <i>Manufacturing Location #1</i>	Quarts, 1, 3 and 5 gallons	ASTM D 4586, Type I, Class I	Modified SBS Flashing Cement
Manta #307 RUBBERTEK <i>Manufacturing Location #1</i>	Quarts, 1, 3 and 5 gallons	ASTM D 4586, Type I, Class I	Rubberized Flashing Cement
MantaStic 318 Elastomeric Roof Patch <i>Manufacturing Location #1</i>	10 oz, 1 and 3.5 gallons	TAS 139	Elastomeric White Roof Patch
MantaFlash #330 High Solids Silicone Butter Grade Mastic <i>Manufacturing Location #1</i>	10 oz, 1 and 2 gallons	Proprietary	High Solids Silicone Butter Grade Mastic
Manta #335 High Solids Fiber Reinforced Silicone Repair Patch <i>Manufacturing Location #1</i>	10 oz, 1 and 2 gallons	Proprietary	High Solids Fiber Reinforced Silicone Repair Patch

MANUFACTURING LOCATION

- Fort Lauderdale, FL

EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Ace Laboratories	DX02G4A	ASTM D6083	05/12/25
	DX13E4A	ASTM D6694	05/02/25
	DX05F5A	ASTM D6694	07/21/25
	DX01K4A	D6083 Type II	07/10/25
UL LLC	R41576	UL 790	04/23/25
PRI Construction Materials Technologies LLC	2819T0004	TAS 139	10/03/25
	2819T0005	Proprietary	09/26/2025
	2819T0006	Proprietary	09/26/2025
	2819T0007	ASTM D41/D41M-11(2023)	09/24/2025
	2819T0008	ASTM D3019	09/24/2025
	2819T0009	ASTM D4586;	09/23/2025
	2819T0002	ASTM D4586; ASTM D3409	05/05, 2025
	2819T0011	ASTM D4586; ASTM D3409	09/23/2025
	2819T0001	ASTM D4586; ASTM D3409	05/05/2025
	2819T0010	ASTM D4586; ASTM D3409	09/23/2025



PHYSICAL PROPERTIES OF COMPONENTS

Trade name:	MantaCryl #410 Alpine White Roof Coating
Specifications:	D6083 Type II
Description:	A liquid-applied coating membrane applied at an application rate listed below: 1. Spray Polyurethane Foam Membrane Roof Systems ; Apply MantaCryl 410 directly to the substrate at 3.0 gal/100 ft² in 2 passes. 2. Aged PVC Membrane Roof Systems; Apply MantaCryl 410 directly to the substrate at 3.0 gal/100 ft² in 2 passes. 3. Aged PVC Membrane Roof System with M230 Bleed Blocker: Apply primer MantaPrime 230 Bleed Blocker at 1 gallon per 100 ft². MantaCryl 410 to the substrate at 3.0 gal/100 ft² 2 coats 4. New Concrete Membrane Roof System*; Apply MantaCryl 410 directly to the substrate at 3.0 gal/100 ft² in 2 passes. 5. New Concrete with MantaPrime 235 Multipurpose Primer*; Apply primer MantaPrime 235 Multipurpose Primer at 1 gallon per 100 ft². Apply MantaCryl 410 to the substrate at a rate of 3.0 gallons per 100 square feet, making two passes. 6. New Galvanized steel with MantaPrime 235 Multipurpose Primer*; Apply primer MantaPrime 235 Multipurpose Primer at 1 gallon per 100 ft². Apply Top MantaCryl 410 to the substrate at 3.0 gallons per 100 square feet, making two passes. 7. Aged SBS Granulated with M230 Bleed Blocker: Apply primer MantaPrime 230 Bleed Blocker at 1 gallon per 100 ft². MantaCryl 410 to the substrate at 3.0 gal/100 ft² 2 passes. *Note: See Limitation #1.
Container Size:	5, 50, 55, and 275 gallons (Note all precautions on container)
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.
Manufacturing location	#1



Trade name: MantaCryl 415 White Diamond White Roof Coating
Specifications: ASTM D6083
Description: A liquid-applied coating membrane applied at application rates as listed below:

- 1- **Spray Polyurethane Foam Membrane Roof System;** Apply 2 coats of MantaCryl 415 direct to substrate at 3.0 gal/100 ft².
- 2- **Aged PVC Membrane Roof System with MantaPrime 230 Primer;** Apply primer ManatPrime 230 Bleed Blocker at 1 gallon per 100/ft². Apply 2 coats of MantaCryl 415 to the substrate at 3.0 gal/100 ft².
- 3- **New Granulated APP Modified Bitumen Membrane Roof System with MantaPrime 230 Bleed Blocker;** Apply primer MantaPrime 230 Bleed Blocker at 1 gallon per 400-500 ft². Apply 2 coats of MantaCryl 415 to the primed substrate at 3.0 gal/100 ft².
- 4- **New Concrete Membrane Roof Systems *;** Apply 2 coats of MantaCryl 415 direct to substrate at 3.0 gal/100 ft².
- 5- **New Galvanized steel Membrane Roof System with MantaPrime 235;** Apply primer MantaPrime 235 Multipurpose Primer at 1 gallon per 100 ft². Apply 2 coats of MantaCryl 415 to the primed substrate at 3.0 gal/100 ft².
- 6- **New Concrete with MantaPrime 235 Multipurpose Primer;** Apply primer MantaPrime 235 Multipurpose Prime at 1 gallon per 100 ft². Apply 2 coats of MantaCryl 415 to the primed substrate at 3.0 gal/100 ft².

***Note: See Limitation #1.**

Container Size: 5,50,55 and 275 gallons. Note all cautions on container label.
Systems Approvals: Methods of application and quantities shall comply with specific Roof Assembly, Product Control Notice of Acceptance.
Manufacturing location #1



Trade name: MantaSil 430 HS Premium Silicone Coating White Roof Coating

Specifications: ASTM D6694

Description: A silicone liquid applied coating membrane applied at application rates as listed below:

- 1- **Spray Polyurethane Foam Roof System;** Apply MantaSil 430 direct to substrate at 1.5 gal/100 ft².
- 2- **Granule SBS Modified Bitumen Roofing Systems;** Apply MantaSil 430 to the substrate at 1.5 gal/100 ft².
- 3- **New Concrete Roof System*;** Apply MantaSil 430 direct to substrate at 1.5 gal/100 ft².
- 4- **New Concrete with MantaPrime 235 Multipurpose Primer;** Apply primer MantaPrime 235 Multipurpose Primer at 1 gallon per 400-500 ft². Apply MantaSil 430 to the primed substrate at 1.5 gal/100 ft².
- 5- **Aged Silicone Coating Roof System;** Apply MantaSil 430 to the substrate at 1.5 gal/100 ft².
- 6- **Aged Galvalume Coating Roof System;** Apply Top Coat MantaSil 430 to the substrate at 1.5 gal/100 ft².
- 7- **Aged Galvanized Coating Roof System;** Apply Top Coat MantaSil 430 to the substrate at 1.5 gal/100 ft².

***Note: See Limitation #1.**

Container Size: 5 and 55 gallons. Note all cautions on container label.

Systems Approvals: Methods of application and quantities shall comply with specific Roof Assembly, Product Control Notice of Acceptance.

Manufacturing location #1



Trade name:	MantaPrime #205 Asphalt Quick Dry Primer
Application Rate	Typical coverage is 150-200 sq. ft. per gallon, depending on temperature and porosity of the surface to receive primer. Avoid over-application and build-up of surface film.
Specifications:	ASTM D 41, Type II
Description:	MantaPrime #205 Asphalt Quick Dry Primer is an asphalt-based material used as a bonding coat and for priming surfaces before applying cold-applied and hot-mopped asphalt coatings, roof cement, mastics, and adhesives. It is ready to use as it comes from the can.
Container Size:	5 gallons, 55 gallons (Note all precautions on container)
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
Manufacturing Location:	#1

Trade name:	MantaPrime #207 Cold Applied Roll Roof Adhesive
Application Rate	Typical coverage is 50 sq. ft. per gallon. The coverage rate varies depending on the surface's texture and porosity.
Specifications:	ASTM D 3019, Type III
Description:	Professional-grade, cold-applied roofing adhesive with a heavy brush consistency. It can be used for new construction and reroofing to bond plies in built-up and modified roofing systems. MantaPrime™ #207 has excellent bonding strength and can be used as a substitute for hot-mopped asphalt. It forms a flexible bond that allows the roofing membrane to conform to normal building movements. Using this product eliminates the potential for burns and the risk of damaging asphalt from overheating.
Container Size:	1 gallon, 5 gallons, 55 gallons (Note all precautions on container)
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
Manufacturing Location:	#1

Trade name:	MANTA #301 Multipurpose Roof Cement
Application Rate	Apply a minimum of 1/8" to 1/4" with a trowel or putty knife. Coverage 12.5 sq ft. per gallon, applied at 1/8 inch thick.
Specifications:	ASTM D 4586, Type I
Description:	A premium trowel-grade compound for sealing roof leaks on dry surfaces. This product is designed to repair leaks in shingles, concrete, metal, and asphalt roofing, as well as the Roof around walls, chimneys, vents, downspouts, and cornices. It is also suitable for sealing cracks in concrete and masonry, acting as a joint filler for precast roof panels, and general maintenance and repair of exterior building structures.
Container Size:	Quarts, 1, 3, 5 gallons (Note all precautions on container)
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
Manufacturing Location:	#1



Trade name:	MANTA #303 Flash-N-Go Roof Cement
Application Rate	Apply at a minimum rate of approximately 12 square feet per gallon at a 1/8-inch thickness with a trowel or putty knife.
Specifications:	ASTM D 4586, Type I
Description:	A premium trowel-grade compound for sealing roof leaks on dry surfaces. This product is designed to repair leaks in shingles, concrete, metal, and asphalt roofing, as well as the Roof around walls, chimneys, vents, downspouts, and cornices. It is also suitable for sealing cracks in concrete and masonry, acting as a joint filler for precast roof panels, and general maintenance and repair of exterior building structures.
Container Size:	Quarts, 1, 3, 5 gallons (Note all precautions on container)
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
Manufacturing Location:	#1

Trade name:	MANTA #304 RAIN-PATCH
Application Rate	Apply at a minimum rate of approximately 12 square feet per gallon at a 1/8-inch thickness with a trowel or putty knife.
Specifications:	ASTM D 4586, Type I
Description:	Premium-grade, asphalt-based Patching cement engineered for superior performance in all weather conditions. This versatile cement is formulated for instant leak repair and is compatible with built-up roofing systems (SBS), base sheets, shingles, and other approved surfaces. It provides exceptional adhesion and durability for repairing leaks, cracks, and holes in various roofing materials, including composition, metal, and masonry.
Container Size:	Quarts, 1, 3, 5 gallons (Note all precautions on container)
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
Manufacturing Location:	#1

Trade name:	MANTA #305 WET-N-DRY Modified Mastic
Application Rate	Apply at a minimum rate of approximately 12 square feet per gallon at a 1/8-inch thickness with a trowel or putty knife.
Specifications:	ASTM D 4586, Type I
Description:	Premium grade, modified SBS Flashing Cement engineered for superior performance in wet and dry conditions. This versatile mastic is formulated for use with built-up roofing systems (SBS), base sheets, shingles, and other approved surfaces, providing exceptional adhesion and durability. Its unique composition allows for effective repairs of leaks, cracks, and holes in various roofing materials, including concrete, steel, and metal. Note: Do not use on TPO, EPDM, PVC, or other rubbery plastic single-ply membranes.
Container Size:	Quarts, 1, 3, 5 gallons (Note all precautions on container)
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
Manufacturing Location:	#1



Trade name:	Manta #307 RUBBERTEK
Application Rate	Apply at a minimum rate of approximately 12 square feet per gallon at a 1/8-inch thickness with a trowel or putty knife.
Specifications:	ASTM D 4586, Type I
Description:	Rubberized Flashing Cement is a super-premium flashing cement modified with SEBS rubber and formulated with high-quality solvents and UV inhibitors. This product is designed for permanent repairs in all weather conditions, whether wet or dry. Its superior elasticity and flexibility make it ideal for use on control joints, seams, and other areas where movement is expected.
Container Size:	Quarts, 1, 3, 5 gallons (Note all precautions on container)
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
Manufacturing Location:	#1

Trade name:	MantaFlash #330 High Solids Silicone Butter Grade Mastic
Application Rate	12-13 sq. ft. per gallon applied 1/8" thick; additional material may be required when 3-coursing to saturate and encapsulate polyester.
Specifications:	Proprietary
Description:	MantaFlash 330 Silicone Roof Patch is a premium-grade sealant designed for professional roofing applications. It effectively seals leaks, repairs damage, and creates a durable barrier on roof surfaces, including metal, asphalt, modified bitumen, concrete, and most single-ply materials.
Container Size:	10 oz, 1, 2 gallons (Note all precautions on container)
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
Manufacturing Location:	#1

Trade name:	Manta #335 High Solids Fiber Reinforced Silicone Repair Patch
Application Rate	12-13 sq. ft. per gallon applied 1/8" thick; additional material may be required when 3-coursing to saturate and encapsulate polyester.
Specifications:	Proprietary
Description:	The MantaMax 335 Silicone Repair Patch adheres underwater. It is a versatile, fiber-reinforced silicone mastic designed for permanent, direct-bond repairs on various roof surfaces. Its flashing grade formula ensures long-lasting durability even in harsh weather conditions.
Container Size:	10 oz, 1, 2 gallons (Note all precautions on container)
Systems Approvals:	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
Manufacturing Location:	#1



LIMITATIONS:

1. **Manta Roof Coatings are not approved as and shall not be used as a Roof or Waterproofing System as required by the Florida Building Code Chapter 15 HVHZ.**
2. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
3. All products shall be applied in strict compliance with Manufacturer's published application instructions.
4. The MantaSil 430, MantaCryl 415 and MantaCryl #410 products shall not be applied in inclement weather conditions.
5. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
6. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code
7. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 25-0930.01
Expiration Date: 06/19/30
Approval Date: 01/29/26
Page 10 of 10