



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Mule-Hide Products Co., Inc.
1195 Prince Hall Drive
Beloit, WI 53511

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Mule-Hide Mastics, Flashings and Field Applied Coatings

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 6.

The submitted documentation was reviewed by Rafael Macedo.

02/05/26



NOA No.: 25-1009.02
Expiration Date: 11/15/27
Approval Date: 02/05/26
Page 1 of 6

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cements and Coatings
Fire Classification: See General Limitation #1

SCOPE:

This approves **Mule-Hide Mastics, Flashings and Field Applied Coatings**, as described in this Notice of Acceptance. This product has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

MANUFACTURING LOCATION

1. Winter Haven, FL

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies Inc.	PUSA-178-02-01	ASTM D4479	12/15/16
	PUSA-179-02-01	ASTM D4586	12/15/16
	PUSA-180-02-01	ASTM D4586	12/15/16
	PUSA-181-02-01	ASTM D4586	12/15/16
	PUSA-182-02-01	ASTM D4586 & D3409	12/15/16
	PUSA-176-02-01	ASTM D41	03/20/17
	PUSA-171-02-01	ASTM D3019	04/27/17
	PUSA-184-02-01	ASTM D2824	05/02/17
	PUSA-185-02-01	ASTM D2824	05/02/17
	PUSA-213-02-01	Proprietary	05/02/17
	PUSA-215-02-01	ASTM D 3019	06/12/17
	PUSA-200-02-01	ASTM D1227	06/13/17
	PUSA-217-02-01	ASTM D 4586	07/06/17
	PUSA-281-02-01	ASTM D6904/TT-C-555B	03/18/19
	PUSA-282-02-01	ASTM D6904/TT-C-555B	03/18/19
	PUSA-283-02-01	ASTM D6904/TT-C-555B	03/18/19
	PUSA-284-02-01	ASTM D6904/TT-C-555B	03/18/19
	PUSA-286-02-01	ASTM D6904/TT-C-555B	03/25/19
	PUSA-287-02-01	ASTM D6904/TT-C-555B	03/19/19
Nemo	708T0120	ASTM C836	11/28/22
	708T0121	ASTM C836	10/05/22
	708T0160	Proprietary	05/31/23
	4y-PLYG-23-SWTP-02.A	Proprietary	08/13/24



NOA No.: 25-1009.02
Expiration Date: 11/15/27
Approval Date: 02/05/26
Page 2 of 6

PHYSICAL PROPERTIES OF COMPONENTS:

Trade name: 121 ASPHALT PRIMER / 121 ASPHALT SPRAY PRIMER

Application Rate: ½ to 1 gallon per 100 sq./ft.

Specifications: ASTM D 41

Description: A general purpose, fast-drying, penetrating asphalt primer used to promote adhesion.

Container Size: 1 gallon can, 5 gallon pail or 14 oz. Spray Can. See product data sheet for specific volume. Note all precautions on container.

Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.

Manufacturing Location #1

Trade name: 102 FIBRATED ROOF COATING

Application Rate: 2 to 3 gallon per 100 sq./ft.

Specifications: ASTM D 4479, Type I

Description: An asphalt fibered, non-polymer modified protective roof coating.

Container Size: 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.

Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.

Manufacturing Location #1

Trade name: 420 MOD BIT ADHESIVE-BRUSH GRADE

Application Rate: 1.5 to 2 gallon per 100 sq./ft.

Specifications: ASTM D 3019 Type III

Description: A cold-applied bonding adhesive for use with modified bitumen membranes.

Container Size: 5 gallon pail, 55 gallon drum. See product data sheet for specific volume. Note all precautions on container.

Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.

Manufacturing Location #1



Trade name: 210 PLASTIC CEMENT / 211 PLASTIC CEMENT
Application Rate: 1/8" thick coat
Specifications: ASTM D 4586, Type I
Description: A cold-applied, sealing and repair flashing cement.
Container Size: 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1

Trade name: 221 WET/DRY ROOF CEMENT
Application Rate: 1/8" thick coat
Specifications: ASTM D 4586, ASTM D 3409 (adhesion to wet surface)
Description: A wet and dry roof cement.
Container Size: 2.8 or 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1

Trade name: 231 FLASHING CEMENT
Application Rate: 1/8" thick coat
Specifications: ASTM D 4586
Description: A trowel grade, general purpose wet and dry roof cement.
Container Size: 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1

Trade name: 241 PREMIUM MODIFIED FLASHING CEMENT /
421 MOD BIT ADHESIVE-TROWEL GRADE
Application Rate: 1/8" thick coat
Specifications: ASTM D 4586, Type I
Description: A thick, fibered, rubberizes flashing cement for used with modified bitumen membranes or tile underlayment applications.
Container Size: 10.1 oz cartridge, 2.8 or 5 gallon pail. Note all precautions on container
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1



Trade name: 416 STANDARD NON-FIBRATED ALUMINIUM ROOF COATING
Application Rate: 0.5 to 1 gallons per 100 sq./ft.
Specifications: ASTM D 2824, Type I
Description: Non-fibered aluminum, reflective, roof coating.
Container Size: 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1

Trade name: 406 STANDARD FIBRATED ALUMINIUM ROOF COATING
Application Rate: 1 to 1.5 gallon per 100 sq./ft.
Specifications: ASTM D 2824, Type III
Description: Fibered aluminum, reflective roof coating.
Container Size: 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1

Trade name: 251 PREMIUM WET/DRY ELASTOMERIC FLASHING CEMENT / RGA 1 FLASHING
Application Rate: 1/8" thick coat
Specifications: ASTM D 4586, Type I & ASTM D 3409 (adhesion to wet surface)
Description: A premium, trowel grade, wet and dry, rubberized flashing cement.
Container Size: 2.8 or 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1

Trade name: 410 PREMIUM NON-FIBRATED ALUMINIUM ROOF COATING
Application Rate: 0.5 to 1 gallon per 100 sq./ft.
Specifications: ASTM D 2824, Type I
Description: A premium grade, non-fibered aluminum, reflective, roof coating.
Container Size: 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1



Trade name: 401 PREMIUM FIBRATED ALUMINIUM ROOF COATING

Application Rate: 1 to 1.5 gallon per 100 sq./ft.

Specifications: ASTM D 2824, Type III

Description: A premium, fibered aluminum, reflective, roof coating.

Container Size: 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.

Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.

Manufacturing Location #1

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Product shall be applied in strict compliance with Manufacturer's published application instructions when not in conflict with the information contained herein.
3. Coating products shall not be applied in inclement weather conditions.
4. The product listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their Roof Assembly Notice of Acceptance. If a product is not listed as part of roof assemblies Notice of Acceptance, a request may be made to the local building official or the Miami Dade County Product Control Section for approval provided that appropriate documentation is provided.
5. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to RER upon request.
6. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



7. The use of a reinforcing fabric in a maintenance coating is only to enhance the coatings ability to deliver efficient and long term performance through the protection of the underlying roof system and in this particular use does not become a roof system itself.
8. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 25-1009.02
Expiration Date: 11/15/27
Approval Date: 02/05/26
Page 6 of 6