



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Tremco CPG, Inc.
3735 Green Road
Beachwood, OH 44122

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TremPly KEE Roof Systems over Wood Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA # 22-0228.35 and consists of pages 1 through 8.
The submitted documentation was reviewed by Alex Tigera.

01/22/26



NOA No.: 25-1210.02
Expiration Date: 01/05/31
Approval Date: 01/22/26
Page 1 of 8

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply
Material: KEE
Deck Type: Wood
Maximum Design Pressure -67.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
TremPly KEE	Various	ASTM D 6754	KEE, polyester reinforced, single ply membrane
TremPly KEE FB	Various	ASTM D 6754	KEE, fleece-backed, polyester reinforced, single ply membrane
TremPly KEE LV Bonding Adhesive	5 gal. pails	Proprietary	Solvent based bonding adhesive
TremPly KEE FB WB II Bonding Adhesive	5 gal. pails	Proprietary	One side “substrate only” fleece backed water based adhesive
TremPly KEE Walkway & Protection Materials	5/32" x 36" x 40' 1/4" x 24" x 48"	N/A	Vinyl walk way; Vinyl protection pad

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
ACFoam-II, ACFoam-III	Isocyanurate Insulation	Atlas Roofing Corporation
DensDeck Roof Board, DensDeck Prime Roof Board	Silicon treated gypsum	Georgia-Pacific Gypsum Products
H-Shield	Isocyanurate Insulation	Hunter Panels, a div. of Carlisle Const. Materials, LLC
ENRGY 3	Isocyanurate Insulation	Johns Manville Corporation
Multi-Max FA-3	Polyisocyanurate foam insulation	Rmax Operating LLC
SECUROCK Gypsum-Fiber Roof Board	Fiber Reinforced Roof Board	United States Gypsum Corporation



APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	Dekfast DF-#15-PH3	Membrane fastener	Various	SFS Group USA, Inc.
2.	Dekfast PLT-O-2-1/2-12B	Galvalume AZ50 stress plate	1.5" x 2.5"	SFS Group USA, Inc.
3.	OMG Fasteners	Insulation and membrane fastener	Various	OMG, Inc.
4.	3 in. Round Metal Plate	Galvalume AZ55 stress plate	3" round	OMG, Inc.
5.	OMG Plastic Plate	Plastic plates for fasteners.	3" round	OMG, Inc.
6.	Dekfast Fasteners	Insulation fastener for steel and wood decks	Various	SFS Group USA, Inc.
7.	Dekfast PLT-R-3	Galvalume AZ50 stress plate	3" round	SFS Group USA, Inc.
8.	Dekfast PLT-R-2-3/8-6B	Barbed, galvalume AZ50 stress plate	2-3/8" Dia.	SFS Group USA, Inc.
9.	TremPly Plus Stress Plate	Oval stress plate	1½" x 2¾"	Tremco CPG, Inc.
10.	<i>Isoweld</i> FI-P-6.8-PVC	Galvanized steel plate with PVC coating	3" round	SFS Group USA, Inc.



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	FM 4470	1Z2A5.AM	01/12/96
	FM 4470	1Z3A8.AM	08/13/97
	FM 4470	3009071	01/03/02
	FM 4470	3028651	04/17/08
	FM 4470	3033396	09/04/09
	FM 4470	3013068	09/23/03
Underwriters Laboratories	UL790	94NK40647	10/15/94
		95NK20862	11/17/95
		98NK12810	8/11/98
		98NK17212	8/21/98
Exterior Research & Design, LLC	TAS 114	4006.08.00-1-1R	10/18/05
Trinity ERD	TAS 114	S5700.06.07-R3	09/06/07
	ASTM D 6754	S34070.06.11-R1	06/18/12
	TAS 117 & ASTM D6862	C850SC.11.07-R1	08/07/09
	ASTM D6754	S47410.12.14	12/15/14
	FM 4470 / TAS 114	S32410.09.10	09/21/10
PRI Construction Materials Technologies LLC	ASTM D 3747	HGC-142-02-03	02/09/12



APPROVED ASSEMBLIES

Membrane Type:	Single Ply, KEE
Deck Type II:	Wood, Insulated
Deck Description:	¹⁹ / ₃₂ " APA rated, 40/20 span rating, CDX, 4-ply or greater plywood or wood plank fastened to supports with wood screws at maximum spacing of 6" o.c.
System Type D(1):	Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier: (Optional) Any UL or FM approved vapor retarder may be installed over the deck or the insulation.

Fire Barrier: ¼" DensDeck Roof Board attached with 4 fasteners per 4' x 8' sheet.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ACFoam-III, Multi-Max FA-3, ENRGY 3, H-Shield Minimum 1" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Membrane: TremPly KEE roof cover attached through the preliminary fastened insulation/barrier to the deck following the fastening methods specified below.

Fastening: Fasten with Dekfast DF-#15-PH3 fasteners and Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plate spaced 9" o.c. through tabs spaced 51" o.c. Laps are sealed with 1.5-inch heat weld.

Maximum Design Pressure: -52.5 psf (See General Limitation #7)



Membrane Type: Single Ply, KEE
Deck Type 1I: Wood, Insulated
Deck Description: 1⁹/₃₂" APA rated, 40/20 span rating, CDX, 4-ply or greater plywood or wood plank fastened to supports with wood screws at maximum spacing of 6" o.c .
System Type D(2): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ACFoam-III, Multi-Max FA-3, ENRGY 3, H-Shield		
Minimum 1.5" thick	N/A	N/A
DensDeck Roof Board, SECUROCK Gypsum-Fiber Roof Board		
Minimum 1/4" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Membrane: TremPly KEE roof cover attached through the preliminary fastened insulation/barrier to the deck following the fastening methods specified below:
Fastening: Fasten with Dekfast DF-#15-PH3 fasteners and Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plate spaced 6" o.c. in 5" laps spaced 51" o.c. Laps are sealed with 1.5-inch heat weld.
Maximum Design Pressure: -52.5 psf (See General Limitation #7)



- Membrane Type:** Single Ply, KEE
- Deck Type II:** Wood, Insulated
- Deck Description:** ¹⁹/₃₂" APA rated, 40/20 span rating, CDX, 4-ply or greater plywood or wood plank attached with 8d common nails 6" o.c. to supports having a maximum span of 24".
- System Type D(3):** Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

- Fire Barrier:** See Insulation Layer, above.
- Membrane:** TremPly KEE roof cover attached through the preliminary fastened insulation/barrier to the deck following one of the fastening methods specified below:
- Fastening #1:** Fasten with Dekfast DF-#15-PH3 fasteners and Dekfast PLT-R-2-3/8-6B plates through the top of the membrane spaced at 12" o.c. in rows spaced 72" o.c through the wood deck into structural members. Fastener rows covered with 6-inch coverstrip and sealed on both sides with 1.5-inch heat weld.
Maximum Design Pressure: -60 psf (See General Limitation #7)
- Fastening #2:** Fasten with Dekfast DF-#15-PH3 fasteners and Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plate through the top of the membrane spaced at 6" o.c. in rows spaced 96" o.c. through the wood deck into structural members. Fastener rows covered with 6-inch coverstrip and sealed on both sides with 1.5-inch heat weld.
Maximum Design Pressure: -67.5 psf (See General Limitation #7)
- Maximum Design Pressure:** See Fastening Options Above.



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

