



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
 BOARD AND CODE ADMINISTRATION DIVISION

**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
 PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
 Miami, Florida 33175-2474  
 T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Tremco CPG, Inc.**  
**3735 Green Road**  
**Beachwood, OH 44122**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: TremPly KEE Roof Systems over Recover Decks.**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA # 22-0228.37 and consists of pages 1 through 41.  
 The submitted documentation was reviewed by Alex Tigera.

01/22/26



NOA No.: 25-1210.04  
 Expiration Date: 01/05/31  
 Approval Date: 01/22/26  
 Page 1 of 41

## ROOFING SYSTEM APPROVAL

<b>Category:</b>	Roofing
<b>Sub-Category:</b>	Single Ply
<b>Material:</b>	KEE
<b>Deck Type:</b>	Recover
<b>Maximum Design Pressure</b>	See Specific deck type

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
TremPly KEE	Various	ASTM D 6754	KEE, polyester reinforced, single ply membrane
TremPly KEE FB	Various	ASTM D 6754	KEE, fleece-backed, polyester reinforced, single ply membrane
TremPly KEE LV Bonding Adhesive	5 gal. pails	Proprietary	Solvent based bonding adhesive
TremPly KEE FB Bonding Adhesive	5 gal. pails	Proprietary	One side "substrate only" fleece back solvent based adhesive
TremPly KEE FB WB II Bonding Adhesive	5 gal. pails	Proprietary	One side "substrate only" fleece backed water based adhesive
Tremco Low Rise Foam Insulation Adhesive	5 gal. pails	Proprietary	Elastomeric, one step foamable adhesive
Tremco Low Rise Foam Insulation Adhesive (BG)	5 gal. or 50 gal. pails	Proprietary	Two-component, VOC free, polyurethane adhesive
TremPly KEE Walkway & Protection Materials	5/32" x 36" x 40' ¼" x 24" x 48"	N/A	Vinyl walk way vinyl protection pad
Tremco LR Adhesive	5 gal. or 50 gal. pails	Proprietary	Two-component, VOC free, polyurethane adhesive



**APPROVED INSULATIONS:**

**TABLE 2**

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
ACFoam Composite	Polyisocyanurate insulation with perlite facer	Atlas Roofing Corporation
ACFoam-II, ACFoam-III	Polyisocyanurate insulation	Atlas Roofing Corporation
DensDeck Roof Board, DensDeck Prime Roof Board	Silicon treated gypsum	Georgia-Pacific Gypsum LLC
H-Shield, H-Shield-NB, H-Shield WF, H-Shield CG	Polyisocyanurate insulation	Hunter Panels, a div. of Carlisle Const. Materials, LLC
ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 CGF 25 PSI, R-Panel	Polyisocyanurate insulation	Johns Manville Corporation
ValuTherm CGF, ValuTherm CGF 25 PSI	Polyisocyanurate insulation	Johns Manville Corporation
Ultra-Max, Multi-Max FA-3	Polyisocyanurate foam insulation	Rmax Operating, LLC
Thermarroof Composite-3, Tapered Thermarroof-3	Polyisocyanurate/perlite composite insulation	Rmax Operating, LLC
SECUROCK Gypsum-Fiber Roof Board	Gypsum coverboard	USG Corporation
SECUROCK Glass-Mat Roof Board	Gypsum Coverboard	USG Corporation
Structodek High Density Fiberboard Roof Insulation	Wood fiber board	Blue Ridge Fiberboard, Inc.



**APPROVED FASTENERS/ADHESIVES:**

**TABLE 3  
Product  
Description**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	Dekfast PLT-O-2-1/2-12B	Galvalume AZ50 stress plate	1.5" x 2.5"	SFS Group USA, Inc.
2.	Dekfast PLT-R-2-3/8-6B	Barbed, Galvalume AZ50 stress plate	2-3/8" Dia.	SFS Group USA, Inc.
3.	<i>isofast</i> PLT-R-2-3/8-BL	Galvalume AZ50 stress plate, #15 belted fastener system	2-3/8" Dia.	SFS Group USA, Inc.
4.	Dekfast DF-#14-PH3	Insulation and membrane fasteners	Various	SFS Group USA, Inc.
5.	Dekfast PLT-H-2-7/8	Galvalume AZ50 steel plate	2-7/8" x 3-1/4"	SFS Group USA, Inc.
6.	Trufast 3" Metal Insulation Plates	Galvalume AZ50 steel plate	3" round	Altenloh, Brinck & Co. U.S., Inc.
7.	Dekfast DF-#15-PH3	Carbon steel fastener for concrete, steel and wood decks	Various	SFS Group USA, Inc.
8.	Trufast #15 EHD Fasteners	Carbon steel fastener used in concrete, steel and wood decks	Various	Altenloh, Brinck & Co. U.S., Inc.
9.	Trufast 2-3/4" Barbed Seam Plate (EHD)	Galvalume steel stress plate for use with Trufast fasteners.	2.75" round	Altenloh, Brinck & Co. U.S., Inc.
10.	TremPly Plus Stress Plate	Oval stress plate	1½" x 2¾"	Tremco CPG, Inc.
11.	Polymer GypTec	Fastener for cementitious and gypsum decks	Various	OMG, Inc.
12.	Polymer GypTec Insulation Plate	Round Galvalume AZ55 plate	3" round	OMG, Inc.
13.	OMG XHD	Self-drilling fastener for use in steel or wood decks	Various	OMG, Inc.
14.	OMG #14 Heavy Duty	Self-drilling fastener for use in steel, wood or concrete decks	Various	OMG, Inc.
15.	3 in. Round Metal Plate	Round Galvalume steel stress plate	3" round	OMG, Inc.
16.	Polyset Commercial Roof Adhesive	A two component elastomeric polyurethane foam adhesive		ICP Construction, Inc.



**APPROVED FASTENERS/ADHESIVES:**

**TABLE 3  
Product  
Description**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
17.	Millennium One Step Foamable Insulation Adhesive	A two component, low rise, polyurethane foam adhesive		H.B. Fuller Company
18.	Millennium PG-1 Low Viscosity Insulation Adhesive	A two component, low rise, polyurethane foam adhesive		H.B. Fuller Company
19.	OlyBond 500	A two component polyurethane foam adhesive		OMG, Inc.
20.	Polysset Board Max	A two component polyurethane foam adhesive		ICP Construction, Inc.
21.	<i>Isoweld</i> FI-P-6.8-PVC	Galvanized steel plate with PVC coating	3” round	SFS Group USA, Inc.
22.	COLPLY EF Adhesive	Single component, asphalt cutback adhesive	5 gal pail 55 gal drum 350 gal tote	SOPREMA, Inc.



**EVIDENCE SUBMITTED:**

<u>Test Agency</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp	FM 4470	1Z2A5.AM	01/12/96
	FM 4470	1Z3A8.AM	08/13/97
	FM 4470	0D2A8.AM	01/12/98
	FM 4470	4D5A4.AM	10/05/99
	FM 4470	3003251	10/15/99
	FM 4470	3006872	06/13/00
	FM 4470	3009071	01/03/02
	FM 4470	3012321	07/29/02
	FM 4470	3014050	07/08/03
	FM 4470	3013068	09/23/03
	FM 4470	3028651	04/17/08
	FM 4470	3032172	06/12/09
	FM 4470	3033396	09/04/09
	FM 4470	3037770	10/22/09
	FM 4470	3037168	04/12/10
	FM 4470	3044075	04/06/12
	FM 4470	3046131	10/17/12
	FM 4470	3048494	11/19/13
	FM 4470	3051608	10/23/16
	Trinity   ERD	TAS 114	02767.09.05-S1
TAS 114		02767.09.05-S2	09/27/05
TAS 117 & ASTM D6862		C850SC.11.07-R1	08/07/09
TAS 114		4006.07.97-1-R1	07/15/10
TAS 114		4015.10.96-1-R1	07/20/10
FM 4470 / TAS 114		S32410.09.10	09/21/10
FM 4470 / TAS 114		S6220.03.07-R1	05/13/11
ASTM D 6754		S47410.12.14	12/15/14
FM 4474 / TAS 114		S43840.11.15	11/30/15
FM 4474 / TAS 114		SMN-SC10155.01.16	01/27/16
Underwriters Laboratories	UL 790	98NK12810	08/11/98
	UL 790	98NK17212	08/21/98
	UL 790	12CA39420	01/08/13
PRI Construction Materials Technologies LLC	ASTM D 3747	HGC-142-02-03-R1	06/16/16

**DECK STRESS ANALYSIS CALCULATIONS/REPORTS**

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
Robert Nieminen, P.E.	Signed/Sealed Calculations	D(8), D(10), E(6), E(7)	12/11/15
		B(2), C(2), C(11), C(12), C(14)	12/27/24
Factory Mutual Research Corp.	RoofNav Listings	C(4), C(5), C(6), D(1) through D(7), E(3), E(4), E(5)	11/23/15
		B(1), C(1)	12/27/24



**APPROVED ASSEMBLIES**

**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(1):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier:** Cold-applied base and/or ply sheet approved for use with the roof cover followed by an  
**(Optional)** additional approved cold-applied sheet.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5 ” thick	N/A	N/A
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Tapered	N/A	N/A

**Note: All insulation shall be adhered to the substrate or vapor barrier in Polyset Board-Max applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** TremPly KEE roof cover adhered with TremPly KEE LV Bonding Adhesive applied at a rate of 100 ft<sup>2</sup> per 1 gal. to the back side of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.  
 Or  
 TremPly KEE FB roof cover adhered with TremPly KEE FB Bonding Adhesive at 100 ft<sup>2</sup> per 1 gal. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure:** -55.0 psf (See General Limitation #9)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(2):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Retarder:** Cold-applied base and/or ply sheet approved for use with the roof cover followed by an additional approved cold-applied sheet.  
**(Optional)**

One or more layers of the following insulations:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum: 0.25 ” thick	N/A	N/A

**Note: All insulation shall be adhered to the substrate or vapor barrier in Polyset Board-Max applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** TremPly KEE roof cover adhered with TremPly KEE LV Bonding Adhesive applied at a rate of 100 ft<sup>2</sup> per 1 gal. to the back side of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.

Or

TremPly KEE FB roof cover adhered with hot asphalt at 25 lbs/sq. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure:**

-55.0 psf (See General Limitation #9)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(3):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Hot-applied, Self-Adhering or Torch-applied vapor barrier as indicated below:  
 Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional approved asphalt-applied sheet.  
 Or  
 Self-adhered base membrane approved for use with roof cover followed by an additional approved self-adhered sheet.  
 Or  
 Hot asphalt-applied base and/or ply sheets or optional torch-applied base membrane approved for use with roof cover followed by an additional approved torch-applied sheet.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Tapered	N/A	N/A

**Note: All insulation shall be adhered to the substrate or vapor barrier in Polyset Board-Max applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**



**Membrane:** TremPly KEE FB roof cover adhered with TremPly KEE FB Bonding Adhesive at 100 ft<sup>2</sup> per 1 gal. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.  
**Maximum Design Pressure: -105 psf (See General Limitation #9)**

Or

TremPly KEE roof cover adhered with TremPly KEE LV Bonding Adhesive applied at a rate of 100 ft<sup>2</sup> per 1 gal. to the back side of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.  
**Maximum Design Pressure: -117 psf (See General Limitation #9)**

**Maximum Design Pressure:** See Membrane Options Above.



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** Min. 272 psi Mearlcrete, or min 240 psi Elastizell LWIC cast over structural concrete  
**System Type A(4):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Tapered	N/A	N/A

**Note: All insulation shall be adhered to the substrate in Polyset Board-Max applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** TremPly KEE FB roof cover adhered with TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.  
*Maximum Design Pressure: -67.5 psf (See General Limitation #9)*

Or

TremPly KEE FB roof cover adhered with TremPly KEE FB Bonding Adhesive at 100 ft<sup>2</sup> per 1 gal. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.  
*Maximum Design Pressure: -105 psf (See General Limitation #9)*

Or

TremPly KEE roof cover adhered with TremPly KEE LV Bonding Adhesive applied at a rate of 100 ft<sup>2</sup> per 1 gal. to the back side of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.  
*Maximum Design Pressure: -117 psf (See General Limitation #9)*

**Maximum Design Pressure:** See Membrane Options Above.



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(5):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Hot-applied, Self-Adhering or Torch-applied vapor barrier as indicated below:  
 Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional approved asphalt-applied sheet.  
 Self-adhered base membrane approved for use with roof cover followed by an additional approved self-adhered sheet.  
 Hot asphalt-applied base and/or ply sheets or optional torch-applied base membrane approved for use with roof cover followed by an additional torch-applied sheet.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5 ” thick	N/A	N/A

**Note: All insulation shall be adhered to the substrate or vapor barrier in Polyset Board-Max applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**



**Membrane:**

TremPly KEE FB roof cover adhered with TremPly KEE FB Bonding Adhesive at 100 ft<sup>2</sup> per 1 gal., or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure: -105 psf (with torch-applied vapor barrier) (See General Limitation #9)**

Or

TremPly KEE roof cover adhered with TremPly KEE LV Bonding Adhesive applied at a rate of 100 ft<sup>2</sup> per 1 gal. to the back side of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure: -210 psf (with self-adhered vapor barrier) (See General Limitation #9)**

**Maximum Design Pressure: -270 psf (with hot-applied vapor barrier or no vapor barrier) (See General Limitation #9)**

**Maximum Design Pressure:**

See Membrane Options Above.



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** Min. 272 psi Mearlcrete, or min 240 psi Elastizell LWIC cast over structural concrete  
**System Type A(6):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5 ” thick	N/A	N/A

**Note: All insulation shall be adhered to the substrate in Polyset Board-Max applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** TremPly KEE FB roof cover adhered with TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.  
*Maximum Design Pressure: -67.5 psf (See General Limitation #9)*

Or

TremPly KEE FB roof cover adhered with TremPly KEE FB Bonding Adhesive at 100 ft<sup>2</sup> per 1 gal. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.  
*Maximum Design Pressure: -105 psf (See General Limitation #9)*

Or

TremPly KEE roof cover adhered with TremPly KEE LV Bonding Adhesive applied at a rate of 100 ft<sup>2</sup> per 1 gal. to the back side of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.  
*Maximum Design Pressure: -180 psf for Elastizell (See General Limitation #9)*  
*Maximum Design Pressure: -210 psf for Mearlcrete (See General Limitation #9)*

**Maximum Design Pressure:** See Membrane Options Above.



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(7):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier:** Any UL or FM approved vapor barrier may be installed over the substrate.  
**(Optional)**

One or more layers of the following insulations:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, ACFoam-III, Multi-Max FA-3, H-Shield Minimum 1.5” thick	N/A	N/A
DensDeck Roof Board, DensDeck Prime Roof Board Minimum 0.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, ACFoam-III, Multi-Max FA-3, H-Shield Tapered	N/A	N/A

**Note: All insulation shall be adhered to the substrate or vapor barrier in 3-3.5” wide beads spaced 12” o.c. of Polyset Board-Max. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** TremPly KEE roof cover adhered to the insulation with TremPly KEE LV Bonding Adhesive applied at an application rate of 100 ft<sup>2</sup> per 1 gal. to the backside of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.  
 Or  
 TremPly KEE FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., or TremPly KEE FB Bonding Adhesive, solvent adhesive at 100 ft<sup>2</sup> per 1 gal.. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure:** -45 psf (See General Limitation #9)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(8):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier:** Any UL or FM approved vapor barrier may be installed over the substrate or the base layer of insulation.

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Ultra-Max, ENRGY 3, H-Shield Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
SECUROCK Gypsum-Fiber Roof Board Minimum 0.25” thick	N/A	N/A

**Note: All insulation shall be adhered to the substrate in 1/2” to 3/4” wide beads 12” o.c. of Tremco Low Rise Foam Insulation Adhesive or Tremco Low Rise Foam Insulation Adhesive (BG) or Tremco LR Adhesive or Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** TremPly KEE roof cover adhered to the insulation with TremPly KEE LV Bonding Adhesive applied at an application rate of 100 ft<sup>2</sup> per 1 gal. to the backside of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.  
 Or  
 TremPly KEE FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., or TremPly KEE FB Bonding Adhesive, solvent adhesive at 100 ft<sup>2</sup> per 1 gal. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure:** -157.5 psf (See General Limitation #9)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(9):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Hot asphalt-applied base and/or ply sheets or optional torch-applied base membrane approved for use with roof cover followed by an additional approved torch-applied sheet.

One or more layers of the following insulations:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum: 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum: 0.25” thick	N/A	N/A

**Note: All insulation shall be adhered to the substrate or vapor barrier in Polyset Board-Max applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** TremPly KEE roof cover adhered with TremPly KEE LV Bonding Adhesive applied at a rate of 100 ft<sup>2</sup> per 1 gal. to the back side of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.  
 Or  
 TremPly KEE FB roof cover adhered with hot asphalt at 25 lbs/sq. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure:** -105.0 psf (See General Limitation #9)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(10):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Hot-applied or Self-Adhering vapor barrier as indicated below:  
 Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional approved asphalt-applied sheet.  
 Self-adhered base membrane approved for use with roof cover followed by an additional approved self-adhered sheet.

One or more layers of the following insulations:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Insulfoam EPS Minimum: 1.5 ” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum: 0.25 ” thick	N/A	N/A

**Note: All insulation shall be adhered to the substrate or vapor barrier in Polyset Board-Max applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** TremPly KEE roof cover adhered with TremPly KEE LV Bonding Adhesive applied at a rate of 100 ft<sup>2</sup> per 1 gal. to the back side of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.  
 Or  
 TremPly KEE FB roof cover adhered with hot asphalt at 25 lbs/sq. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure:** -180 psf (See General Limitation #9)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(11):** All layers of insulation adhered subsequently membrane adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier:** Any approved asphaltic vapor barrier, or existing BUR.  
**(Optional)**

One or more layers of the following:

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
H-Shield, ENRGY3, AC Foam II, Multi-Max FA-3 Minimum 1.0" thick	N/A	N/A

**Note: Substrate shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the substrate in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** TremPly KEE roof cover adhered with TremPly KEE LV Bonding Adhesive applied at a rate of 100 ft<sup>2</sup> per 1 gal. to the back side of the membrane and to the substrate. The outside 1.5" of the lap is heat welded.

**Maximum Design Pressures:** -210.0 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(12):** One or more layers of insulation adhered with approved asphalt, membrane adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier:** Asphaltic Vapor Barrier.  
**(Optional)**

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3 Minimum 1.5” thick	N/A	N/A
DensDeck Prime Roof Board Minimum 0.25” thick	N/A	N/A

**Note: All insulation shall be adhered to the deck in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup> Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.**



**Membrane:** TremPly KEE roof cover adhered to the insulation with TremPly KEE LV Bonding Adhesive applied at an application rate of 100 ft<sup>2</sup> per 1 gal. to the backside of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.

Or

TremPly KEE FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., or TremPly KEE FB Bonding Adhesive, solvent adhesive at 100 ft<sup>2</sup> per 1 gal. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design**

**Pressure:** -187.5 psf; (See General Limitation #9.)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(13):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier:** Any UL or FM approved vapor barrier may be installed over the substrate.  
**(Optional)**

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, ACFoam-III, Multi-Max FA-3, H-Shield Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Roof Board, DensDeck Prime Roof Board Minimum 0.5” thick	N/A	N/A

**Note: All insulation shall be adhered to the substrate in 3-3.5” wide beads spaced 12” o.c. of Polyset Board-Max. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** TremPly KEE roof cover adhered to the insulation with TremPly KEE LV Bonding Adhesive applied at an application rate of 100 ft<sup>2</sup> per 1 gal. to the backside of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.  
 Or  
 TremPly KEE FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., or TremPly KEE FB Bonding Adhesive, solvent adhesive at 100 ft<sup>2</sup> per 1 gal. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure:** -262.5 psf (See General Limitation #9)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(14):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Hot-applied or Self-Adhering vapor barrier as indicated below:  
 Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional approved asphalt-applied sheet.  
 Self-adhered base membrane approved for use with roof cover followed by an additional approved self-adhered sheet.

One or more layers of the following insulations:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield, ENRGY 3, Insulfoam EPS (min. 2.0 pcf) Minimum: 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum: 0.25 ” thick	N/A	N/A

**Note: All insulation shall be adhered to the substrate with Polyset Board-Max applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** TremPly KEE roof cover adhered with TremPly KEE LV Bonding Adhesive applied at a rate of 100 ft<sup>2</sup> per 1 gal. to the back side of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.  
 Or  
 TremPly KEE FB roof cover adhered with hot asphalt at 25 lbs/sq. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure:** -195 psf (See General Limitation #9)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type A(15):** One or more layers of insulation adhered with approved adhesive, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier:** Any UL or FM approved asphaltic vapor barrier installed over the substrate.

One or more layers of the following insulations:

<u>Insulation Layer:</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, ACFoam-III, H-Shield Minimum 1.5” thick	N/A	N/A
DensDeck Roof Board, DensDeck Prime Roof Board Minimum ½” thick	N/A	N/A

**Note: All insulation shall be adhered to the substrate with Polyset Board-Max applied in 3” to 3½” ribbons spaced 12 in. o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** TremPly KEE roof cover adhered to the insulation with TremPly KEE LV Bonding Adhesive applied at an application rate of 50 ft<sup>2</sup> per 1 gal.  
 Or  
 TremPly KEE FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., TremPly KEE FB Bonding Adhesive, solvent adhesive at 90 ft<sup>2</sup> per 1 gal. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive at 100 ft<sup>2</sup> per 1 gal.

**Maximum Design Pressure:** -262.5 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** Min. 18-22ga steel  
**System Type B(1):** Base layer of insulation mechanically attached, top layer adhere; membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield		
Minimum 1.5" thick	Approved Fastener for Deck Type	1:2 ft <sup>2</sup>
Minimum 2" thick	Approved Fastener for Deck Type	1:4 ft <sup>2</sup>
DensDeck Roof Board, DensDeck Prime Roof Board		
Minimum 0.25" thick	Approved Fastener for Deck Type	1:2 ft <sup>2</sup>

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u> <u>(Optional)</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Multi-Max FA-3, H-Shield		
Minimum 1.5" thick	N/A	N/A

Note: Apply optional top layer of insulation in a full mopping of any approved mopping hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup> or in ¾" to 1" wide beads 12" o.c. of Tremco Low Rise Foam Insulation Adhesive or Tremco Low Rise Foam Insulation Adhesive (BG) or Tremco LR Adhesive or Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive or OlyBond Adhesive Fastener at application rate of 100 ft<sup>2</sup> per 1 gal.. Refer to Roofing Application Standard RAS 117 and insulation adhesive manufacturer's Roofing Component Product Control Approval for insulation attachment requirements. Insulations listed as base layer shall be used only as base layers with an optional top layer insulation installed as the final membrane substrate.



**Membrane:**

TremPly KEE roof cover adhered to the insulation with TremPly KEE LV Bonding Adhesive applied at an application rate of 100 ft<sup>2</sup> per 1 gal. to the backside of the membrane and to the substrate. The outside 1.5” of the lap is heat welded.

Or

TremPly KEE FB roof cover adhered to the insulation with approved asphalt at 20-25 lbs./sq., TremPly KEE FB Bonding Adhesive, solvent adhesive at 100 ft<sup>2</sup> per 1 gal. or TremPly KEE FB WB II Bonding Adhesive, water based adhesive 100 ft<sup>2</sup> per 1 gal. The outside 1.5” of the lap is heat welded.

**Maximum Design Pressure:**

-45 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** Min. 18-22 ga. steel deck.  
**System Type C(1):** All layers of insulation simultaneously attached over BUR or Modified Bitumen existing roof; Membrane adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations:

<b><u>Base Insulation Layer</u></b>	<b><u>Insulation Fasteners (Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
<b>ACFoam-II, H-Shield, H-Shield CG Maximum 1.0" thick</b>	<b>8 with 6</b>	<b>1:2 ft<sup>2</sup></b>
<b>SECUROCK Gypsum-Fiber Roof Board, DensDeck Prime Roof Board Maximum 1.0" thick</b>	<b>8 with 6</b>	<b>1:2 ft<sup>2</sup></b>

**Note: All layers shall be simultaneously fastened; see top or base layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** TremPly KEE FB roof cover fully adhered with spatter-applied Polyset Commercial Roof Adhesive. Laps are sealed with 1.5-inch heat weld.  
**Maximum Design Pressure:** -45.0 psf (See General Limitation #9)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank or Min. 22 ga., (*See Maximum Design Pressure below*) steel deck attached to structural supports spaced max. 6 ft o.c. attached with ITW Buildex Traxx/5 fasteners spaced max. 6 in. o.c. at supports (one fastener was installed at each bearing attachment). Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.**  
**System Type D(1):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ENRGY 3, Multi-Max FA-3, H-Shield, ACFoam II Maximum 1" thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Roof Board, DensDeck Prime Roof Board Maximum 1" thick	N/A	N/A
Structodek High Density Fiberboard Roof Insulation Maximum 1" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** TremPly KEE or TremPly KEE FB secured through the preliminarily attached insulation as described below.  
**Fastening #1:** (*ASTM A653 SS Grade 80 or A1008 SS Grade 80 Steel Deck or Structural Concrete*) Trufast #15 EHD fasteners and 2-3/4" Barbed Seam Plates (EHD) spaced 12" o.c. within the 6" wide side laps in rows spaced 94" o.c. The roof cover side laps are sealed with a minimum 1.5" heat weld.  
**Maximum Design Pressure: -45 psf. (See General Limitation #7)**



**Fastening #2:**

*(Type B Grade 80 Steel Deck or Structural Concrete)* Trufast #15 EHD fasteners and 2-3/4” Barbed Seam Plates (EHD) spaced 6” o.c. within the 6” wide side laps in rows spaced 94” o.c. The roof cover side laps are sealed with a minimum 1.5” heat weld.  
**Maximum Design Pressure: -67.5 psf. (See General Limitation #7)**

**Maximum Design Pressures:**

See Fastening Options Above



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** Min. 22 ga., ASTM A 653 Grade 33 steel deck secured to structural supports spaced maximum 6 ft o.c. with ITW Buildex Traxx/5 fasteners spaced 6" o.c. Deck side laps secured with ITW Buildex Traxx/1 fasteners spaced 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.**  
**System Type D(2):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam Composite, H-Shield, ENRGY 3, Ultra-Max, Thermarroof Composite-3, Maximum 1.0" thick	N/A	N/A
H-Shield-NB, H-Shield WF Maximum 1.0" thick	N/A	N/A
ACFoam-II, Structodek HD Fiberboard Roof Insulation Maximum 1.0" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** TremPly KEE or TremPly KEE FB secured through the preliminarily attached insulation as specified below.

**Fastening #1:** Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates, spaced 12" o.c. within the 5" laps in rows spaced 69" o.c. The side laps are sealed with a minimum 1.5" heat weld.  
**Note: H-Shield must be the base insulation layer used for this fastening method.**  
**Maximum Design Pressure: -45 psf. (See General Limitation #7)**

**Fastening #2:** Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates, spaced 6" o.c. within the 5" laps in rows spaced 69" o.c. The side laps are sealed with a minimum 1.5" heat weld.  
**Maximum Design Pressure: -60.0 psf. (See General Limitation #7)**

**Maximum Design Pressures:** See Fastening Options Above.



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank or Min.18, 20, or 22 ga. Grade 80, Type B steel deck secured to support at a maximum span of 6' o.c. Steel deck shall be fastened with SFS Impax 5 or ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with SFS ¼-14 Lap Tek or Traxx/1 screws at a maximum spacing of 30 inches o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.**  
**System Type D(3):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Any UL or FM approved vapor barrier applied to the substrate or over a base layer of insulation.  
**Fire Barrier: (Optional)** Min. ¼" DensDeck Roof Board or DensDeck Prime Roof Board attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Any approved polyisocyanurate Listed in Table 2 Minimum 1.5" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** TremPly KEE secured through the preliminarily attached insulation as specified below.  
**Fastening #1:** Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 72" o.c. The outside 1.5" of the lap is heat welded.  
*Maximum Design Pressure: -45 psf. (See General Limitation #7)*  
**Fastening #2:** Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 96" o.c. The outside 1.5" of the lap is heat welded.  
*Maximum Design Pressure: -52.5 psf. (See General Limitation #7)*  
**Maximum Design Pressures:** See Fastening Options Above



**Membrane Type:** Single Ply, KEE

**Deck Type 7I:** Recover, Insulated

**Deck Description:** 2500 psi. structural concrete or plank or Min. 22 ga., ASTM A653 or A1008 SS Grade 80 steel deck secured to structural supports spaced maximum 6 ft o.c. with Traxx/5 fasteners spaced 6" o.c. Deck side laps are secured with Traxx/1 fasteners spaced 30" o.c.

**This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.**

**System Type D(4):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Any UL or FM approved vapor barrier applied to the substrate or over a base layer of insulation.

**Fire Barrier: (Optional)** Min. ¼" DensDeck Roof Board or DensDeck Prime Roof Board attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Any approved polyisocyanurate Listed in Table 2 Minimum 1.5" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** TremPly KEE secured through the preliminarily attached insulation as specified below.

**Fastening #1:** Dekfast DF-#15-PH3 fasteners with Dekfast PLT-R-2-3/8-6B plates or Dekfast DF-#15-PH3 fasteners and *isofast* PLT-R-2-3/8-BL plates, spaced 6" o.c. within the 5" open laps in rows spaced 144.0" o.c., or installed through integral 3-1/2" fastening tab. The outside 1.5" of the lap is heat welded.  
**Maximum Design Pressure: -45 psf. (See General Limitation #7)**

**Fastening #2:** Dekfast DF-#15-PH3 fasteners with Dekfast PLT-R-2-3/8-6B plates or Dekfast DF-#15-PH3 fasteners and *isofast* PLT-R-2-3/8-BL plates, spaced 6" o.c. through the top of the roof cover in rows spaced 144.0" o.c. Rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab (closed lap configuration) over the fasteners. The edge of tab or both edges of cover strip are heat welded min. 1.5". Laps are sealed with 1.5-inch heat weld.  
**Maximum Design Pressure: -52.5 psf. (See General Limitation #7)**



**Fastening #3:**

Dekfast DF-#15-PH3 fasteners with Dekfast PLT-R-2-3/8-6B plates or Dekfast DF-#15-PH3 fasteners and *isofast* PLT-R-2-3/8-BL plates, spaced 6" o.c. within the 5" open laps in rows spaced 72.0" o.c., or installed through integral 3-1/2" fastening tab. The outside 1.5" of the lap is heat welded.

***Maximum Design Pressure: -67.5 psf. (See General Limitation #7)***

**Maximum Design Pressure:**

See Fastening Options Above.



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank or minimum 22 gage ASTM A 611 Grade 80 Type B Steel deck fastened to steel support at a maximum span of 6' o.c. Steel deck shall be fastened with ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with Traxx/1 screws at a maximum spacing of 30 inches o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.**  
**System Type D(5):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Any UL or FM approved vapor barrier applied to the substrate or over a base layer of insulation.  
**Fire Barrier: (Optional)** Min. ¼" DensDeck Roof Board or DensDeck Prime Roof Board attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Any approved polyisocyanurate Listed in Table 2 Minimum 1.5" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** TremPly KEE secured through the preliminarily attached insulation as specified below.  
**Fastening #1:** Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 18" o.c. within the 5" open laps in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.  
*Maximum Design Pressure: -45 psf. (See General Limitation #7)*  
**Fastening #2:** Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 12" o.c. in the 5" open laps in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.  
*Maximum Design Pressure: -60 psf. (See General Limitation #7)*



**Fastening #3:**

Fasten with Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 6" o.c. through the top of the roof cover spaced at maximum intervals of 104.5". Fastener rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab. (closed lap configuration) over the fasteners. The edge of the stripping and/or surface tabs shall be welded a minimum of 1". Laps are sealed with 1.5-inch heat weld.

***Maximum Design Pressure: -75 psf. (See General Limitation #7)***

**Maximum Design Pressures:**

See Fastening Options Above



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank or min. 18-22 ga., Type B, Grade 33 steel deck fastened to steel support at a maximum span of 6' o.c. Steel deck shall be fastened with SFS Impax 5 or ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with SFS ¼-14 Lap Tek or Traxx/1 screws at a maximum spacing of 30 inches o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.**  
**System Type D(6):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Any UL or FM approved vapor retarder applied to the substrate or over a base layer of insulation.  
**Fire Barrier: (Optional)** Min. ¼" DensDeck Roof Board or DensDeck Prime Roof Board attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Any approved polyisocyanurate Listed in Table 2 Minimum 1.5" thick	N/A	N/A

**Note:** All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

**Membrane:** TremPly KEE secured through the preliminarily attached insulation as specified below.  
**Fastening #1:** Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 12" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.  
*Maximum Design Pressure: -52.5 psf. (See General Limitation #7)*  
**Fastening #2:** Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.  
*Maximum Design Pressure: -60 psf. (See General Limitation #7)*  
**Maximum Design Pressures:** See Fastening Options Above



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank or min. 18-22 ga., Type B, Grade 80 steel deck fastened to steel support at a maximum span of 6' o.c. Steel deck shall be fastened with SFS Impax 5 or ITW Buildex Traxx/5 at a maximum spacing of 6" o.c. Side laps shall be fastened with SFS ¼-14 Lap Tek or Traxx/1 screws at a maximum spacing of 30 inches o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.**  
**System Type D(7):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Any UL or FM approved vapor retarder applied to the substrate or over a base layer of insulation.  
**Fire Barrier: (Optional)** Min. ¼" DensDeck Roof Board or DensDeck Prime Roof Board attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Any approved polyisocyanurate Listed in Table 2 Minimum 1.5" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** TremPly KEE secured through the preliminarily attached insulation as specified below.  
**Fastening #1:** Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 6" o.c. in the 5" lap of membrane in rows spaced 51" o.c. The outside 1.5" of the lap is heat welded.  
*Maximum Design Pressure: -67.5 psf. (See General Limitation #7)*  
**Maximum Design Pressures:** See Fastening Options Above



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank or min. 22 ga., Type B, Grade 80 steel deck placed over minimum 0.25" thick structural supports having maximum 6 ft spans. Deck shall be anchored with ITW Buildex Traxx/4 or Traxx/5 fasteners spaced at maximum 6" o.c. at supports. Deck side laps shall be secured with ITW Buildex Traxx/1 fasteners spaced at a maximum 18" o.c. \*The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 319 lbf when tested with fasteners, listed in this assembly, installed through to the deck in accordance with TAS 105.

**This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table.**

**System Type D(8):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Any UL or FM approved vapor retarder applied to the substrate or over a base layer of insulation.

**Fire Barrier: (Optional)** Min. ¼" DensDeck Roof Board or DensDeck Prime Roof Board attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Any approved polyisocyanurate Listed in Table 2 Minimum 1" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** TremPly KEE roof cover attached through the presecured insulation to the deck using Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 6" o.c. through the tabs spaced a maximum of 51" o.c. Laps are sealed with 1.5-inch heat weld.

**Maximum Design Pressures:** -75 psf (See General Limitation #7.)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank or minimum 20 ga., Type B, Grade 80 steel decking placed over minimum 0.25" thick structural supports having maximum 5 ft spans. Deck shall be anchored with ITW Buildex Traxx/4 or Traxx/5 fasteners spaced at maximum 6" o.c. at supports. Deck side laps shall be secured with ITW Buildex Traxx/1 fasteners spaced at a maximum 18" o.c. \* The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 784 lbf when tested with fasteners, listed in this assembly, installed through to the deck in accordance with TAS 105.

**This Tested Assembly has been analyzed for allowable deck stress. See Deck Stress Analysis Table**

**System Type D(9):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier: (Optional)** Any UL or FM approved vapor retarder applied to the substrate or over a base layer of insulation.

**Fire Barrier: (Optional)** Min. ¼" DensDeck Roof Board or DensDeck Prime Roof Board attached with 4 fasteners per 4' x 8' sheet.

One or more layers of the following:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Any approved polyisocyanurate Listed in Table 2 Minimum 1" thick	N/A	N/A

**Note:** All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

**Membrane:** TremPly KEE attached using Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 6" o.c. through the top of the membrane spaced at intervals of 104.5". Laps are sealed with 1.5-inch heat weld.

**Maximum Design Pressures:** -90 psf (See General Limitation #7.)



**Membrane Type:** Single Ply, KEE  
**Deck Type 7I:** Recover, Insulated  
**Deck Description:** 2500 psi. structural concrete or plank  
**System Type D(10):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier:** Any UL or FM approved vapor retarder applied to the substrate or over a base layer of insulation.  
**(Optional)**

**Fire Barrier:** Min. ¼" DensDeck Roof Board or DensDeck Prime Roof Board attached with 4 fasteners per 4' x 8' sheet.  
**(Optional)**

One or more layers of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft<sup>2</sup></u>
ACFoam-II, ACFoam-III, Ultra-Max, Multi-Max FA-3, ENRGY 3, H-Shield Minimum 1" thick	N/A	N/A
DensDeck Roof Board, DensDeck Prime Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** TremPly KEE roof cover attached through the preliminary fastened insulation to the deck following one of the fastening methods specified below:

**Fastening #1:** Fasten with Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 6" o.c. through 5" wide open laps with a minimum 1.5" field weld or through 3.5" fastening tabs; spaced 51" o.c. Laps are sealed with 1.5-inch heat weld.  
*Maximum Design Pressure: -112.5 psf. (See General Limitation #7)*

**Fastening #2:** Fasten with Dekfast DF-#15-PH3 fastener with Dekfast PLT-O-2-1/2-12B plates or TremPly Plus Stress Plates spaced 6" o.c. through roof cover in rows spaced 51" o.c. Rows are sealed by either welding a 6" cover strip or prefabricated 4.5" surface tab (closed lap configuration) over the fasteners. The edge of tab or both edges of cover strip are heat welded min. 1.5". Laps are sealed with 1.5-inch heat weld.  
*Maximum Design Pressure: -112.5 psf. (See General Limitation #7)*

**Maximum Design Pressures:** See Fastening Options Above



## RECOVER SYSTEM LIMITATIONS:

1. All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

## END OF THIS ACCEPTANCE

