



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

ICP Construction, Inc.
2775 Barber Road
Norton, OH 44203

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: APOC Polyset Commercial Roof Adhesives

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 23-0718.11 and consists of pages 1 through 3.
The submitted documentation was reviewed by Rafael Macedo.


05/14/26



NOA No. 25-1219.04
Expiration Date: 02/03/27
Approval Date: 05/14/26
Page 1 of 3

ROOFING COMPONENT APPROVAL:

Category: Roofing
Sub Category: Cements-Coatings-Adhesives
Materials: Polyurethane

SCOPE:

This approves **APOC Polyset Commercial Roof Adhesive & APOC Polyset Commercial Roof Adhesive Bulk**, manufactured by **ICP Construction, Inc.** in Tomball, TX as described in this Notice of Acceptance. The use of this acceptance is limited to those roof assemblies where Polyset Commercial Roof Adhesive & Polyset Commercial Roof Adhesive Bulk are specifically listed as accepted components in their Notice of Acceptance.

PRODUCT DESCRIPTION:

APOC Polyset Commercial Roof Adhesive is a dual component urethane adhesive with the properties described below:

<u>Property</u>	<u>Standard</u>	<u>Properties</u>
Flame Spread Index	ASTM E 84	15
Smoke Developed Index	ASTM E 84	200
Density	ASTM D 1622	2.8 lb/ft ³
Tensile Strength	ASTM D 1623	29 psi
Compressive Strength	ASTM D 1621	11 psi (Parallel to Rise)
		9 (Perp. To Rise)
Water Absorption	ASTM D 2842	4.2%
Self Ignition Temperature	ASTM D 1929	1000°F

APOC Polyset Commercial Roof Adhesive Bulk is a dual component urethane adhesive with the properties described below:

<u>Property</u>	<u>Standard</u>	<u>Properties</u>
Flame Spread Index	ASTM E 84	10
Smoke Developed Index	ASTM E 84	150
Density	ASTM D 1622	2.6 lb/ft ³
Tensile Strength	ASTM D 1623	41 psi
Compressive Strength	ASTM D 1621	12 psi
Water Absorption	ASTM D 2842	36.5%
Self Ignition Temperature	ASTM D 1929	684°F

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
NEMO ETC, LLC	Various Standards	4p-ICP-19-SSLAP-04.A	5/28/21
Intertek	Various Standards	4p-ICP-SSLAP-003.A	02/27/26
	ASTM E84	L6731.01-121-18-R0	1/19/21

MANUFACTURING LOCATION:

1. Tomball, TX.



NOA No. 25-1219.04
Expiration Date: 02/03/27
Approval Date: 05/14/26
Page 2 of 3

LIMITATIONS:

1. Fire classification is not a part of this Notice of Acceptance. Maximum design pressure ratings shall be as define in the Roof Assembly Notice of Acceptance.
2. **Polyset Commercial Roof Adhesive & Polyset Commercial Roof Adhesive Bulk** are components used in approved roof assemblies. Roof assemblies are approved under specific roof assembly Notice of Acceptances.
3. **Polyset Commercial Roof Adhesive & Polyset Commercial Roof Adhesive Bulk** may be used with any approved roof assembly listing **Polyset Commercial Roof Adhesive & Polyset Commercial Roof Adhesive Bulk** as a component part of an assembly in the approval.
4. **Polyset Commercial Roof Adhesive & Polyset Commercial Roof Adhesive Bulk** shall have a quality control testing program by an approved independent listing agency having unannounced follow-up visits. Follow up test results shall be made available to Miami-Dade Country Product Control Division upon request.

INSTALLATION:

Polyset Commercial Roof Adhesive & Polyset Commercial Roof Adhesive Bulk shall be installed in strict compliance with the roof assembly's Notice of Acceptance, and manufacturer's published literature.

LABELING:

ICP Construction, Inc. shall mark each packing container or label with manufacturer's name, address, shelf life of product, and with the Miami-Dade County Product Control Seal as shown below or the words "Miami-Dade Approved."



BUILDING PERMIT REQUIREMENTS:

As required by the Building Official or applicable Building Code in order to properly evaluate the installation of this product. This Notice of Acceptance on its own cannot be used to obtain a building permit.

END OF THIS ACCEPTANCE

