



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Johns Manville Corporation
717 17th Street
Denver, CO 80202

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Johns Manville APP Modified Bitumen Roofing Systems Over Wood Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA# 21-0303.08 and consists of pages 1 through 12.
The submitted documentation was reviewed by Alex Tigera.

06/25/26



NOA No.: 26-0316.08
Expiration Date: 06/28/31
Approval Date: 06/25/26
Page 1 of 12

ROOFING SYSTEM APPROVAL

<u>Category:</u>	Roofing
<u>Sub-Category:</u>	Modified Bitumen
<u>Materials:</u>	APP/SBS
<u>Deck Type:</u>	Wood
<u>Maximum Design Pressure:</u>	-82.5 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
JM APP Base	39-3/8" x 48'10"	ASTM D6509	APP modified asphalt, fiberglass reinforced, smooth surfaced base sheet.
APPeX 4S	39-3/8" x 32'10"	ASTM D6222 Type I Grade S	APP modified asphalt, polyester reinforced, smooth surfaced membrane for use as a Base and/or Ply Sheet only.
APPeX 4.5M	39-3/8" x 32'10"	ASTM D6222 Type I Grade G	APP modified asphalt, polyester reinforced, mineral surfaced membrane.
APPeX 4.5M FR	39-3/8" x 32'10"	ASTM D6222 Type I Grade G	APP modified asphalt, polyester reinforced, fire-retardant, mineral surfaced membrane.
Tricor M FR	39-3/8" x 34'1"	ASTM D6223	APP modified asphalt, polyester / glass reinforced, granule surfaced membrane.
Tricor M FR CR	39-3/8" x 34'1"	ASTM D6223	APP modified asphalt, polyester / glass reinforced, coated granule surfaced membrane.
Tricor S	39-3/8" x 32'10"	ASTM D6223	APP modified asphalt, polyester / glass reinforced, smooth surfaced membrane for use as a Base and/or Ply Sheet only.
PermaPly 28	36" x 106'	ASTM D4601	Type II asphalt impregnated and coated glass fiber base sheet.
Ventsulation	36" x 36'	ASTM D4897 Type II	Heavy duty fiber glass base sheet impregnated and coated on both sides with asphalt with or without fine mineral stabilizer.
GlasBase Plus	36" x 106'	ASTM D4601	Type II SBS and asphalt blend impregnated and coated glass fiber base sheet with fine mineral stabilizer.



DynaFast 180 S	39-3/8" x 49'2"	ASTM D6164	SBS modified asphalt, polyester reinforced, smooth surfaced sheet.
DynaFast 180 HW	39-3/8" x 49'2"	ASTM D6164	SBS modified asphalt, polyester reinforced, smooth surfaced sheet.
DynaFast 250 HW	39-3/8" x 32'10"	ASTM D6164	SBS modified asphalt, polyester reinforced, smooth surfaced base sheet.
DynaWeld 250 S	39-3/8" x 32'10"	ASTM D6164 Type II Grade S	SBS modified asphalt, polyester reinforced, smooth surfaced sheet.
JM Roofing System Urethane Adhesive	N/A	Proprietary	A two-part urethane insulation adhesive.
JM Two-Part Urethane Insulation Adhesive	Various	Proprietary	A two-component, cold-applied adhesive
JM Two-Part UIA	Various	Proprietary	A two-component, cold-applied adhesive
JM Two-Part Urethane Insulation Adhesive Canister	Various	Proprietary	Self-contained two-part, low-rise foam adhesive
JM Two-Part UIA Canister	Various	Proprietary	Self-contained two-part, low-rise foam adhesive

APPROVED INSULATIONS:

<u>Product Name</u>	<u>TABLE 2 Product Description</u>	<u>Manufacturer (With Current NOA)</u>
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI	Polyisocyanurate Insulation.	Johns Manville
ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI	Polyisocyanurate Insulation with glass reinforced facers.	Johns Manville
ENRGY 3 FR, ENRGY 3 FR 25 PSI	Polyisocyanurate Insulation with inorganic coated glass reinforced facers; bottom face is premium coated for combustible decks.	Johns Manville



ENRGY 3 C1, ENRGY 3 C1 CGF	Polyisocyanurate foam insulation	Atlas Roofing Corp.
Fesco Foam, DuraFoam	Polyisocyanurate Insulation with perlite facer.	Johns Manville
Retro-Fit Board, DuraBoard	High-density perlite roof insulation.	Johns Manville
Retro Plus Roof Board	High density perlite cover board	Johns Manville
ProtectoR HD	High-Density polyiso cover board	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
Structodek® High Density Fiber Board Roof Insulation	High Density Fiber Board.	Blue Ridge Fiberboard, Inc.
JM SECUROCK Gypsum-Fiber Roof Board	Rigid, gypsum-based board stock	Johns Manville
DEXcell FA Glass Mat Roof Board	Fire barrier and thermal barrier	National Gypsum Company
DensDeck Prime	Silicon treated gypsum	Georgia Pacific Gypsum, LLC

APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	UltraFast Fasteners	Insulation fastener for wood and steel.	#12 x 8" max. Length, #3 Phillips head	Johns Manville
2.	UltraFast Metal Plate Recessed or UltraFast Plate Metal (Round)	Galvalume AZ55 steel plate	3" round & 3" square	Johns Manville
3.	All Purpose Fastener	Insulation fastener for wood, concrete and steel.	#14 x 24" max. #3Phillips head	Johns Manville
4.	High Load Fastener	Membrane fastener	#15 x 14" max. #3Phillips head	Johns Manville
5.	High Load Plates	Seam plate with reinforcing ribs and eyehooks	2-3/8" round steel plate	Johns Manville
6.	Polymer Membrane Batten	Plastic membrane batten strips.	1" x 250'	OMG, Inc.



7.	High Load LH	#15 Large Head fastener for steel, wood, or concrete	#15 x 14" max. Oversize #3 Phillips head	OMG, Inc.
8.	APB Plates	Steel Seam plate with reinforcing ribs and barbs.	2" round	Johns Manville

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
FM Approvals	3037540	4450	10/20/10
	3054150	4470	05/13/15
	3062497	4470	04/18/18
	3063554	4470	02/15/18
UL LLC	R10167	UL 790	05/12/21
Exterior Research & Design, LLC	#4361-2.04.97-1	TAS 114(J)	04/15/97
	10390A.12.97-1	TAS 114(J)	12/15/97
PRI Construction Materials, LLC	JMC-088-02-01.8	Various	08/28/20
	JMC-107-02-01.8	ASTM D903/D1876/D5147	09/17/20
		TAS 117(B) & 117(A)	
		TAS 114(C)	
	JMC-126-02-01	TAS 114(J)	04/17/13
	JMC-167-02-01	TAS 114(C)	08/05/13
	JMC-222-02-04	TAS 114(J)	08/14/15
	JMC-242-02-01	TAS 114(J)	11/18/15
	507T0412	TAS 114 (E)	09/23/24
	507T0438	TAS 114 (E)	08/13/24



APPROVED ASSEMBLIES

Membrane Type:	APP
Deck Type 3I:	Wood, Insulated
Deck Description:	¹⁹ / ₃₂ " or greater CDX plywood fastened with 0.113" x 2-3/8" ring shank nails at 6" o.c. to supports having a maximum spacing of 24".
System Type A:	One or more layers of insulation adhered with approved asphalt.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI, ENRGY 3 C1, ENRGY 3 C1 CGF Minimum 1.5" thick	1 with 2	1:1.33 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
JM SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board, DensDeck Prime Minimum ½" thick	N/A	N/A

Note: Top layer of insulation shall be adhered with JM Roofing System Urethane Adhesive, JM One-Step Foamable Adhesive, JM Two Part Urethane Insulation Adhesive, JM Two-Part UIA, JM Two-Part Urethane Insulation Adhesive Canister, JM Two-Part UIA Canister and applied in ¾" to 1" wide beads spaced maximum 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	DynaWeld 250 S, DynaFast 180 HW, or DynaFast 250 HW fully bonded by torch adhering with minimum 3" side laps.
Ply Sheet (Optional):	One or more plies of DynaFast 180 HW, DynaWeld 250 S or DynaFast 250 HW heat welded while maintaining minimum 4" side laps.
Membrane:	One or more plies of APPEX 4.5M FR, Tricor M FR, or Tricor M FR CR heat welded while maintaining 4" side laps.
Maximum Design Pressure:	-67.5 psf. (See General Limitation #7.)



Membrane Type:	APP
Deck Type 3I:	Wood, Insulated
Deck Description:	¹⁹ / ₃₂ " or greater plywood or wood plank fastened with #8 screws at 6" o.c. to supports having a maximum spacing of 24".
System Type D(1):	One or more layers of insulation and base sheet simultaneously attached.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, Fesco Foam, DuraFoam, ENRGY 3 FR, ENRGY 3 FR 25 PSI, ENRGY 3 C1, ENRGY 3 C1 CGF, DuraFoam, Fesco Foam Minimum 1.5" thick	N/A	N/A
Fesco Board Minimum ¾" thick	N/A	N/A
Retro-Fit Board, DuraBoard, RetroPlus Roof Board, Strucktodek High-Density Fiber Board, Minimum ½" thick	N/A	N/A
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board, or Protector HD Minimum ¼" thick	N/A	N/A

Note: Insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Fire Barrier (Optional):	One or more plies of PermaPly 28, GlasBase Plus or Ventsulation, preliminarily fastened below the base sheet.
Base Sheet:	Minimum two plies of JM APP Base simultaneously fastened through the insulation to the deck with Ultrafast Fasteners and Square Metal Plates spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.
Ply Sheet (Optional):	One or more plies of JM APP Base or APPeX 4S heat welded to base sheet while maintaining 4" side laps and 6" end laps.
Membrane:	One or more plies of APPeX 4.5M or APPeX 4.5M FR heat welded while maintaining 4" side laps and 6" end laps.



**Surfacing
(Optional):**

Install one of the following for all systems that do not achieve acceptable fire ratings through the use of FR membrane sheets. Any coating, listed below, used as a surfacing, must be listed within a current NOA.

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at a rate of 60 lb./sq.
2. Karnak 97, Karnak 97 AF, Monsey Premium Long Life Aluminum Roof Coating Asbestos Free or Monsey Prograde Aluminum, Grundy AL MB aluminum coating at a rate of 1-1/2 gal./sq. Monsey Aquabrite, Gardner asphalt emulsion, APOC Sunbright 400 or Henry 229 Aluminum Emulsion at 2½ gal./sq. or APOC 212 Aluminum Roof Coating at 3 gal./sq.
3. Grundy 20 F asphalt emulsion, Endure Asphalt Emulsion, APOC 302 or 302 AF applied at 2½ gal./sq. with optional 60 lbs./sq. of roofing granules embedded in wet coating.

**Maximum Design
Pressure:**

-52.5 psf. (See General Limitation #7.)



Membrane Type:	APP
Deck Type 3I:	Wood, Insulated
Deck Description:	¹⁹ / ₃₂ " or greater plywood or wood plank fastened with #8 screws at 6" o.c. to supports having a maximum spacing of 24".
System Type D(2):	One or more layers of insulation and base sheet simultaneously attached.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI, ENRGY 3 C1, ENRGY 3 C1 CGF, DuraFoam, FescoFoam Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
RetroPlus Roof Board, Strucktodek High-Density Fiber Board, DuraBoard, Retro-Fit Board Minimum ½" thick	N/A	N/A
Fesco Board Minimum ¾" thick	N/A	N/A
DensDeck Prime, SECUROCK Gypsum-Fiber RoofBoard, DEXcell FA Glass Mat Roof Board, or ProtectoR HD Minimum ¼" thick	N/A	N/A

Note: Top insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Fire Barrier (Optional):	One or more plies of PermaPly 28, GlasBase Plus or Ventsulation, preliminarily fastened below the base sheet.
Base Sheet:	(Option #1) One ply of DynaFast 180 HW, DynaWeld 250 S, or DynaFast 250 HW mechanically fastened through the insulation with High Load LH and Polymer Membrane Batten spaced 6" o.c. in the center of the minimum 4" torch welded side laps. (Option #2) One ply of DynaFast 180 HW, DynaWeld 250 S, or DynaFast 250 HW mechanically fastened through the insulation with High Load Fastener & APB Plates or High Load Plates spaced 9" o.c. in the center of the minimum 4" torch welded side laps.
Ply Sheet (Optional):	One or more plies of DynaFast 180 HW, DynaWeld 250 S or DynaFast 250 HW heat welded while maintaining minimum 4" side laps.



Membrane: One or more plies of APpeX 4.5 M FR, Tricor M FR, Tricor M FR CR heat welded while maintaining 4" side laps.

Maximum Design Pressure: -82.5 psf. with Base Sheet Option 1 (See General Limitation #7.)
-60 psf. with Base Sheet Option 2 (See General Limitation #7.)



Membrane Type:	APP
Deck Type 3I:	Wood, Insulated
Deck Description:	¹⁹ / ₃₂ " or greater plywood or wood plank fastened with #8 screws at 6" o.c. to supports having a maximum spacing of 24".
System Type E:	Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet:	(Option #1) Minimum two plies of JM APP Base simultaneously fastened to the deck lapped 4" and fastened with approved roofing nails and tin caps 9" o.c. at the lap and two rows staggered in the center of the sheet 12" o.c. (Option #2) Minimum two plies of JM APP Base simultaneously fastened to the deck with Ultrafast Fasteners and Square Metal Plates spaced 9" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.
Ply Sheet (Optional):	One or more plies of JM APP Base or APPeX 4S heat welded to base sheet while maintaining 4" side laps and 6" end laps.
Membrane:	One or more plies of APPeX 4.5M or APPeX 4.5M FR heat welded while maintaining 4" side laps and 6" end laps.
Surfacing (Optional):	Install one of the following for all systems that do not achieve acceptable fire ratings through the use of FR membrane sheets. Any coating, listed below, used as a surfacing, must be listed within a current NOA. 1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at a rate of 60 lb./sq. 2. Karnak 97, Karnak 97 AF, Monsey Premium Long Life Aluminum Roof Coating Asbestos Free or Monsey Prograde Aluminum, Grundy AL MB aluminum coating at a rate of 1-1/2 gal./sq. Monsey Aquabrite, Gardner asphalt emulsion, APOC Sunbright 400 or Henry 229 Aluminum Emulsion at 2½ gal./sq. or APOC 212 Aluminum Roof Coating at 3 gal./sq. 3. Grundy 20 F asphalt emulsion, Endure Asphalt Emulsion, APOC 302 or 302 AF applied at 2½ gal./sq. with optional 60 lbs./sq. of roofing granules embedded in wet coating.
Maximum Design Pressure:	-52.5 psf. (See General Limitation #7.)



WOOD DECK SYSTEM LIMITATIONS:

- 1 A slip sheet is required with Ply 4 and Ply 6 when used as a mechanically fastened base or anchor sheet.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
- 10.. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

