



**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

**DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION**

NOTICE OF ACCEPTANCE (NOA)

**Continental Materials, Inc.
1614 Old York Road
Abington, PA 19001**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: CMI Self-Adhered Roof Underlayment

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 25-0717.01 consists of pages 1 through 5.
The submitted documentation was reviewed by Rafael Macedo.

05/28/26



**NOA-No.: 26-0408.03
Expiration Date: 10/23/30
Approval Date: 05/28/26
Page 1 of 5**

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Materials: SBS

SCOPE:

This acceptance is for **SecureGrip Ice and Water Self-Adhered Roof Underlayment**, as described in this Notice of Acceptance, for use with approved prepared roof assemblies as described in this Notice of Acceptance; designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
SecureGrip Ice & Water <i>Manufacturing Location #1</i>	36" x 65' rolls	ASTM D1970	SBS self-adhering asphalt sheet material for use as an underlayment for slate, shake, and asphalt shingle roofing
Topshield Ice & Water <i>Manufacturing Location #1</i>	36" x 65' rolls	ASTM D1970	SBS self-adhering asphalt sheet material for use as an underlayment for slate, shake, and asphalt shingle roofing.
SecureGrip PS/Max 100 HT <i>Manufacturing Location #1</i>	36" x 67' rolls	ASTM D1970 TAS 110	0.040" to 0.048" thick self-adhering polymer modified bitumen underlayment.
SecureGrip PS/Max HT 2.0 <i>Manufacturing Location #1</i>	36" x 67' rolls	ASTM D1970 TAS 110	0.040" to 0.048" thick self-adhering polymer modified bitumen underlayment.
Topshield PS/Max HT 2.0 <i>Manufacturing Location #1</i>	36" x 67' rolls	ASTM D1970 TAS 110	0.040" to 0.048" thick self-adhering polymer modified bitumen underlayment.
Topshield PS/Max 100 HT <i>Manufacturing Location #1</i>	36" x 67' rolls	ASTM D1970 TAS 110	0.040" to 0.048" thick self-adhering polymer modified bitumen underlayment.
Topshield Ice & Water IWX <i>Manufacturing Location #1</i>	36" x 66' rolls	ASTM D1970 TAS 110	SBS modified self-adhesive bitumen underlayment reinforced with a glass mat, topside surfaced with non-woven film and silicone release film underneath.
SecureGrip Ice & Water Xtra <i>Manufacturing Location #1</i>	36" x 66' rolls	ASTM D1970 TAS 110	SBS modified self-adhesive bitumen underlayment reinforced with a glass mat, topside surfaced with non-woven film and silicone release film underneath.
SecureGrip Xtra Roof Deck Seam Tape <i>Manufacturing Location #1</i>	36" x 66' rolls	ASTM D1970 TAS 110	SBS modified self-adhesive bitumen underlayment reinforced with a glass mat, topside surfaced with non-woven film and silicone release film underneath.
Topshield Roof Deck Seam Tape <i>Manufacturing Location #1</i>	36" x 66' rolls	ASTM D1970 TAS 110	SBS modified self-adhesive bitumen underlayment reinforced with a glass mat, topside surfaced with non-woven film and silicone release film underneath.



NOA-No.: 26-0408.03
Expiration Date: 10/23/30
Approval Date: 05/28/26
Page 2 of 5

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
SecureGrip Starter SA <i>Manufacturing Location #1</i>	36" x 65' rolls	ASTM D1970	Self-adhering, granule surfaced, fiberglass reinforced, modified bitumen sheet material with a release liner and a single sealing stripe line on the surface located approximately 1-1/2" of one edge
Topshield S/A Roll Starter <i>Manufacturing Location #1</i>	36" x 65' rolls	ASTM D1970	Self-adhering, granule surfaced, fiberglass reinforced, modified bitumen sheet material with a release liner and a single sealing stripe line on the surface located approximately 1-1/2" of one edge

MANUFACTURING LOCATION:

1. Umm Al Quwain, UAE

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
NEMO ETC, LLC	4j-INBT-23-SSUDL-02.A	ASTM D1970	10/12/23
	4j-INBT-SSUDL-010.C	ASTM D1970 / TAS 110	04/22/26
	4j-INBT-SSUDL-013.B	ASTM D1970 / TAS 110	04/22/26
	4j-INBT-SSUDL-014.B.R1	ASTM D1970	04/22/26
	4j-INBT-SSUDL-014.C	ASTM D1970	04/22/26

APPROVED ASSEMBLIES:

Deck Type 1: Wood, Non-insulated

Deck Description: 1/2" or greater plywood or wood plank.

System E: Base sheet mechanically fastened, membrane adhered.

Base Sheet: One or more plies of ASTM D226 Type II or ASTM D2626 with a minimum 4" side lap and a 6" end lap mechanically fastened to deck with approved nails and tin caps 6" o.c. at the laps and two staggered rows 12" o.c. the field of the roll.

Membrane: One ply of SecureGrip Ice & Water, Topshield Ice & Water, SecureGrip PS/Max 100 HT, SecureGrip PS/Max HT 2.0, Topshield PS/Max HT 2.0, Topshield PS/Max 100 HT, Topshield Ice & Water IWX, SecureGrip Ice & Water Xtra, SecureGrip Xtra Roof Deck Seam Tape SecureGrip S/A Starter Roll, or Topshield Starter Roll S/A with minimum 3-inch horizontal laps and 6-inch vertical laps. Starting at the first course, parallel to the eave. Peel back 1 to 2 feet of the release liner, align the membrane and then continue to peel the release liner from the membrane. Hand press or walk the membrane onto the surface, then follow with a 40 pound or heavier pressure roller to smooth and secure the membrane, especially at overlap areas. If a roller is not available or considered safe in the circumstance, walk-in all laps and as much of the field area as possible to secure the adhesive into the pores of the roof deck and overlap areas.

Surfacing: Approved for Mechanically Fastened slate, shake, asphalt shingles and metal roof applications.
Tile Roofing is not an approved roof covering for use with this assembly.



NOA-No.: 26-0408.03
Expiration Date: 10/23/30
Approval Date: 05/28/26
Page 3 of 5

Deck Type 1:	Wood, non-insulated
Deck Description:	¹⁹ / ₃₂ " or greater plywood or wood plank.
System F:	Membrane adhered direct to deck.
Membrane:	One ply of SecureGrip Ice & Water, Topshield Ice & Water, SecureGrip PS/Max 100 HT, SecureGrip PS/Max HT 2.0, Topshield PS/Max HT 2.0, Topshield PS/Max 100 HT, Topshield Ice & Water IWX, SecureGrip Ice & Water Xtra, SecureGrip Xtra Roof Deck Seam Tape SecureGrip S/A Starter Roll, or Topshield Starter Roll S/A self-adhered in accordance with FBC HVHZ 1518.2.1(1) and back-nailed using 12 ga. x 1- ¹ / ₄ " long x 3/8 head diameter annular ring shank roofing nails with 32 ga., 1- ⁵ / ₈ " diameter tin caps max 12" o.c.
Surfacing:	Approved for Mechanically Fastened slate, shake, asphalt shingles and metal roof applications. Tile Roofing is not an approved roof covering for use with this assembly.

LIMITATIONS:

1. Fire classification is not part of this acceptance.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with the applicable building code. **SecureGrip Ice & Water, Topshield Ice & Water, SecureGrip PS/Max 100 HT, SecureGrip PS/Max HT 2.0, Topshield PS/Max HT 2.0, Topshield PS/Max 100 HT, Topshield Ice & Water IWX, SecureGrip Ice & Water Xtra, SecureGrip Xtra Roof Deck Seam Tape SecureGrip S/A Starter Roll, or Topshield Starter Roll S/A** shall be installed in strict compliance with the applicable building code.
3. **SecureGrip Ice & Water, Topshield Ice & Water, SecureGrip PS/Max 100 HT, SecureGrip PS/Max HT 2.0, Topshield PS/Max HT 2.0, Topshield PS/Max 100 HT, Topshield Ice & Water IWX, SecureGrip Ice & Water Xtra, SecureGrip Xtra Roof Deck Seam Tape SecureGrip S/A Starter Roll, or Topshield Starter Roll S/A** shall be applied to a smooth, clean and dry surface, free from irregularities. Re-fasten any loose decking panels, and check for protruding nail heads. Sweep the substrate thoroughly to remove any dust and debris prior to application. When a smooth, clean and/or dry surface cannot be obtained, the substrate shall be primed with Elastocol Stick prior to application..
4. **SecureGrip Ice & Water, Topshield Ice & Water, SecureGrip PS/Max 100 HT, SecureGrip PS/Max HT 2.0, Topshield PS/Max HT 2.0, Topshield PS/Max 100 HT, Topshield Ice & Water IWX, SecureGrip Ice & Water Xtra, SecureGrip Xtra Roof Deck Seam Tape SecureGrip S/A Starter Roll, or Topshield Starter Roll S/A** shall not be applied over an existing roof membrane as a recover system but may be applied over a roofing Base/Anchor sheet underlayment.
5. **SecureGrip Ice & Water, Topshield Ice & Water, SecureGrip PS/Max 100 HT, SecureGrip PS/Max HT 2.0, Topshield PS/Max HT 2.0, Topshield PS/Max 100 HT, Topshield Ice & Water IWX, SecureGrip Ice & Water Xtra, SecureGrip Xtra Roof Deck Seam Tape SecureGrip S/A Starter Roll, or Topshield Starter Roll S/A** is acceptable for use in mechanically fastened slate, shake, and asphalt shingle roofing as specified in the surfacing option of the approved roof covering assemblies.
6. **SecureGrip Ice & Water, Topshield Ice & Water, SecureGrip S/A Starter Roll, and Topshield Starter Roll S/A** not be left exposed as a temporary roof for longer than 30 days.
7. **Topshield Ice & Water IWX, SecureGrip Ice & Water Xtra, SecureGrip Xtra Roof Xtra Roof Deck Seam Tape, & Topshield Roof Deck Seam Tape** not be left exposed as a temporary roof for longer than 90 days.
8. **SecureGrip PS/Max 100 HT, SecureGrip PS/Max HT 2.0, Topshield PS/Max HT 2.0, Topshield PS/Max 100 HT** not be left exposed as a temporary roof for longer than 180 days.



LIMITATIONS:

9. **SecureGrip Ice & Water, Topshield Ice & Water, SecureGrip PS/Max 100 HT, SecureGrip PS/Max HT 2.0, Topshield PS/Max HT 2.0, Topshield PS/Max 100 HT, Topshield Ice & Water IWX, SecureGrip Ice & Water Xtra, SecureGrip Xtra Roof Deck Seam Tape SecureGrip S/A Starter Roll, or Topshield Starter Roll S/A** may be used with any approved roof covering listing SecureGrip Ice & Water within the Product Approval. If **SecureGrip Ice & Water, Topshield Ice & Water, SecureGrip PS/Max 100 HT, SecureGrip PS/Max HT 2.0, Topshield PS/Max HT 2.0, Topshield PS/Max 100 HT, Topshield Ice & Water IWX, SecureGrip Ice & Water Xtra, SecureGrip Xtra Roof Deck Seam Tape SecureGrip S/A Starter Roll, or Topshield Starter Roll S/A** is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval based on the necessary documentation to detail compatibility of the products, wind uplift resistance and fire resistance results.
10. When applying the membrane in the valley, start at the low point and work to the high point, rolling the membrane from the center outward in both directions. For ridge applications, center the membrane and roll from the center outwards in both directions.
11. Membrane shall be applied to protrusions, slope changes, valley, curb, and other roof top penetration details before any other sections of the roof.
12. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
13. All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE

