



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

Sika Corporation
201 Polito Avenue
Lyndhurst, New Jersey 07071

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Sika Tile-100 Moisture Guard Waterproofing System

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 22-1101.01 and consists of pages 1 through 4.

The submitted documentation was reviewed by Rafael Macedo.

07/16/26



NOA No.: 26-0504.02
Expiration Date: 10/06/26
Approval Date: 07/16/26
Page 1 of 4

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Waterproofing
Deck Type: Concrete
Material: Elastomeric
Maximum Design Pressure: -465 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Container Sizes</u>	<u>Test Specification</u>	<u>Product Description</u>
Sika Tile-100 Moisture Guard	1 gallon Pail, 5 gallon Pail	ASTM C836	Ready-to-use elastomeric waterproofing and crack prevention membrane.

TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
Exterior Ceramic Tiles	12" x 12" x ½"	ANSI A137.1	Ceramic plaza deck walking tiles, 5% water absorption max.	Generic
Sika Tile-395 LHT Set	50 lb. Bags	ANSI A118.4	Polymer-Modified Portland Cement Thin Set Mortar.	Sika Corporation
Sika Tile-305 Pro Set	50 lb. Bags	ANSI A118.4	Polymer-Modified Portland Cement Thin Set Mortar.	Sika Corporation
Sika Tile-350 Flex Set White	50 lb. Bags	ANSI A118.4	Polymer-Modified Portland Cement Thin Set Mortar.	Sika Corporation

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Specification</u>	<u>Test Date</u>
PRI Construction Materials Technologies	PARE-003-02-01	ASTM C836	02/08/16
	PARE-004-02-01	ASTM D7105	02/08/16
	PARE-006-02-01	TAS 114 D	02/08/16



NOA No.: 26-0504.02
Expiration Date: 10/06/26
Approval Date: 07/16/26
Page 2 of 4

APPROVED ASSEMBLIES:

Deck Type 3:	Concrete Decks, Non-Insulated
Deck Description:	Min. 2500 psi structural concrete or concrete plank
System Type:	Fully adhered waterproofing membrane with ceramic tile finish
Substrate Preparation:	All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants.
Coating:	Apply Sika Tile-100 Moisture Guard Coating in 2-coats, each coat to achieve a 30 mils wet film (40 mils sum total dry film thickness of combined coats). For details on application methods and coverage, refer to manufacturer's Installation Instructions on Product Data Sheet.
Integrity Test:	Required, and shall be performed in accordance with ASTM D 5957 by an approved lab. Water may be maintained for a period longer than 24 hours if required.
Inspection:	Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. All defects shall be corrected.
Surfacing:	Exterior grade ceramic plaza deck walking tiles (minimum 12" x 12" x $\frac{5}{16}$ " thick, maximum 24" x 24" x $\frac{7}{16}$ " thick). Tiles shall be embedded into Thin-Set/Mortar listed in Table 2 herein, applied with $\frac{1}{4}$ " x $\frac{1}{4}$ " square notched trowel and as specified in Thin-Set/Mortar manufacturer's installation specifications. Tiles should then be carefully embedded in the mortar bed and tapped in place to insure full solid bearing. Tile shall be installed in accordance with applicable Building Code.
Maximum Design Pressure:	-465 psf. (See General Limitation #9)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. A copy of the integrity test report described herein in accordance with ASTM D5957 shall be provided to the Building Official for review at time of final inspection.
3. Contractor shall submit to the Building Official for review the system specifications and details. Submission of these documents, as well as the proper application and installation details of all materials shall be the sole responsibility of the contractor.
4. Flashings shall be installed according to the manufacturers published standard details, specific details, approved by Sika Corporation and shall be submitted to the Building Official for review.
5. All work shall be performed by a Contractor licensed to do roofing/waterproofing and be a Manufacturer Trained 'Qualified Applicator' approved by Sika Corporation shall supply a list of approved applicators to the authority having jurisdiction.
6. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and the wind load requirements of applicable Building Code.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. Sika Tile-100 Moisture Guard Coating shall be covered with surfacing and shall not be left exposed.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. Sika Tile-100 Moisture Guard Coating shall not be installed over lightweight insulating concrete.
11. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

