



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Johns Manville Corporation**  
717 17th Street  
Denver, CO 80202

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Johns Manville Built-Up Roofing Systems Over Steel Decks.

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA# 21-0303.13 and consists of pages 1 through 9.  
The submitted documentation was reviewed by Alex Tigera.

07/16/26



NOA No.: 26-0526.02  
Expiration Date: 07/19/31  
Approval Date: 07/16/26  
Page 1 of 9

## ROOFING SYSTEM APPROVAL

|                                        |                  |
|----------------------------------------|------------------|
| <b><u>Category:</u></b>                | Roofing          |
| <b><u>Sub-Category:</u></b>            | Built-up Roofing |
| <b><u>Materials:</u></b>               | Fiberglass       |
| <b><u>Deck Type:</u></b>               | Steel            |
| <b><u>Maximum Design Pressure:</u></b> | -60 psf.         |

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

| <b><u>Product</u></b>          | <b><u>Dimensions</u></b> | <b><u>Test Specification</u></b> | <b><u>Product Description</u></b>                                                                                               |
|--------------------------------|--------------------------|----------------------------------|---------------------------------------------------------------------------------------------------------------------------------|
| GlasBase Plus                  | 36" x 108'               | ASTM D4601                       | Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.    |
| PermaPly 28                    | 36" x 106'               | ASTM D4601                       | Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.    |
| GlasPly IV                     | 36" x 180'               | ASTM D2178 Type IV               | Type IV asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.                           |
| GlasPly Premier                | 36" x 180'               | ASTM D2178 Type VI               | Type VI asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.                           |
| GlasKap                        | 36" x 36                 | ASTM D3909                       | Asphalt impregnated and coated felt surfaced with mineral granules used as the top ply in conventional built-up roof membranes. |
| GlasKap Plus                   | 39-3/8" x 34'            | ASTM D3909                       | SBS Modified Asphaltic cap sheet used as the top ply in conventional built-up roof membranes.                                   |
| Bestile Industrial Roof Cement | N/A                      | ASTM D4586 Type II               | General purpose medium trowel grade, cement cutback asphalt mastic reinforced with non-asbestos fibers and mineral stabilizers. |
| MBR Flashing Cement Activator  | N/A                      | Proprietary                      | Activator component for use with MBR Flashing Cement Base                                                                       |
| MBR Flashing Cement Base       | N/A                      | Proprietary                      | A two-component elastomeric, cold application adhesive, consisting of a modified proprietary compound with an asphalt base.     |



**APPROVED INSULATIONS:****TABLE 2**

| <b><u>Product Name</u></b>                                                                                                                                      | <b><u>Product Description</u></b>                                                                                                 | <b><u>Manufacturer</u><br/><u>(With Current NOA)</u></b> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|
| ENRGY 3, ENRGY 3 25 PSI,<br>ValuTherm, ValuTherm 25 PSI,<br>R-Panel, R-Panel 25 PSI<br>(Flat & Tapered)                                                         | Isocyanurate Insulation.                                                                                                          | Johns Manville                                           |
| ENRGY 3 AGF,<br>ENRGY 3 AGF 25 PSI,<br>ENRGY 3 CGF,<br>ENRGY 3 CGF 25 PSI, ValuTherm<br>CGF,<br>ValuTherm CGF 25 PSI,<br>ValuTherm AGF,<br>ValuTherm AGF 25 PSI | Isocyanurate Insulation with glass reinforced<br>facers                                                                           | Johns Manville                                           |
| ENRGY 3 FR,<br>ENRGY 3 FR 25 PSI                                                                                                                                | Isocyanurate Insulation with inorganic coated<br>glass reinforced facers; bottom face is premium<br>coated for combustible decks. | Johns Manville                                           |
| Fesco Foam, Dura Foam                                                                                                                                           | Isocyanurate Insulation with perlite facer                                                                                        | Johns Manville                                           |
| Retro-Fit Board, DuraBoard                                                                                                                                      | High-density perlite roof insulation.                                                                                             | Johns Manville                                           |
| Fesco Board, Tapered Fesco Board                                                                                                                                | Rigid perlite roof insulation board.                                                                                              | Johns Manville                                           |

**APPROVED FASTENERS:****TABLE 3**

| <b><u>Fastener<br/>Number</u></b> | <b><u>Product<br/>Name</u></b>                                        | <b><u>Product<br/>Description</u></b>          | <b><u>Dimensions</u></b>          | <b><u>Manufacturer</u><br/><u>(With Current NOA)</u></b> |
|-----------------------------------|-----------------------------------------------------------------------|------------------------------------------------|-----------------------------------|----------------------------------------------------------|
| 1.                                | AccuTrac Plate                                                        | Galvalume AZ 50 stress<br>plate.               | 3" square                         | OMG                                                      |
| 2.                                | UltraFast Fastener                                                    | Insulation fastener.                           | #12 x 8" max.<br>#3 Phillips head | Johns Manville                                           |
| 3.                                | UltraFast ASAP                                                        | Pre-assembled Insulation<br>fastener and plate |                                   | Johns Manville                                           |
| 4.                                | UltraFast Metal Plate<br>Recessed or UltraFast<br>Plate Metal (Round) | Galvalume AZ55 steel plate                     | 3" round &<br>3" square           | Johns Manville                                           |
| 5.                                | UltraFast Plastic Plate                                               | High Density Polyolefin<br>round plate         | 3" round                          | Johns Manville                                           |



**EVIDENCE SUBMITTED:**

| <u>Test Agency/Identifier</u>                              | <u>Name</u>     | <u>Report</u> | <u>Date</u> |
|------------------------------------------------------------|-----------------|---------------|-------------|
| FM Approvals                                               | 3014090         | Class 4470    | 09/05/02    |
|                                                            | 3009499         | Class 4470    | 04/04/01    |
|                                                            | 3012974         | Class 4450    | 06/03/02    |
|                                                            | 3037540         | Class 4450    | 10/20/10    |
| Trinity ERD                                                | J7670.06.08     | ASTM D3909    | 06/16/08    |
| UL LLC                                                     | R10167          | UL 790        | 05/12/21    |
| Independent Roof Testing &<br>Consultants of South Florida | IRT 99010       | TAS 114       | 02/11/99    |
|                                                            | IRT 99011       | TAS 114       | 02/11/99    |
| PRI Construction Materials<br>Technologies, LLC            | 507T0079        | ASTM 3909     | 10/1/20     |
|                                                            | JMC-107-02-01.7 | ASTM D 903    | 03/31/16    |
|                                                            |                 | ASTM D 1876   |             |
|                                                            |                 | ASTM D 5147   |             |
|                                                            |                 | TAS 117(B)    |             |
|                                                            |                 | TAS 117(A)    |             |
|                                                            |                 | TAS 114(C)    |             |

**DECK STRESS ANALYSIS CALCULATIONS/REPORTS**

| <u>Engineer/Agency</u>       | <u>Identifier</u>             | <u>Assemblies</u> | <u>Date</u> |
|------------------------------|-------------------------------|-------------------|-------------|
| FM Approval Deck Limitations | N/A                           | B                 | 01/01/13    |
| Zachary R. Priest, P.E.      | Signed/Sealed<br>Calculations | C                 | 04/25/16    |



## APPROVED ASSEMBLIES

|                          |                                                                                                                                                                                                                                                                                                                              |
|--------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Membrane Type:</b>    | BUR                                                                                                                                                                                                                                                                                                                          |
| <b>Deck Type 2I:</b>     | Steel, Insulated                                                                                                                                                                                                                                                                                                             |
| <b>Deck Description:</b> | Minimum 18-22 ga. type B, Grade 33 steel decking over ¼" thick steel supports spaced maximum of 6 ft. o.c. attached 6" o.c. using Traxx/5 fasteners. Deck side laps are attached 24" o.c. using Traxx/1 fasteners.<br><b>This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.</b> |
| <b>System Type B:</b>    | Base layer of insulation mechanically fastened; top layer fully adhered with approved asphalt.                                                                                                                                                                                                                               |

All General and System limitations apply.

| <u>Base Insulation Layer</u>                                                                                                                                                                                                                                                 | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener</u><br><u>Density/ft<sup>2</sup></u> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------|--------------------------------------------------|
| ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm, ValuTherm 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, R-Panel, R-Panel 25 PSI, Minimum 1.5" thick | 3, with 4 or 5                                  | 1:1.78 ft <sup>2</sup>                           |

**Note:** Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

| <u>Top Insulation Layer</u>                    | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener</u><br><u>Density/ft<sup>2</sup></u> |
|------------------------------------------------|-------------------------------------------------|--------------------------------------------------|
| Retro-Fit Board, DuraBoard<br>Minimum ½" thick | N/A                                             | N/A                                              |

**Note:** Top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

|                    |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
|--------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Base Sheet:</b> | (Optional) One ply of PermaPly 28 or GlasBase Plus adhered to the insulated substrate in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; <b>See General Limitation #4 Maximum Design Pressure - 45 psf. applies.</b>                                                                                   |
| <b>Ply Sheet:</b>  | Three plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt if optional cap sheet is utilized or four plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If ply sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; <b>See General Limitation #4 Maximum Design Pressure -45 psf. applies.</b> |
| <b>Cap Sheet:</b>  | (Optional) One ply of GlasKap or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.                                                                                                                                                                                                                                                                                                                                                       |



**Surfacing:** (Required if no cap sheet is used) Install the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

**Maximum Design  
Pressure:**

-60 psf. (See general limitation #7).



**Membrane Type:** BUR

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel

**System Type C:** One or more layers of insulation simultaneously attached.

**Deck:** Minimum 18-22 ga. Grade 80 steel deck shall be secured 6" o.c. to structural supports spaced a maximum of 5 ft. on centers with 5/8" puddle welds. Deck side laps are attached 6" o.c. using Traxx/1 fasteners.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**All General and System limitations apply.**

One or more layers of any of the following insulations:

| <b><u>Base Insulation Layer</u></b>                                                                                                                                                                                                                                            | <b><u>Insulation Fasteners</u><br/><u>(Table 3)</u></b> | <b><u>Fastener</u><br/><u>Density/ft<sup>2</sup></u></b> |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------|----------------------------------------------------------|
| ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm, ValuTherm 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, R-Panel, R-Panel 25 PSI<br>Minimum 1.4" thick | N/A                                                     | N/A                                                      |
| Fesco Foam, Dura Foam<br>Minimum 1.5" thick                                                                                                                                                                                                                                    | N/A                                                     | N/A                                                      |
| Fesco Board, DuraBoard<br>Minimum 3/4" thick                                                                                                                                                                                                                                   | N/A                                                     | N/A                                                      |

**Note:** All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

| <b><u>Top Insulation Layer</u></b>                                                                                                                                                                                                                                             | <b><u>Insulation Fasteners</u><br/><u>(Table 3)</u></b> | <b><u>Fastener</u><br/><u>Density/ft<sup>2</sup></u></b> |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------|----------------------------------------------------------|
| ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm, ValuTherm 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, R-Panel, R-Panel 25 PSI<br>Minimum 1.5" thick | 2 with 4                                                | 1:4 ft <sup>2</sup>                                      |
| Fesco Board<br>Minimum 1" thick                                                                                                                                                                                                                                                | 2 with 4                                                | 1:2 ft <sup>2</sup>                                      |

**Note:** Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.



- Base Sheet:** (Optional) Install one ply of GlasBase Plus or PermaPly 28 directly over the top layer of insulation. Adhere in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; **See General Limitation #4 Maximum Design Pressure -45 psf. applies.**
- Ply Sheet:** Two or more plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If ply sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; **See General Limitation #4 Maximum Design Pressure -45 psf. applies.**
- Cap Sheet:** (Optional) One ply of GlasKap or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Surfacing:** (Required if no cap sheet is used) Install the following:
1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.
- Maximum Design Pressure:** -52.5 psf. (See General Limitation #7)

## STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.  
**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

## END OF THIS ACCEPTANCE