




XERXES® CORP DWT-II T-31
 8 FT. DIA. 10,000 GALLON FRP DOUBLEWALL UST



ANCHOR STRAPPING



TYPICAL SERVICE STATION
 DWT INSTALLATION
 N.T.S.



DOUBLEWALL TANK
 TYPICAL MONITOR SYSTEM
 N.T.S.

PREPARATION FOR INSTALLATION

USE THE LIFT LUG WHEN HOISTING TANK. DO NOT USE CABLES OR CHAINS AROUND THE TANK. USE GUY ROPES TO GUIDE THE TANK WHEN REQUIRED. DO NOT ROLL TANK.

PRE-INSTALLATION TESTING

TIGHTEN ALL FITTINGS, PRESSURE TO 5 PSIG (35 KPA), THEN SOAK ENTIRE TANK FOR A PERIOD LONG ENOUGH TO DETERMINE THAT THERE ARE NO LEAKS AS INDICATED BY SOAP BUBBLES OR A DROP IN PRESSURE (SOAP TEST). IF DAMAGE HAS OCCURRED, DO NOT ATTEMPT REPAIRS, CONTACT XERXES REP FOR INSTRUCTIONS.

BACKFILL AND BEDDING MATERIAL

USE PEA GRAVEL (ROUNDED PARTICLES) WITH A MINIMUM DIAMETER OF 1/8" (3mm) AND MAXIMUM DIAMETER OF 3/4" (19mm).

DEPTH OF EXCAVATION

THE HOLE MUST BE DEEP ENOUGH TO PROVIDE SUFFICIENT BEDDING AND COVER DEPTH. TANKS SUBJECTED TO TRAFFIC LOADS AND HIGH WATER MUST HAVE A MINIMUM OF 30" (76cm) OF BACKFILL OVER TANK AND 6" OF STEEL REINFORCED CONCRETE.

EXCAVATION SIZE

WHERE SHORING IS NOT REQUIRED TO MAINTAIN A VERTICAL WALL FROM TOP TO BOTTOM OF THE EXCAVATION, THE MINIMUM SPACING BETWEEN THE SPHERICAL OR END CAP OF THE TANK AND SIDE OF EXCAVATION MUST BE 18" (45cm). IF MORE THAN ONE TANK IS TO BE INSTALLED IN THE SAME HOLE, THERE MUST BE AT LEAST 18" (45cm) BETWEEN TANKS.

ANCHORING TANKS - DEADMAN

A DEADMAN MUST BE A CONCRETE BEAM WITH A TOTAL LENGTH 12" (30cm) GREATER THAN THE TOTAL LENGTH OF THE TANK. 8" (2.4m) DIAMETER TANKS REQUIRE A DEADMAN WITH A 12" X 12" (30cm X 30cm) CROSS SECTION. LOCATE THE DEADMAN PARALLEL TO THE TANK, NOT MORE THAN 4.5' (1.4m) FROM THE CENTERLINE OF TANK. POSITION EACH HOLD DOWN STRAP SO IT WILL BE CENTERED ON THE FACE OF THE SUB DESIGNATED BY ARROWS. FASTEN THE WIRE CABLE TO THE DEADMAN WITH AT LEAST THREE CLAMPS. CONNECT THE CABLE AND STRAP WITH A TURNBUCKLE, THEN TIGHTEN UNIFORMLY WITH OTHER STRAPS UNTIL SHAG, BUT CAUSE NO DEFLECTION OF THE TANK.

METROPOLITAN DADE COUNTY
 POLLUTION CONTROL DIVISION
 UNDERGROUND STORAGE FACILITIES
 APPROVED *CS*
 DATE 5/31/95

MILLER INDUSTRIAL EQUIPMENT, INC.			
SCALE: AS SHOWN	APPROVED BY: <i>CS</i>	DRAWN BY: <i>CS</i>	
DATE: 5/31/95	REVISED: 05-30-95		
VESADA AUTO REPAIR CORP OF FLORIDA 6900 SW 8 ST MIAMI FL			
UST DETAIL			DRAWING NUMBER: 30F4



DEPT. OF ENVIRONMENTAL RESOURCES MANAGEMENT PLANS PROCESSING				
DEPARTMENTAL APPROVAL		DATE:		
PLAN REVIEW				
SECTIONS	DISAPPROVED	DATE	APPROVED	DATE
PLAN REVIEW				
HAZARDOUS WASTE				
HAZARDOUS FACILITIES				
STORAGE TANK			W	5/21/95
WATER SUPPLY				
WASTEWATER				
UPLAND & FRESHWATER RESOURCES				
WATER CONTROL				
FLOOD CONTROL				
AIR				
(AIR FACILITIES)				
PLANNING & EVALUATION				

*PERMIT NOT VALID UNTIL DEPARTMENTAL APPROVAL IS ISSUED BY PLAN REVIEW SECTION.



INVOICE # Q07711

MONITORING SYSTEM CERTIFICATION

A. General Information

Facility Name: JAK SERVICE CENTER Bldg. No.: _____
 Site Address: 6900 SW 8TH ST. City: MIAMI Zip: 33144
 Facility Contact Person: PETROLEUM SOLUTIONS Contact Phone No.: (305) 883-8687
 Make/Model of Monitoring System: INCON-TS 550 Date of Testing/Servicing: 7 / 8 / 16

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced;

Tank ID- <u>REGULAR</u> <input checked="" type="checkbox"/> In-Tank Gauging Probe. Model: <u>MAG</u> <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>TSP-EIS</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>TSP-ULS</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>LD-2200</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other _____	Tank ID - <u>PREMIUM</u> <input checked="" type="checkbox"/> In-Tank -Gauging Probe. Model: <u>MAG</u> <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>TSP-EIS</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>TSP-ULS</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>FX-1V</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other _____
Tank ID- <u>DIESEL</u> <input checked="" type="checkbox"/> In-Tank Gauging Probe. Model: <u>MAG</u> <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>TSP-EIS</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>TSP-ULS</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>FX-1DV</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other _____	Tank ID: _____ <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s).. Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill I High-Level Sensor. Model: _____ <input type="checkbox"/> Other _____
Dispenser ID: <u>ALL</u> <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID- _____ <input type="checkbox"/> -Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID- _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID- _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID- _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with -the manufacturers' guidelines. For any equipment capable of generating such reports, I have also attached a copy of the report; check all that apply: ☐ system set up ☒ alarm history

Technician Name (print): H. DENT Signature: H Dent
 Certification No.: A22857 License. No.: RQ66547
 Testing Company Name: DISCOVERY TANK TESTING, INC. Phone No: (561) 840-1666
 Site Address: P.O. BOX 14207, NORTH PALM BEACH, FL 33408 Date of Testing/Servicing: 7 / 8 / 16

Digitally signed by: H Dent
 DN: CN = H Dent C = US O = Discovery
 Tank Testing, Inc. OU = Tank Tester
 Date: 2016.03.11 11:06:42 -0400

D. Results of Testing/Serviceing

Software Version Installed: N/A

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> <input checked="" type="checkbox"/> N/A	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g. modem) operational?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails. to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? (<i>Check all that apply</i>) <input type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks <u>and</u> sensor failure/disconnection? <input type="checkbox"/> Yes; <input type="checkbox"/> No.
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For tank systems that utilize the monitoring system as the primary tank overfill warning device (i.e. no mechanical overfill prevention valve is installed), is the overfill warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? <u>90</u> %
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? (<i>Check all that apply</i>) <input type="checkbox"/> Product; <input type="checkbox"/> Water
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

☐ Check this box if tank gauging is used only for inventory control.

☐ Check this box if no tank gauging or SIR equipment is installed.

E. In-Tank Gauging / SIR Equipment:

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?

F. Line Leak Detectors (LLD):

☐ Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (<i>Check all that apply</i>) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h., <input type="checkbox"/> 0.1 g.p.h., <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?

Comments: PREMIUM ANNULAR SENSOR IS IN ALARM - NO WATER OR FUEL IN ANNULAR - BUT SENSOR IS STUCK
IN ANNULAR SPACE - CAN'T GET IT OUT.



Line Leak Detector Test Data Sheet

Station Name: JAK SERVICE CENTER Date 7/8/16

Address 6900 SW 8TH ST.

Test Information

	1	2	3	4	5
Product	REGULAR	PREMIUM	DIESEL		
Manufacturer	VMI	RED JACKET	RED JACKET		
Model	LD-2200	FX-1V	FX-1DV		
Full Operating Pressure (psi)	29 PSI	28 PSI	31 PSI		
Trip Time (see)	3	3	2		
F/E Holding Pressure (psi)	16 PSI	20 PSI	22 PSI		
Test Leak Rate	3.0 gph	3.0 gph	3.0 gph	3.0 gph	3.0 gph
PASS or FAIL	PASS	PASS	PASS		

COMMENTS: ALL LEAK DETECTOR TESTS PASSED.

This letter certifies that the annual leak detector tests were performed at the above referenced facility according to the equipment manufacturers procedures and limitations and the results as listed are to my knowledge true and correct. The mechanical leak test detector test pass/fail is determined using a low flow threshold trip rate of 3.0 gph.

Inspected By: Contractor **DISCOVERY TANK TESTING, INC.** PO Box 14207 North Palm Beach, FL 33408 561-840-1666

Technician H DENT Lic# RQ66547

Signature H Dent

Digitally signed by: H Dent
DN: CN = H Dent C = US O = Discovery Tank Testing, Inc.
OU = Tank Tester
Date: 2016.08.11 11:07:54 -0400

TANK CLOSURE REPORT

for

ADRIAN SERVICE STATION
UT 0166

6900 S.W. 8 STREET
MIAMI, FLORIDA


Submitted to the

DEPARTMENT OF ENVIRONMENTAL RESOURCES MANAGEMENT
(DERM)

by


SERVICE STATION AID, ENVIRONMENTAL
(SSAE)

Written by




Alejandro Montalvo
Project Manager

Reviewed by



Mario Zamora
QA/QC Officer



Rolando R.H. Santos, P.E., D.E.E
Director, Environmental Department

AUGUST 7, 1991

2101910

The information and opinions rendered in this report are exclusively for the use by ADRIAN SERVICE STATION. SSA Environmental (SSAE) will not distribute this report without your consent as may be required by law or court order. The information and opinions expressed in this report are in response to our limited assignment. Therefore, should be evaluated and implemented only in light of that assignment. We accept responsibility for competent performance of our duties in executing the assignment and preparing this report in accordance with the normal standards of our profession. However, SSAE disclaims any responsibility for consequential damages.

TABLE OF CONTENTS

F-DER FORMS

Closure Assessment Form

FIGURES

(1) Site Sketch

APPENDIX

Appendix A

- DERM'S Approval letter
- Scope of work

Appendix B

- PID readings, from the walls of excavated pit and the stock piled excavated soil

Appendix C

- Ground water analytical results

Appendix D

- Chain of custody.

August 6, 1991

M. Amando Villanueva
Department of Environmental
Resource Management (DERM)
Storage Tank Section
111 N.W. 1 Street
Suite 1310
Miami, Florida 33128

RE: Tank closure report for the Adrian Service Station facility located at, near, or in the vicinity of 6900 S.W. 8 Street, Miami, Dade County, Florida.

Dear Mr. Villanueva:

SSA Environmental hereby submits this document in accordance with Rule 17-761 requiring a closure assessment at the time of removal of three (3) 550 gallons and two (2) 2,000 gallons Steel Underground Storage Tanks (UST).

Plans for UST removal were submitted by SSA Environmental (SSAE) to the Department of Environmental Resources Management (DERM) on May 21, 1991. The said plans were approved by DERM on May 31, 1991. Approval for re-lining of one (1) existing 2,000 gallons tank was also granted by DERM's Storage Tank Section. Refer to APPENDIX A for copies of the Storage Tank Excavation Permits. A copy of the Scope of Work proposed by SSAE for the legal removal and disposal of the UST's is also included in APPENDIX A.

On July 17, 1991 the UST's and surrounding soil were excavated. The extent of the excavation was determined by screening the excavation pit walls with a Photoionization Detector (PID), until organic vapor readings of less than 500 ppm for Gasoline and 50 ppm for Diesel fuel were detected or structural constraints impeded further excavation. The PID analysis is listed in APPENDIX C. During the excavation, the UST's were disposed of by N & M Trucking and transported to Sun-Metal at 13200 Cairo Ln., Opa Locka, Florida. Tank removal was done in accordance with FDER 17-761, 17-770, and API 1604.


On July 29, 1991, the ground water samples were analyzed by a state certified laboratory (Engineers-Scientists Laboratory) via EPA methods 602 and 610. The results indicated that the ground water beneath the site is contaminated by members of the Gasoline groups in the vicinity of the underground storage tank. Refer to Appendix D for a copy of the analytical results.

We look forward to hearing from you regarding your response and if further evaluation is warranted on the site.

Should you have any questions or comments, please contact Alejandro Montalvo at (305)573-7420. Thank you.

Sincerely,


SSA ENVIRONMENTAL



Rolando R.H. Santos, F.E., D.E.E.
Director

RRHS/am
2101910

Enclosures



Florida Department of Environmental Regulation

Division Towers Office Bldg • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

DER Form #	17 751500(5)
Form #	Closure Assessment Form
Effective Date	December 10, 1990
DER Approval No.	17 751500(5)

Closure Assessment Form

Owners of storage tank systems that are replacing, removing or closing in place storage tanks shall use this form to demonstrate that a storage system closure assessment was performed in accordance with Rule 17 751 or 17 752, Florida Administrative Code. Eligible Early Detection Incentive (EDI) and Reimbursement Program sites do not have to perform a closure assessment.

Please Print or Type
Complete All Applicable Blanks

- Date AUGUST 6, 1991
- DER Facility ID Number: 138503663
- County: DADE COUNTY
- Facility Name: ADRIAN SERVICE STATION
- Facility Owner: JORGE AND JULIA UGAN
- Facility Address: 6900 S.W. 8 STREET
- Mailing Address: 11050 S.W. 143 RD. PL., MIAMI, FL. 33186
- Telephone Number: (305) 261-8116
- Facility Operator: JORGE UGAN
- Are the Storage Tank(s) (Circle one or both) A. Aboveground or (B) Underground
Type of Product(s) Stored: GASOLINE AND DIESEL FUEL, KEROSENE AND WASTE OIL.
- Were the Tank(s) (Circle one) A. Replaced (B) Removed C. Closed in Place D. Upgraded (aboveground tanks only)
- Number of Tanks Closed: FIVE (5) TANKS
THREE (3) 550 GAL. UST'S.
TWO (2) 2,000 GAL. UST'S.
- Age of Tanks: UNKNOWN

Facility Assessment Information

Yes No Not Applicable

- | | | |
|-------------------------------------|-------------------------------------|--------------------------|
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
- Is the facility participating in the Florida Petroleum Liability Insurance and Restoration Program (FPLIRP)?
 - Was a Discharge Reporting Form submitted to the Department?
If yes, When: -- Where: --
 - Is the depth to ground water less than 20 feet?
 - Are monitoring wells present around the storage system?
If yes, specify type: ☒ Water monitoring ☐ Vapor monitoring
 - Is there free product present in the monitoring wells or within the excavation?
 - Were the petroleum hydrocarbon vapor levels in the soils greater than 500 parts per million for gasoline?
Specify sample type: ☐ Vapor Monitoring wells ☒ Soil sample(s)
 - Were the petroleum hydrocarbon vapor levels in the soils greater than 50 parts per million for diesel/kerosene?
Specify sample type: ☐ Vapor Monitoring wells ☒ Soil sample(s)
 - Were the analytical laboratory results of the ground water sample(s) greater than the allowable state target levels?
(See target levels on reverse side of this form and supply laboratory data sheets)
 - If a used oil storage system, did a visual inspection detect any discolored soil indicating a release?
 - Are any potable wells located within 1/4 of a mile radius of the facility?
 - Is there a surface water body within 1/4 mile radius of the site? If yes, indicate distance: --

DER Form #	17-761.900(5)
Form Title	Closure Assessment Form
Effective Date	December 10, 1990
DER Application No.	(Filing by DER)

12. A detailed drawing or sketch of the facility that includes the storage system location, monitoring wells, buildings, storm drains, sample locations, and dispenser locations must accompany this form.
13. If a facility has a pollutant storage tank system that has both gasoline and kerosene/diesel stored on site, both EPA Method 602 and EPA Method 610 must be performed on the ground water samples obtained.
14. Amount of soils removed and receipt of proper disposal.
15. If yes is answered to any one of questions 5-9, a Discharge Reporting Form 17-761.900(1) indicating a suspected release shall be submitted to the Department within one working day.
16. A copy of this form and any attachments must be submitted to the Department's district office in your area and to the locally administered program office under contract with the Department within 60 days of completion of tank removal or filling a tank with an inert material.

JORGE UGAN

Signature of Owner

Date

ROLANDO R. H. SANTOS

Signature of Person Performing Assessment

Date

DIRECTOR, SSA ENVIRONMENTAL (SSAE)

Title of Person Performing Assessment

State Ground Water Target Levels That Affect A Pollutant Storage Tank System Closure Assessment

State ground water target levels are as follows:


1. For gasoline (EPA Method 602):

- a. Benzene 1 ug/l
- b. Total VOA 50 ug/l
 - Benzene
 - Toluene
 - Total Xylenes
 - Ethylbenzene
- c. Methyl Tertiary-Butyl Ether (MTBE) 50 ug/l

2. For kerosene/diesel (EPA Method 610):

- a. Polynuclear Aromatic Hydrocarbons (PAHS)
(Best achievable detection limit, 10 ug/l maximum)

FIGURE



~~SECRET~~

11

APPENDIX A



SCALE IN FEET
0 10 20

LEGEND

⊙ MONITOR WELL

▢ RUNOFF DRAIN

■ TANK FILLS

□ DISPENSERS

—— PRODUCT LINE (2" DOUBLE WALL FIBERGLASS)


--- VENT LINE (2" SINGLE WALL FIBERGLASS)

----- STAGE II LINE (2" DOUBLE WALL FIBERGLASS)

METROPOLITAN DADE COUNTY
POLLUTION CONTROL DIVISION
UNDERGROUND STORAGE FACILITIES

APPROVED *[Signature]*

DATE 5/31/91



METROPOLITAN DADE COUNTY
MECHANICAL DEPT. BLDG. & ZONING

APPROVED *[Signature]*

DATE 6-14-91

RECEIVED
MAY 21 1991

METRO - DADE COUNTY
POLLUTION CONTROL



SERVICE STATION AID INC

SCALE AS SHOWN

DATE 4/15/91

APPROVED BY:

[Signature]
Alan R. [Name]

DRAWN BY *[Signature]*

REVISED 5-21-91

ADRIAN SERVICE STATION
6900 SW 8 ST
MIAMI, FL

(UGAN)

PROPOSED SITE SKETCH


DRAWING NUMBER

METROPOLITAN DADE COUNTY
WATER CONTROL DIVISION
WASTEWATER STORAGE FACILITIES

WED

GC

2/11/86



3-200 GAL



WASTE OIL TANKS

EXISTING BUILDING

DERM INSPECTION REQUIRED

FAILURE TO COMPLY WILL RESULT IN
AN ILLEGAL INSTALLATION. TO
SCHEDULE INSPECTION CALL 375-3323
AT LEAST 48 HOURS PRIOR TO INSTALLATION

CONSTRUCT (4) 2" PVC MONITORING WELLS

JOB NAME ADRIAN SERVICE STATION INC.

JOB LOCATION 6900 S.W. 8 ST.

MIAMI, FL 33144

261-8116

DEPT. OF ENVIRONMENTAL
RESOURCES MANAGEMENT
METROPOLITAN DADE COUNTY
ENVIRONMENTAL
FACILITIES ONLY
APPROVED

BY PC 60488 p/GC

DATE FEB 14 1986

Handwritten:
Paid in full.
2/19/86
P. Hensley

1/LAYOUTS ARE APPROXIMATE.
DRILLER TO TAKE FULL
RESPONSIBILITY FOR UTILITY
AVOIDANCE AND EXACT
UNDER GROUND TANK PERIMETER
& LINE LOCATION

2/NO WORK TO PROCEED WITH
OUT DERM APPROVAL

3/PREPARED UNDER SUPERVISION
OF PHILLIP WATSON, P.E.

J.M. HENSLEY DRILLING, INC.

DATE 1-22-86


DWN. BY: J.M.H.

STATE LICENSE NO.

2489

DRILLER LICENSE NO.

40663



EXISTING PORTION OF BUILDING SHALL
 COMPLY WITH THE 1983 EDITION OF THE
 CO. OF THE 1983 EDITION OF THE 1983
 NFP-101 L.P.G. CODE

STO. TANKS & PIPING SYSTEM TO BE
 INSTALLED IN ACCORDANCE
 WITH N. F. P. A. 30.

METROPOLITAN DADE COUNTY
ENVIRONMENTAL RESOURCES MANAGEMENT
STORAGE TANK SECTION
111 N W 1 ST SUITE 1310
MIAMI FL 33129
375-5531

File # 2003

Date *5/31/91*

Reviewed by *Rev*

PROJECT NAME *Address Service Station*
ADDRESS *6900 SW 8th Street*
CONTRACTOR *SSA*

Phone *573-7126*

UT * *0166*

PC * *13545*

Approval is hereby granted to the underground storage facility(ies) as described below as meeting the Pollution Control requirements. However, this approval does not relieve the owner and/or contractor from their responsibilities of seeking approval from Building and Zoning, Fire Dept. and/or any other department that may be necessary prior to construction.

T A N K S	QUANTITY	CAPACITY	MAT'L OF CONSTRUCTION		CATHODIC PROTECTION
M O N I T O R	QUANTITY	STATUS	DIAMETER		C.A.L.D.S
PIPING	FIBERGLASS	STEEL	COPPER	OTHER	PROTECTION SYSTEM
PRODUCT	✓				
VENT	✓				
SEC. CONTA- INMENT	TANKS: <i>Re-lining.</i>				
	PIPING: <i>Double wall</i>				
PUMP SYSTEM	SUCTION:				
	SUBMERSIBLE: LINE LEAK DETECTOR:				
OTHER	<i>1) Approval for removal of three (3) 500 gallon and two (2) 2,000 gallon underground storage tanks to be disposed of by WSA Tanking. Tank (1) contents to be removed and disposed of by P&S.</i> <i>2) Approval for re-lining of one (1) existing 2000 gallon tank.</i> <i>3) Approval for stage II vapor recovery piping.</i> <i>4) Approval for overfill/overflow protection system.</i> <i>5) Approval for proper disposal of tanks and tank (1) contents must be submitted to this Department within thirty (30) days of tank removal.</i> <i>Approval of owner's site inspection shall be obtained prior to installation of stage II vapor recovery and overfill equipment.</i>				

PROVIDED:

1. Construction is completed according to approved plans.
2. Construction on this project must be commenced within one year of this approval, otherwise plans and specifications must be resubmitted for approval by this department.
3. The water supply for this building shall be in accordance with requirements of Dade County Health Department.
4. All water lines shall be located a minimum horizontal distance of 10 ft. from all septic tanks, drainfields, sewer lines, etc.
5. There may be county, municipal or other local regulations or restrictions to be complied with by the owner prior to construction of the facilities represented by these plans. We recommend that appropriate local agencies be consulted before starting construction.
The plumbing layout, sizes and slopes shall be approved by the Plumbing Department before installation.



SERVICE STATION AIR, INC.
Petroleum Equipment & Environmental Services

81 N.E. 21ST STREET
MIAMI, FLORIDA 33137
PHONE (305) 573-7420

SCOPE OF WORK

1. Remove and legally dispose of three (3) 550 gallon underground storage tank and two (2) 2000 gallon underground storage tanks and associated piping.
2. Tank disposal will be done by N&M Trucking to Sun metal at 3200 Cairo Ln, Opa Locka, Florida. Disposal documents will be provided to the contractor for further report to DERM.
3. Any sludge or liquid pollutants remaining in the tanks shall be legally disposed of by PMI, a duly licensed company.
4. Tank removal will be done in accordance with FDER 17-761, 17-770, and API 1604.
5. Contaminated soil from the site can be temporarily stored at the site following pertinent rules and regulations. Soil will be disposed of by a properly licensed contractor.
6. Re-line one (1) 2000 gallon underground storage tank. Work to be done by Williams Tank Service.
7. Install overfill/overspill protection on 2000 gallon tank.
8. Install 2" double wall fiberglass product and vent lines.
9. Install underground lines for Stage II vapor recovery system, to be stubbed up underneath dispenser for future use.

STO. TANKS & PIPING SYSTEM TO BE
INSTALLED IN ACCORDANCE
WITH N.E.P.A. 30

EXISTING FORTH SCOR BUILDING SHALL
BE RE-USE FOR FUTURE USE
DATE: 1-1-1985

Serving South Florida since 1959.

APPENDIX B

81 NE 21st Street
Miami, Florida 33137
(305) 573-7420

SSA Environmental

SOIL SAMPLING DATA

NUMBER 3

DATE 7/18	JOB NUMBER 201910	LOCATION 6900 S.W. 8 Street	JOB NAME Arian Env Station
PROJECT MANAGER L. 7/12	FIELD PERSONNEL Aler Montalvo	TITLE Env Technician	
BOARNO NUMBER N/A	DRIER N/A		

Gas #1 7/17		
FROM		P.I.D. READINGS
Northwest	NW	56.6 ppm ✓
Northeast	NE	57.8 ppm ✓
Southeast	SE	292 ppm ✓
Southwest	SW	4150 ppm x

Diesel 7/17		
FROM		P.I.D. READINGS
North	N	3.5 ppm ✓
South	S	0.5 ppm ✓

South (S) → Gas #2 7/17		
FROM		P.I.D. READINGS
Southeast	Composite (S.N)	2100 ppm x

South (S) → Gas #3 7/18		
FROM		P.I.D. READINGS
Corner	S E	3300 ppm x
Middle	S	21.4 ppm ✓
Corner	S W	282 ppm ✓

South (S) → Gas #4 7/18		
FROM		P.I.D. READINGS
Corner	S.E.	4200 ppm x
Middle	S.	30.8 ppm ✓
Corner	S W	12.6 ppm ✓

South (S) → Gas #5 7/18		
FROM		P.I.D. READINGS
Southeast	S.E. Composite	2200 ppm x
Corner		

South (S) → Gas #6 7/18		
FROM		P.I.D. READINGS
Southeast	S.E. Composite	815 ppm x
Corner		

South (S) → Gas #7 7/18		
FROM		P.I.D. READINGS
Southeast	S.E. Composite	156 ppm ✓
Corner		

* South wall of excavation pit was contaminated. Excavation was continued until PID readings under 500 ppm were obtained.

S - South
S.E. - Southeast
S.W. - Southwest

APPENDIX C

engineers-scientists
LABORATORY

11960 S W 144 STREET, MIAMI, FL 33156
(305) 233 1411 ■ FAX (305) 235-6214

August 2, 1991

Mr. Mario Zamora
SSA Environmental
81 N.E. 21 Street
Miami, FL 33139

Re: SSA Project No: 2101910
ESL Project No: 9129TA
Invoice No: 1803
P.O. No: 3095-2101910
Terms: Net 20 Days

Dear Mr. Zamora:

This invoice is submitted for laboratory services as detailed below:

Parameter	Quantity	Unit Cost	Extended Cost
EPA 602	1	\$79.00	\$79.00
EPA 610	1	\$134.00	\$134.00

TOTAL AMOUNT DUE THIS INVOICE

\$213.00

=====

RESULTS OF LABORATORY ANALYSES

Client: SSA Environmental

Client Project No: 2101910 ESL Project No: 9129TA
Client Sample No: Exc Pit 1 ESL Sample No: 7434

Sample Date: Unknown
Sample Location: Adrian Service Station Date Received: 7/17/91
Time Received:
Collected By: Wilfred Chin Analysis Date(s): 7/29/91
Sample Matrix: Water Report Date: 7/30/91

PARAMETER	RESULTS	UNITS	DETECTION LIMIT
EPA METHOD 602			
Methyl-t-butyl ether (MTBE)	1900	ug/l	400 (a)
Benzene	550	ug/l	100 (a)
Toluene	1600	ug/l	100 (a)
Ethylbenzene	2500	ug/l	100 (a)
p-Xylene	2400	ug/l	100 (a)
Chlcrobenzene/m-Xylene *	6100	ug/l	100 (a)
o-Xylene	1600	ug/l	100 (a)
1,4-Dichlorobenzene	BDL	ug/l	100 (a)
1,3-Dichlorobenzene	660	ug/l	100 (a)
1,2-Dichlorobenzene	180	ug/l	100 (a)

Comments:

BDL: Below Detection Limits

* Compounds co-elute at the same retention time

(a) Dilution of 1:100

Adriana Perez

Adriana Perez
Laboratory Supervisor

engineers-scientists LABORATORY

11960 S W 144 STREET, MIAMI, FL 33186
(305) 233-1411 • FAX (305) 235-6214

RESULTS OF LABORATORY ANALYSES

Client: SSA Environmental

Client Project No: 2101910 ESL Project No: 9129TA
Client Sample No: Exc Pit 2 ESL Sample No: 7435


Sample Date: Unknown
Sample Location: Adrian Service Station Date Received: 7-17-91
Time Received:
Collected By: Wilfred Chin Analysis Date(s): 7-29-91
Sample Matrix: Water Report Date: 7-30-91

PARAMETER	RESULTS	UNITS	DETECTION LIMIT
EPA METHOD 610			
Naphthalene	BDL	ug/l	2
2-methylnaphthlene	BDL	ug/l	2
1-methylnaphthlene	BDL	ug/l	2
Acenaphthalene	BDL	ug/l	2
Acenaphthene	BDL	ug/l	2
Fluorene	BDL	ug/l	2
Phenanthrene	BDL	ug/l	2
Anthracene	BDL	ug/l	2
Fluoranthene	BDL	ug/l	2
Pyrene	BDL	ug/l	2
Benzo(a)anthracene	BDL	ug/l	2
Chrysene	BDL	ug/l	2
Benzo(b)fluoranthene/			
Benzo(k)fluoranthene *	BDL	ug/l	4
Benzo(a)pyrene	BDL	ug/l	2
Dibenzo(a,h)anthracene/			
Indeno(1,2,3-cd)pyrene *	BDL	ug/l	4
Benzo(g,h,i)perylene	BDL	ug/l	2

Comments:

BDL: Below Detection Limits

* Compounds co-elute at the same retention time


Adriana Perez
Laboratory Supervisor

APPENDIX D

81 N.E. 21 Street
Miami, Florida 33137
In Dade: 573-7420
In Broward: 524-5232

PO# 3095 - 2102910

№ 2119

[illegible]

TABLE 1

Monitor Well No.	Date Sampled	Benzene ug/l	Toluene ug/l	Ethyl Benzene ug/l	Total Xylenes ug/l	Total VOA ug/l	MTBE ug/l	FDB ug/l	Lead mg/l
MW-1	12/17/92	BDL	530 0	1,720 0	9,470 0	11,720 0	BDL	BDL	0 022
MW-2	12/17/92	7 0	13 0	215 0	661 0	896 0	BDL	BDL	0 008
MW-3	12/17/92	728 0	15 0	91 0	BDL	834 0	895 0	BDL	0 007
MW-4	12/17/92	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL
MW-5	12/17/92	1 7	BDL	1 1	BDL	2 8	BDL	BDL	BDL
MW-6	12/17/92	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL
MW-7	12/17/92	BDL	3,100 0	1,900 0	10,800 0	15,800 0	BDL	BDL	0 017
MW-8	12/17/92	129 0	6 0	13 0	37 0	185 0	275 0	BDL	BDL
DW-1	12/17/92	0 9	2 8	6 1	78 1	87 9	21 5	BDL	BDL

ug/l = Micrograms/Liter

mg/l = Milligrams/Liter


BDL = Below Detection Limit

TABLE 2

Soil Boring No	Date of Sample	Sample Number	Depth of Sample (ft)	OVA Readings (ppm)
SB-5	12/9/92	1	0' - 2'	0
		2	2' - 4'	0
		3	4' - 6'	0
SB-6	12/9/92	1	0' - 2'	0
		2	2' - 4'	0
		3	4' - 6'	0
SB-7	12/9/92	1	0' - 2'	0
		2	2' - 4'	0
		3	4' - 6'	0
SB-8	12/9/92	1	0' - 2'	0
		2	2' - 4'	0
		3	4' - 6'	0
SB-9	12/9/92	1	0' - 2'	0
		2	2' - 4'	0
		3	4' - 6'	0
SB-10	12/9/92	1	0' - 2'	
		2	2' - 4'	0
		3	4' - 6'	0
SB-11	12/9/92	1	0' - 2'	0
		2	2' - 4'	0
		3	4' - 6'	1

TABLE 3

MONITORING WELL NO.	DATE OF READING	ELEVATION OF MONITORING WELL	DEPTH TO WATER	DEPTH OF GROUNDWATER
MW-1	12/17/92	10 28	6 15	4 13
MW-2	12/17/92	10 52	6 28	4 24
MW-3	12/17/92	10 13	6 36	3 77
MW-4	12/17/92	8 88	6 02	2 86
MW-5	12/17/92	9 90	6 66	3 24
MW-6	12/17/92	10 75	5 86	4 89
MW-7	12/17/92	9 21	6 08	3 13
MW-8	12/17/92	9 50		




SEE MAP NO. 57

PETRO HYDRO, INC.
 7355 N.W. 41ST. STREET
 MIAMI, FLORIDA 33316

SITE VICINITY MAP
 ADRIAN SERVICE STATION
 6900 S.W. 8TH. STREET
 MIAMI, DADE COUNTY FLORIDA

FIGURE
 1



PETRO HYDRO, INC.

7355 N.W. 41ST. STREET
MIAMI, FLORIDA 33136

ADRIAN SERVICE STATION
6900 S.W. 8TH. STREET
MIAMI, DADE COUNTY FLORIDA

ROAD TRACKS

SCALE: 1" = 30'-0"

GUARDRAIL

STORM SEWER

MW-1

MW-7

JUMP

2' DIA.
STORM SEWER

MW-2

DW-1

MW-6


S.W. 8TH. STREET

ON
ET
RIDA

SITE MAP-LOCATION OF MONITOR WELLS

FIGURE

2



PETRO HYDRO, INC.

7355 N.W. 41ST. STREET
MIAMI, FLORIDA 33136

ADRIAN SERVICE STATION
6900 S.W. 8TH. STREET
MIAMI, DADE COUNTY FLORIDA

ROAD TRACKS

SCALE: 1" = 30'-0"

GUARDRAIL

STORM SEWER

MW-1 4.13'

MW-7 3.13'

2' DIA STORM SEWER

MW-2 4.24'

DW-1

MW-6 4.89'

4.13'

S.W. 8TH. STREET

← APPARENT DIRECTION OF
GROUNDWATER FLOW.

HYDRAULIC GRADIENT=0.0104(FT/FT)

ON
ET
ORIDA


GROUNDWATER ELEVATIONS

FIGURE

3

C:\PSL\ADRIAN\LDGN
11042

01/25/93



PETRO HYDRO, INC.
7355 N.W. 41ST. STREET
MIAMI, FLORIDA 33366


ADRIAN SERVICE STATION
6900 S.W. 8TH. STREET
MIAMI, DADE COUNTY FLORIDA

ROAD TRACKS

SCALE: 1" = 30'-0"

GUARDRAIL

S.W. 8TH. STREET




BENZENE DISTRIBUTION MAP

FIGURE

4

C:\PS\ADRIANI.DGN
11042

01/25/93




PETRO HYDRO, INC.

7355 N.W. 41ST. STREET
MIAMI, FLORIDA 33306

ADRIAN SERVICE STATION
6900 S.W. 8TH. STREET
MIAMI, DADE COUNTY FL

RAILROAD TRACKS

SCALE: 1" = 30'-0"




ION
EET
ORIDA

TOTAL VOA PLUME

FIGURE

5



PETRO HYDRO, INC.

7355 N.W. 41ST. STREET
MIAMI, FLORIDA 33346

ADRIAN SERVICE STATION
6900 S.W. 8TH. STREET
MIAMI, DADE COUNTY FLORIDA

ROAD TRACKS

SCALE: 1" = 30'-0"

GUARDRAIL

STORM SEWER

▲ SB-7

S.W. 8TH. STREET

MP

2' DIA.
STORM SEWER

SB-6 ▲

▲ = SOIL BORING


MAP OF SOIL BORINGS

FIGURE

6

C:\PSL\ADRIAN\IDGN
11042

01/25/93



PETRO HYDRO, INC.

7355 N.W. 41ST. STREET
MIAMI, FLORIDA 3336

ADRIAN SERVICE STATION
6900 S.W. 8TH. STREET
MIAMI, DADE COUNTY FLORIDA

ROAD TRACKS

SCALE: 1" = 30'-0"

GUARDRAIL

STORM SEWER

MW-1

MW-7

LMP

2' DIA.
STORM SEWER

MW-2

DW-1

MW-6

S.W. 8TH. STREET


UNDERGROUND SEWER LINES

ON
ET
ORIDA

LOCATION OF UNDERGROUND UTILITIES

FIGURE

7



PETRO HYDRO, INC.

7355 N.W. 41ST. STREET
MIAMI, FLORIDA 33316

ADRIAN SERVICE STATION
6900 S.W. 8TH. STREET
MIAMI, DADE COUNTY FLORIDA

ROAD TRACKS

SCALE: 1" = 30'-0"

4000 GALLON
UST
(REMOVED)

GUARDRAIL

EXCAVATION No. 2

STORM SEWER

4000 GALLON
USTs-2ea.
REMOVED

MW-1

MW-7

GAS PUMP

PIPING

2' DIA.
STORM SEWER

MW-2

DW-1

EXCAVATION No. 1


MW-8

S.W. 8TH. STREET

SITE MAP-LOCATION OF UST & PIPING


FIGURE

8



RAILROAD TRACKS

PRIVATE PROPERTY



S.W. 8TH STREET

S.W. 69TH AVENUE

MONITORING WELL

All readings are in parts per billion.

PETRO HYDRO ENVIRONMENTAL ENGINEERING PROJECT #2518.101

ADRIAN SERVICE STATION

6900 S.W. 8TH STREET


MIAMI, FLORIDA

GROUNDWATER IMPACT MAIL

BENZENE

FIGURE 2

HAZARDOUS WASTES





S.W. 69TH AVENUE

<p>0' 20'</p>	<p>ADRIAN SERVICE STATION 6900 S.W. 8TH STREET MIAMI, FLORIDA</p>		<p>GROUNDWATER IMPACT MAP TOTAL BTX</p>	<p>PROJECT #2518.101</p>
	<p>ADRIAN SERVICE STATION 6900 S.W. 8TH STREET MIAMI, FLORIDA</p>		<p>GROUNDWATER IMPACT MAP TOTAL BTX</p>	<p>FIGURE 3</p>

MONITORING WELL

All readings are in parts per billion.





APPENDIX C

Table 1
SOIL QUALITY ANALYSIS

<u>Location</u>	<u>Depth</u>	<u>Unfiltered OVA Readings</u>
MW 12	2'	<10
	4'	<10
	5'	<10
MW 13	2'	<10
	4'	<10
	5'	<10
MW 14	2'	<10
	4'	<10
	5'	<10

NOTE: All results are recorded in parts per million.

Table 2
GROUNDWATER QUALITY RESULTS

Date	MW	Benzene	Toluene	Ethyl		Total	Total	Total
				Benzene	Xylenes	VOA	Naph.	Pah
11/02/94	12	BDL	1.10	1.92	8.32	11.37	*BDL	*BDL
11/02/94	13	3.27	5.99	2.35	10.91	22.52	--	--
11/02/94	14	3.57	8.34	3.06	12.51	27.48	--	--
11/02/94	DW1	--	--	--	--	--	BDL	BDL
11/02/94	3	--	--	--	--	--	240	BDL
05/02/94	DW2	BDL	BDL	4.26	11.7	15.96	--	--
11/21/94	1	--	--	--	--	--	265	BDL
11/21/94	2	--	--	--	--	--	816	BDL
11/21/94	4	--	--	--	--	--	BDL	BDL
11/21/94	7	--	--	--	--	--	62	BDL
11/21/94	8	--	--	--	--	--	7	BDL

Notes: All values are expressed in parts per billion.

* = Sample Date 11/21/94

BDL = Below detection limits

Total VOA = Volatile organic aromatics (summation of detected BTEX by EPA Method 602).

Naph. = Total Naphthalenes, EPA 610

PAH = Polynuclear aromatic hydrocarbons, EPA 610

-- = Not analyzed

TABLE 3
SUMMARY OF GROUNDWATER ELEVATION SURVEY

MW NO.	SURVEY DATE	MONITORING WELL ELEVATION	GROUNDWATER DEPTH	GROUNDWATER ELEVATION
MW-1	12/17/92	10.28	6.15	4.13
MW-2	12/17/92	10.52	6.28	4.24
MW-3	12/17/92	10.13	6.36	3.77
MW-4	12/17/92	8.88	6.02	2.86
MW-5	12/17/92	9.90	6.66	3.24
MW-6	12/17/92	10.75	5.86	4.89
MW-7	12/17/92	9.21	6.08	3.13
MW-8	12/17/92	9.50	N/A	N/A
MW-1	4/05/94	10.28	6.30	3.98
MW-2	4/05/94	10.52	6.22	4.30
MW-3	4/05/94	10.13	6.48	3.65
MW-4	4/05/94	8.88	6.13	2.75
MW-5	4/05/94	8.88	6.75	2.13
MW-6	4/05/94	8.88	5.94	2.94
MW-7	4/05/94	8.88	6.39	2.49
MW-8	4/05/94	9.50	6.36	3.14

Table 4
Groundwater Level Measurements
November 21, 1994

Monitor Well	Depth to Water

1	5.00
2	4.89
3	5.12
4	4.87
5	5.52
6	4.71
7	4.94
8	5.06
9	5.31
10	5.09
11	5.13
12	5.32
13	5.27
14	5.31

NOTE: All groundwater measurements are expressed in feet.