

Top 10 Reasons for Sewer Extension Certification Disapproval

1. Expired FDEP permits cannot be certified if construction was done outside the 5-year permit life.
2. Missing tests notification three days prior to performing the tests (exfiltration, pressure, PS start up).
3. Incomplete submittals (i.e., submittals missing as-builts, DERM form, FDEP Application, test results, etc.)
4. Discrepancies throughout submittal (i.e., as-builts and DERM approved plans are not consistent)
5. Documents, plans, and test results that are not digitally signed and sealed by the Professional Engineer of Record.
6. Incomplete FDEP Application To Construct a Domestic Wastewater Collection/Transmission System form (i.e., deviations not included, not signed by Utilities, etc.)
7. Incomplete DERM Domestic Wastewater Collection/transmission Systems Certification of Completion of Construction form (i.e., Utility pump station information not included).
8. As-builts do not depict the building sewer system as permitted in the DERM/FDEP Approved plans.
9. Incomplete Test Reports (i.e. date of the test is not included, test not consistent with the DERM/FDEP approved plans and as-builts, etc.)
10. Lamping and televising tests are not accepted in lieu of exfiltration tests. Incomplete submittals (i.e. submittals missing Engineering Report, pressure Memo, hydraulic analysis, FDEP Application, etc.)