

QUALITY. VALUE. ECONOMIC GROWTH.

WWW.MIAMIDADE.GOV/WATER



MIAMI-DADE  
COUNTY

Sheet Number: 1.2.2

## Product Specifications

Miami-Dade Water & Sewer Department  
Address: 3071 SW 38th Ave, Miami, FL 33146  
Phone: (305) 665-7477

## Poly Vinylchloride (PVC) Pipe- SDR 26



### Minimum Standards

- ASTM D1784, D3034, F477
- MDWASD Specifications: Sections UC-250, 15060

### Other Requirements

- SDR 26 Heavy Walled Gravity Sewer Pipe
- Color Green for Sanitary Sewer Application

### Applications

- Sewer – for gravity sewer application
- Not to be used in wellfield protection areas
- Not to be used at depths greater than 13 feet
- Gravity sewer laterals

### PRE-APPROVED MANUFACTURER

- 1) Diamond Plastics Corporations
- 2) JM Eagle
- 3) National Pipe & Plastics, Inc.
- 4) Next Polymers
- 5) Westlake Pipe and Fittings
- 6) Sanderson Pipe Corp.

### Issue Date:

4-4-2016

### Revised Date:

1-21-2026

### APPROVED PRODUCTS / MODELS

PIPE SIZE	MANUFACTURER	MODEL	SUBMITTED
<b>GRAVITY SEWER PIPE</b>			
4" - 12"	Westlake Pipe and Fittings	CertaFlo PVC Gravity Sewer Pipe	<input type="checkbox"/>
4" - 30"	Diamond Plastics Corporations	Diamond Gravity Sewer pipe	<input type="checkbox"/>
4" - 30"	JM Eagle	Gravity Sewer	<input type="checkbox"/>
4" - 18"	National Pipe & Plastics, Inc.	EVER-GREEN for sewer and storm drainage	<input type="checkbox"/>
4" - 30"	Next Polymers	Duroloc PVC Sewer Pipe	<input type="checkbox"/>
4" - 15" & 18" - 30"	Westlake Pipe and Fittings	ASTM D3034 Gravity Sewer Pipe	<input type="checkbox"/>
4" - 15"	Sanderson Pipe Corp.	Gravity Sewer Pipe Gasket Bell	<input type="checkbox"/>
<i>Note: Other sizes require MDWASD Approval</i>			<input type="checkbox"/>

### SIZES FURNISHED:

- |                              |                              |                                |
|------------------------------|------------------------------|--------------------------------|
| <input type="checkbox"/> 4"  | <input type="checkbox"/> 12" | <input type="checkbox"/> 30"   |
| <input type="checkbox"/> 6"  | <input type="checkbox"/> 15" | <input type="checkbox"/> Other |
| <input type="checkbox"/> 8"  | <input type="checkbox"/> 18" |                                |
| <input type="checkbox"/> 10" | <input type="checkbox"/> 24" |                                |

**COMMENTS:** \_\_\_\_\_

**Approved by:** David Vazquez, PE  
Utility Pipeline Engineering Division

**Revision History:**

1-21-2026: North American Pipe Corp changed company name to Westlake Pipe and Fittings