

Product Specifications

Miami-Dade Water & Sewer Department
 Address: 3071 SW 38th Ave, Miami, FL 33146
 Phone: (305) 665-7477

Resilient Seated Gate Valve



Minimum Standards

- AWWA C500, C509, C515, C550, C11/A21.11
- ASTM A123, A153, D429
- ANSI B16.1 Class 125
- MDWASD Specifications: Sections 15100, 15120

Other Requirements

- NSF61/ANSI for potable water applications
- Non Rising Stem (NRS)
- Design working water pressure : 250psi (3" - 30")

Applications

- Water
- In bevel position, blowoff assembly required, see STD 4.70

PRE-APPROVED MANUFACTURER

- | | |
|--------------------------|-------------------|
| 1) American Flow Control | 5) US Pipe |
| 2) Clow | 6) Matco-Norca |
| 3) J & S Valve | 7) VSI Waterworks |
| 4) Kennedy | |
| 5) Mueller | |

Issue Date:

4-4-2016

Revised Date:

8-26-2025

APPROVED PRODUCTS / MODELS

SIZE	MANUFACTURER	MODEL	SUBMITTED
4" - 48"	American Flow Control	Series 2500, DI (Resilient Wedge)	<input type="checkbox"/>
3" - 12"	Clow	2639 & 2640	<input type="checkbox"/>
24"	Clow	2638	<input type="checkbox"/>
14" - 30 1/4" - 12"	J & S Valve	Series 6000/6000.5, (Resilient Seated)	<input type="checkbox"/>
4" - 12"	Kennedy	Model KS_FW, (Resilient Wedge)	<input type="checkbox"/>
4" - 12"	Kennedy	Model KS_RW, (Resilient Wedge)	<input type="checkbox"/>
24" - 48"	Kennedy	Rotating Disc Gate Valve	<input type="checkbox"/>
4" - 12"	Mueller	Series A-2362, (Resilient Wedge)	<input type="checkbox"/>
4" - 12"	Mueller	Series A-2361 DI (Resilient Wedge)	<input type="checkbox"/>
4" - 12"	Mueller	Series A-2362 Thick wall DI (Resilient Wedge)	<input type="checkbox"/>
14" - 36"	Mueller	Series A-2361-23 (Resilient Wedge)	<input type="checkbox"/>
4" - 36 1/4" - 12"	US Pipe	Series A-USP1/A-USP2, (Resilient Wedge)	<input type="checkbox"/>
4" - 12"	Matco-Norca	Series 225 (Resilient Wedge)	<input type="checkbox"/>
4" - 48"	VSI Waterworks	Series GVI Resilient Seated Gate Valve	<input type="checkbox"/>

SIZE FURNISHED:

<input type="checkbox"/> 4"	<input type="checkbox"/> 12"	<input type="checkbox"/> 20"	<input type="checkbox"/> 42"
<input type="checkbox"/> 6"	<input type="checkbox"/> 14"	<input type="checkbox"/> 24"	<input type="checkbox"/> 48"
<input type="checkbox"/> 8"	<input type="checkbox"/> 16"	<input type="checkbox"/> 30"	<input type="checkbox"/> other
<input type="checkbox"/> 10"	<input type="checkbox"/> 18"	<input type="checkbox"/> 36"	

POSITION:

- Vertical Position
- Bevel Position with Blow-off Assembly – WASD
- Approval required prior to use in bevel position
due to debris accumulation in tracks

COMMENTS: _____

Approved by: David Vazquez, PE

Revision History:

7-30-2019: Added Matco-Norca Series 225 valve; Specified WASD approval required for use in bevel position; changed picture;
8-26-2025: Added VSI Waterworks resilient Seated Gate Valve