DEPARTMENTAL INPUT CONTRACT/PROJECT MEASURE ANALYSIS AND RECOMMENDATION

$\underline{\boxtimes \text{New}} \underline{\square \text{OTR}} \underline{\square \text{Sole Source}} \underline{\square}$	Bid Waiver 🔲 En	nergency Previous	Contract/Project No.
Contract		N/A	
$\square \text{ Re-Bid} \qquad \square \text{ Other}$		LIVING WAGE APPLI	ES: 🔟 YES 🛄 NO
Requisition No./Project No.: FB-00929	TERM CONT		YEAR(S) WITH YEAR(S) OTR
Requisition /Project Title: Hearing Impaired Smoke Alarms			
Description: The County anticipates purchasing one thousand (1,000) hearing impaired smoke alarms. The purchase will be made using Fire Prevention and Safety Grant funds.			
	<u>Person:</u>	onzo Joseph	Phone: <u>305-375-2774</u>
Estimate Cost: \$112,000.00		NERAL FEDERAL	OTHER
<u>F</u>	unding Source: Fe	<u>deral</u>	
	ANALYSI ct History of previous pur is a new contract/purcha		
<u> </u>		YEAR	3 RD YEAR
Contractor			
Small Business Enterprise:			
Contract Value:			
Comments:			
Continued on another page (s): \Box Yes \Box No RE	COMMENDA	TIONS	
Set-aside	Sub-contractor go	bal Bid preferer	ce Selection factor
SBE			
Basis of recommendation:			
Signad Alonzo Joseph	Date	sent to SBD: 05/14/201	8
Signed: Alonzo Joseph	Date	returned to DPM:	

Revised April 2005

SECTION 2

SPECIAL TERMS AND CONDITIONS

2.1 PURPOSE

The purpose of this solicitation is to establish a contract for the purchase of hearing impaired smoke alarms for Miami-Dade County.

DEFINITIONS

- A. Volts (V) the electrical voltage in an alternating current circuit.
- B. Volts of Direct Current (VDC) –current that comes from a battery or the power supply of many electronic devices.
- C. Weighted Decibels (dBA) expression of the relative loudness of sounds in air as perceived by the human ear.
- D. Hertz (Hz) frequency in the International System of Units (SI) and is defined as one cycle per second.
- E. The Americans with Disabilities Act (ADA) is a civil rights law that prohibits discrimination against individuals with disabilities in all areas of public life, including jobs, schools, transportation, and all public and private places that are open to the general public.
- F. ANSI/UL 1971 Standard for Signaling Devices for the Hearing Impaired.

2.2 <u>TERM OF CONTRACT</u>

This contract shall commence on the first calendar day of the month succeeding approval of the contract by the Board of County Commissioners, or designee, unless otherwise stipulated in the Blanket Purchase Order issued by the Internal Services Department, Procurement Management Division. The contract shall expire on the last day of the one (1) year term.

2.3 METHOD OF AWARD

Award of this solicitation will be made to lowest priced responsive and responsible Bidder. If the Successful Bidder fails to perform in accordance with the terms and conditions of the contract, the Bidder may be deemed in default of the contract. If the Successful Bidder defaults, the County shall have the right to negotiate with the next responsive, responsible Bidder.

2.4 PRICES

The price(s) resultant from this solicitation shall remain <u>fixed and firm</u> for the term of the contract. The fixed rates quoted shall be deemed to provide full compensation to the Successful Bidder for the purchase, delivery, and any other element of cost or price.

2.5 <u>DELIVERY</u>

The Successful Bidder shall make deliveries within thirty (30) calendar days from the date of the Purchase Order. All deliveries shall be made in accordance with good commercial practice and all required delivery timeframes shall be adhered to by the awarded bidder. Items shall be delivered in full compliance with the specifications detailed throughout this solicitation.

Should the Successful Bidder fail to deliver in the number of days specified, the County reserves the right to cancel the order on a default basis after any back order period that has been mutually agree to lapsed.

2.6 EXEMPTION TO CERTAIN CLAUSES

The following clauses shall not apply:

- Section 1, Paragraph 1.11; Local Preference
- Section 1, Paragraph 1.21; Insurance Requirements
- Section 1, Paragraph 1.28; Office of the Inspection General
- Section 1, Paragraph 1.36; County User Access Program (UAP)
- Section 1, Paragraph 1.44; Small Business Enterprises (SBE) Measure
- Section 1, Paragraph 1.45; Local Certified Serviced-Disable Veteran's Business Enterprise Preference
- Section 1, Paragraph 1.47; First Source Hiring Referral Program

SECTION 3

SCOPE OF WORK

3.1 SCOPE OF WORK

The County anticipates purchasing one thousand (1,000) hearing impaired smoke alarms. The purchase will be made using Fire Prevention and Safety Grant funds.

3.2 MINIMUM REQUIREMENTS

Below are the minimum requirements of specification for the hearing impaired smoke alarms:

- 120 V with 9VDC battery back-up
- 90dBA temporal 3 evacuation piezo horn with 3100Hz (nominal) horn frequency
- ADA compliant 177 candela strobe (ANSI/UL 1971)
- Wall mount
- Nominal 2.5% sensitivity
- 3 position test switch
- Low or missing battery indicator
- 9' plug-in line cord
- 1 year warranty from date of purchase