



**FLOW**

**PLAN**

**SECTION**

**NOTES:**

1. ALL EXPOSED METALLIC THREADS ARE TO BE COATED WITH BITUMASTIC PAINT AFTER INSTALLATION.
2. USE 4' x 4' VAULT.
3. METERS WILL NOT BE INSTALLED IF THE METER BOX IS LOCATED ON A DRIVING SURFACE.
4. ALL SPACER TUBES AND TAILPIECES SHALL BE FURNISHED AND INSTALLED BY CONTRACTOR.

No. 2 VALVE BOX & LID	WS 3.10	
TIE RODS	GS 1.0	
CONC. ANCHORS	GS 1.1	
ITEM	CROSS REF.	SPEC. REF.



ISSUE DATE	APPROVED BY
10/05/2009	V.F.C.

STANDARD DETAIL  
**DUAL 2" METER INSTALLATION  
 FOR TYPICAL 4" DOMESTIC  
 SERVICE LINES**

**WS  
 4.21**  
 SHEET 1 OF 2