



NOTES:

1. RESILIENT SEATED GATE TAPPING VALVE CAN BE USED FOR SEWER CONNECTION.
2. 18" CLEARANCE FROM FITTINGS AND BELLS.
3. TAPPING VALVE AND SLEEVE SHALL BE PRESSURE TESTED AT 150 "psi" PRIOR TO BEING TAPPED.
4. TAPPING ON CONCRETE MAINS SHALL BE PRESSURE TESTED AT A LOWER PRESSURE THAN THE ACTIVE OPERATING PRESSURE OF THE MAIN.

| | | |
|-----------------|------------|------------|
| No.53 Valve Box | SS 13.0 | |
| No.3 Valve Box | WS 3.11 | |
| INSTALLATION | GS 1.8 | |
| | | |
| I T E M | CROSS REF. | SPEC. REF. |



| | |
|-------------------|--------------------|
| <u>ISSUE DATE</u> | <u>APPROVED BY</u> |
| 01/22/2009 | V.F.C. |
| 07/20/2016 | D.V. |
| | |
| | |

STANDARD DETAIL
**TYPICAL TAPPING
 VALVE SETTING
 (16" AND SMALLER)**

**GS
 1.7**
 SHEET 1 OF 1