

QUALITY. VALUE. ECONOMIC GROWTH.

WWW.MIAMIDADE.GOV/WATER



MIAMI-DADE  
COUNTY

Sheet Number: 1.2.2

Product Specifications

Miami-Dade Water & Sewer Department  
Address: 3071 SW 38th Ave, Miami, FL 33146  
Phone: (305) 665-7477

Poly Vinylchloride (PVC) Pipe-  
SDR 26/35



Minimum Standards

- ASTM D1784, D3034, F477
- MDWASD Specifications: Sections UC-250, 15060

Other Requirements

- SDR 26, 35
- Color Green for Sanitary Sewer Application

Applications

- Sewer – for gravity sewer application
- Not to be used in wellfield protection areas
- Not to be used at depths greater than 13 feet

PRE-APPROVED MANUFACTURER

- 1) CertainTeed/North American Specialty Products
- 2) Diamond Plastics Corporations
- 3) JM Eagle
- 4) National Pipe & Plastics, Inc.
- 5) Next Polymers
- 6) North American Pipe, Corp
- 7) Sanderson Pipe Corp.

Issue Date: 4/4/2016

Revised Date:

APPROVED PRODUCTS / MODELS

PIPE SIZE	MANUFACTURER	MODEL	SUBMITTED
<b>GRAVITY SEWER PIPE</b>			
4" - 12"	CertainTeed	CertaFlo Greenline	<input type="checkbox"/>
4" - 30"	Diamond Plastics Corporations	Diamond Gravity Sewer pipe	<input type="checkbox"/>
4" - 30"	JM Eagle	Gravity Sewer	<input type="checkbox"/>
4" - 18"	National Pipe & Plastics, Inc.	EVER-GREEN for sewer and storm drainage	<input type="checkbox"/>
4" - 30"	Next Polymers	Duroloc PVC Sewer Pipe	<input type="checkbox"/>
4" - 15" & 18" - 30"	North American Pipe, Corp	Gravity Sewer	<input type="checkbox"/>
4" - 15"	Sanderson Pipe Corp.	Gravity Sewer Pipe Gasket Bell	<input type="checkbox"/>
<i>Note: Other sizes require MDWASD Approval</i>			<input type="checkbox"/>

SIZES FURNISHED:

- |                              |                              |                                |
|------------------------------|------------------------------|--------------------------------|
| <input type="checkbox"/> 4"  | <input type="checkbox"/> 12" | <input type="checkbox"/> 30"   |
| <input type="checkbox"/> 6"  | <input type="checkbox"/> 15" | <input type="checkbox"/> Other |
| <input type="checkbox"/> 8"  | <input type="checkbox"/> 18" |                                |
| <input type="checkbox"/> 10" | <input type="checkbox"/> 24" |                                |

**COMMENTS:** \_\_\_\_\_

**Approved by:** James B. Ferguson, PE

**Title:** Chief, Engineering and Design Division