

QUALITY. VALUE. ECONOMIC GROWTH. WWW.MIAMIDADE.GOV/WATER MIAMI-DADE COUNTY		MIAMI-DADE COUNTY	Sheet Number: 1.2.3 Product Specifications	
Miami-Dade Water & Sewer Department Address: 3071 SW 38th Ave, Miami, FL 33146 Phone: (305) 665-7477			Poly Vinylchloride (PVC) Pipe- Schedule 80	
 		Minimum Standards - ASTM D1785, D 2467, D2464, D2564, D2865 - MDWASD Specifications: Section 15060 Other Requirements - NSF 61 for water applications Applications - Riser and Miscellaneous Piping - Plant Process Pipe - Conduits		
PRE-APPROVED MANUFACTURER 1) Accord Industries 2) Charlotte Pipe 3) JM Eagle 4) National Pipe & Plastics, Inc. 5) North American Pipe Corp. 6) Next Polymers			Issue Date: Revised Date: 2-28-2024	
APPROVED PRODUCTS / MODELS				
PIPE SIZE	MANUFACTURER	MODEL	SUBMITTED	
RISER PIPE				
1/2" - 4"	Accord Industries	Sch. 80 Bell End, Universal 100	☐	
1 1/4" - 4"	Accord Industries	Sch. 80 Bell End, Universal 100	☐	
1/2" - 4"	Charlotte Pipe	PVC Schedule 80	☐	
1 1/2" - 4"	JM Eagle	Solvent Weld SCH80	☐	
1/2" - 4"	National Pipe & Plastics, Inc.	PVC Schedule 80 IPS	☐	
1/2" - 4"	North American Pipe Corp.	ASTM D1785 Sch80: Solvent Weld Pipe	☐	
1/2" - 4"	Next Polymers	PVC Schedule 80, Solvent Weld Type, Bell and Spigot Type.	☐	
SIZES FURNISHED:				
☐ 1/2" ☐ 1 1/4" ☐ 1 1/2" ☐ 2" ☐ 4"				

COMMENTS: _____

Approved by: David Vazquez, PE

Title: Manager, Specifications

Revision History:

2-28-2024 Added Next Polymers PVC Pipe;