

QUALITY. VALUE. ECONOMIC GROWTH.

WWW.MIAMIDADE.GOV/WATER



MIAMI-DADE COUNTY

Sheet Number: 10.7

Product Specifications

Miami-Dade Water & Sewer Department
Address: 3071 SW 38th Ave, Miami, FL 33146
Phone: (305) 665-7477

Wet Well Coating



Minimum Standards

- ASTM G210
ASTM D4227
MDWASD Specifications: Sections 02536
Modified Epoxy Coating

Other Requirements

- NACE Certified Technician Available
Manufacturer's Certified Applicator
Underlayment shall be compatible with coating (manufacture's complete system)
No Calcium Aluminates allowed
WASD forces need to have the materials to in stock to spot repair coating after installation of pipe, electric conduits and mechanical supports

Applications

- Sewer Wet Wells

PRE-APPROVED MANUFACTURER

- 1) Epoxytec
2) Polymorphic Polymers Corp

Issue Date:

9/9/2016

Revised Date:

9/9/2016

APPROVED PRODUCTS / MODELS

Table with 3 columns: COATING MANUFACTURER, COATING SYSTEM, SUBMITTED. Rows include Epoxytec and Polymorphic Polymers Corp.

CHEMICAL SEAL FOR ACTIVE LEAKS:

Drill through Manhole and seal outside void

Table with 2 columns: Product Name, Submitted checkbox. Rows include Avanti, Deneef, and Quadex Quad-plug.

COMMENTS: [Blank lines for notes]

Approved by: David Vazquez, PE

Title: Specifications Manager