

**Product Specifications**

Miami-Dade Water & Sewer Department  
Address: 3071 SW 38th Ave, Miami, FL 33146  
Phone: (305) 665-7477

**HDPE Pipe Fittings**



**Minimum Standards**

- AWWA C800
- ASTM D3350, F714
- MDWASD specification: Sections 15060, UC-250

**Other Requirements**

- NSF61/ANSI for potable water applications
- Cement Lining for water application
- Protecto 401 Lining for sewer application

**Applications**

- Water and Sewer

**PRE-APPROVED MANUFACTURER**

- 1) Integrity Fusion Products, Inc.
- 2) Specified Fittings, LLC

**Issue Date: 4/4/2016**

**Revised Date:**

**APPROVED PRODUCTS / MODELS**

SIZE	MANUFACTURER	MODEL	SUBMITTED
4" - 12"	Integrity Fusion Products, Inc.	Molded Butt Fusion 45deg Elbows, IntegriFuse PE3408 / PE4710 / PE100 HDPE Fittings	<input type="checkbox"/>
4" - 12"	Integrity Fusion Products, Inc.	Molded Butt Fusion 90deg Elbows, IntegriFuse PE3408 / PE4710 / PE100 HDPE Fittings	<input type="checkbox"/>
4" - 12"	Integrity Fusion Products, Inc.	Molded Butt Fusion MJ Adapters, IntegriFuse PE3408 / PE4710 / PE100 HDPE Fittings,	<input type="checkbox"/>
4" - 8"	Integrity Fusion Products, Inc.	Molded Butt Fusion MJ Caps, IntegriFuse Fittings	<input type="checkbox"/>
4" - 30"	Integrity Fusion Products, Inc.	Molded Butt Fusion Reducers, IntegriFuse PE3408 / PE4710 / PE100 HDPE Fittings	<input type="checkbox"/>
4" - 12"	Integrity Fusion Products, Inc.	Molded Butt Fusion Tees, IntegriFuse PE3408 / PE4710 / PE100 HDPE Fittings	<input type="checkbox"/>
2" - 36"	Integrity Fusion Products, Inc.	Molded Butt Fusion Flange Adapter, IntegriFuse PE3408 / PE4710 / PE100 HDPE Fittings	<input type="checkbox"/>
4" - 30"	Specified Fittings, LLC	HDPE DIPS Fittings	<input type="checkbox"/>
4" - 30"	Specified Fittings, LLC	HDPE IPS Fittings	<input type="checkbox"/>

**SIZES FURNISHED:**

- |                              |                              |                                |
|------------------------------|------------------------------|--------------------------------|
| <input type="checkbox"/> 4"  | <input type="checkbox"/> 12" | <input type="checkbox"/> 20"   |
| <input type="checkbox"/> 6"  | <input type="checkbox"/> 14" | <input type="checkbox"/> 24"   |
| <input type="checkbox"/> 8"  | <input type="checkbox"/> 16" | <input type="checkbox"/> 30"   |
| <input type="checkbox"/> 10" | <input type="checkbox"/> 18" | <input type="checkbox"/> Other |

**COMMENTS:**

**Approved by:** James B. Ferguson, PE

**Title:** Chief, Engineering and Design Division