QUALITY. VALUE. ECONOMIC GROWTH.		
WWW.MIAMIDADE.GOV/WATER	MIAMI-DADE COUNTY	



Sheet Number: 4.9

Product Specifications

Miami-Dade Water & Sewer Department Address: 3071 SW 38th Ave, Miami, FL 33146

Phone: (305) 665-7477

Ball Valves





Minimum Standards

- Full Port
- Two Piece
- 150 lb. PSI
- 600PSI Non-Shock/CWP 150 PSI SWP Brass
- 316 Stainless Steel Body
- Lead Free Brass
- Locking Handle
- ASME B16.34, MSS SP-110
- Blow-Out Proof Stem

Other Requirements

N/A

Applications

- Sewer Stainless Steel
- Water Bronze

PRE-APPROVED MANUFACTURER

- 1) Apollo
- 2) Ford
- 3) FNW
- 4) James Jones
- 5) Matco-Norca Industrial
- 6) Stockham

Issue D	ate:
---------	------

11/29/2018

Revised Date:

STAINLESS STEEL BALL VALVE FOR SEWER AUTOMATIC AIR RELEASE VALVES

Size	MANUFACTURER	MODEL	SUBMITTED
2"	Matco-Norca Industrial – Stainless Steel	20SST	
2" Standard Locking Lever	FNW – Stainless Steel	240TLF	
2"	Stockham	T-2852-SS-R-66-LL	

BRASS BALL VALVE FOR FLUSHING VALVE OUTLET AND MANUAL AIR RELEASE VALVES

SIZE	MANUFACTURER	MODEL	SUBMITTED
2	Apollo	94ALF-A	
2"	Ford	BLA18-777-TA-NL	
2"	Matco-Norca Industrial - Brass	759LF	
2"	Matco-Norca Industrial - Brass	240T04LF	
2"	James Jones Co	E1998 L/C	

COMMENTS:			

STAINLESS STEEL BALL VALVE FOR SEWER AUTOMATIC AIR RELEASE VALVES				
SIZE	MANUFACTURER	MODEL	SUBMITTED	
Approved by: MDWASD Departmental Standards, Specifications, and Product Committee				