

QUALITY. VALUE. ECONOMIC GROWTH.

WWW.MIAMIDADE.GOV/WATER



MIAMI-DADE  
COUNTY

Sheet Number: 7.0

Product Specifications

Miami-Dade Water & Sewer Department  
Address: 3071 SW 38th Ave, Miami, FL 33146  
Phone: (305) 665-7477

Saddles



Minimum Standards

- AWWA C800
- ASTM B62, B584
- MDWASD Specifications: Section 15065

Other Requirements

- NSF61/ANSI for potable water applications

Applications

- Water and Sewer

PRE-APPROVED MANUFACTURER

- |                         |                           |
|-------------------------|---------------------------|
| 1) AY McDonald          | 5) Power Seal             |
| 2) Ford                 | 6) Romac Industries, Inc. |
| 3) JCM                  | 7) Smith-Blair            |
| 4) Jones Water Products |                           |

Issue Date: 4/4/2016

Revised Date:

APPROVED PRODUCTS / MODELS

SIZE	MANUFACTURER	MODEL	SUBMITTED
2" - 12"	AY McDonald	Two Piece Brass Saddle - 3801	<input type="checkbox"/>
2" - 12"	AY McDonald	Two Piece Brass Saddle - 3802	<input type="checkbox"/>
4" - 12"	AY McDonald	Two Piece Brass Saddle - 3805	<input type="checkbox"/>
4" - 12"	AY McDonald	Two Piece Brass Saddle - 3806	<input type="checkbox"/>
4" - 30"	Ford	202B DOUBLE STRAP BRASS SADDLES	<input type="checkbox"/>
4" - 30"	Ford	FC202-xxx-xxx style	<input type="checkbox"/>
2" - 30"	Ford	Style F101, FS101, FC101, F202, FS202, FC202, FSD202, FCD202	<input type="checkbox"/>
4" - 24"	JCM	JCM 406, 408	<input type="checkbox"/>
4" - 24"	Jones Water Products	J 969/979	<input type="checkbox"/>
2" - 24"	Power Seal	3417DI, 3417AS	<input type="checkbox"/>
2" - 30"	Romac Industries, Inc.	202S/202N	<input type="checkbox"/>
6" - 48"	Romac Industries, Inc.	Style "CB" Sewer Saddle	<input type="checkbox"/>
4" - 24"	Smith-Blair	317 Service Saddles	<input type="checkbox"/>

**SIZE FURNISHED:**

- |                              |                              |                                |
|------------------------------|------------------------------|--------------------------------|
| <input type="checkbox"/> 4"  | <input type="checkbox"/> 12" | <input type="checkbox"/> 20"   |
| <input type="checkbox"/> 6"  | <input type="checkbox"/> 14" | <input type="checkbox"/> 24"   |
| <input type="checkbox"/> 8"  | <input type="checkbox"/> 16" | <input type="checkbox"/> 30"   |
| <input type="checkbox"/> 10" | <input type="checkbox"/> 18" | <input type="checkbox"/> Other |

**COMMENTS:** \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

**Approved by:** James B. Ferguson, PE

**Title:** Chief, Engineering and Design Division