

QUALITY. VALUE. ECONOMIC GROWTH.

WWW.MIAMIDADE.GOV/WATER



MIAMI-DADE
COUNTY

Sheet Number: 8.2

Product Specifications

Miami-Dade Water & Sewer Department
Address: 3071 SW 38th Ave, Miami, FL 33146
Phone: (305) 665-7477

Water Services – Meter Couplings



Minimum Standards

- AWWA C700, C800
- MDWASD Specifications: Section 15065

Other Requirements

- ANSI/NSF Standard 61
- No Lead – All brass components shall be marked “NL”

Applications

- Water

PRE-APPROVED MANUFACTURER

- 1) A.Y. McDonald
- 2) Ford
- 3) Mueller
- 4) Cambridge Brass

Issue Date: 4/4/2016

Revised Date: 5/09/2018

APPROVED PRODUCTS / MODELS

SIZE	MANUFACTURER	MODEL	SUBMITTED
5/8" - 1 x 2 13/16"	A.Y. McDonald	74624 meter swivel nut x MNPT	<input type="checkbox"/>
2"	A.Y. McDonald	7611-44 2 PVC Comp x MNPT	<input type="checkbox"/>
2"	A.Y. McDonald	7611-55 2 IP Comp x MNPT	<input type="checkbox"/>
1"	A.Y. McDonald	74638-22 meter swivel nut x CTS	<input type="checkbox"/>
5/8" - 2"	A.Y. McDonald	74620 meter swivel nut with wire seal hole x MNPT	<input type="checkbox"/>
5/8" - 1"	Ford	C34-xx-NL style meter swivel nut x pack joint CTS	<input type="checkbox"/>
1 1/2" - 2"	Ford	CT35-xx-NL style Lok-Pak Meter Coupling	<input type="checkbox"/>
1/2" - 1"	Mueller	H10890N meter x MIP	<input type="checkbox"/>
3/4" - 2"	Mueller	H10891N meter nut x MIP	<input type="checkbox"/>
1/2" - 1"	Mueller	H10896N meter x MIP	<input type="checkbox"/>
3/4" - 1"	Mueller	H14201N meter swivel nut x CTS	<input type="checkbox"/>
5/8" - 1"	Cambridge Brass	417NL-TXBX meter swivel nut x CTS	<input type="checkbox"/>

SIZE FURNISHED:

Inlet Size: _____ Outlet Size: _____

COMMENTS: _____

Approved by: MDWASD Departmental Standards, Specifications, and Product Committee

Revision History:

5-09-2018 – Added Cambridge Brass; Added Product Description to all Couplings.